

IRC R506.2.3

Vapor retarder NOT required under concrete slabs (This should have been amended out, administratively we won't require this)

Amendment R506.2.4

Concrete slab reinforcement NOT required (This should have been corrected in the amendment).

Amendment M1501.2

Q: Would additional combustion air be required for a mechanically ventilated crawlspace next to and opened to a basement.

A: NO, but mechanical exhaust systems shall not cause an indoor depressurization in excess of negative 3 pa.

Amendment N1112.7

Requires mechanical system piping to be insulated. The PEX Piping hydronic floor heating system if designed to be in contact with underside of the floor system or embedded in concrete--no insulation required where in contact with the floor or in concrete but needed on lines up to those placements.

Amendment R702.4.4

Q: Is cement backer board required in shower compartments of one-piece or three-piece interlocking shower panels.

A: NO not for total one-piece shower or shower/tub units or three/four-piece shower units designed to interlock and be installed without backer.