



## Application for Haunted House

Name of Company \_\_\_\_\_

Address of Where Haunted House is to be  
Placed \_\_\_\_\_

Contact Person \_\_\_\_\_ Telephone \_\_\_\_\_

Dates Haunted House Will Be In Place \_\_\_\_\_ to \_\_\_\_\_

Best Time \_\_\_\_\_ Best Date \_\_\_\_\_ to Inspect Haunted House

### Requirements for haunted houses:

1. All haunted houses must conform to the Uniform Building Code for temporary buildings or structures.
2. No fire protection systems (alarms or sprinklers) in any building shall be obstructed by the construction of this haunted house.
3. "NO SMOKING" signs must be posted at the entrance.
4. There shall be trained staff members with flashlights available at all times. These staff members must know the interior maze, exit facilities, and enforce "no smoking" restrictions within the area.
5. No readily combustible material can be used for construction or decoration in the haunted house unless it is treated with a flame-retardant chemical. **NO BLACK PLASTIC IS ALLOWED.**
6. All electrical wiring must conform to the National Electrical Code for temporary installations.
7. Fire extinguishers of at least a 2A rating must be placed every 75 feet of travel distance. The trained staff must know where they are and how to use them.
8. Customers may be required to be escorted through the haunted houses by haunted house staff, i.e. 10 in/10 out.
9. Additional single station smoke detectors may be required by the Fire Marshal.

An on-site consultation and inspection of the area to be utilized as a "haunted house" must be conducted by Poudre Fire Authority personnel before the house is opened to the public.

If you have any questions or would like a pre-construction consultation, please contact the Fire Prevention Bureau at (970) 416-2890.

[Click to Reset Form](#)

[Click to Submit Application](#)