

N. Division 10 - Specialties1. Washroom Accessories

Provide the following in public restrooms: (verify with City's Custodial Contract Manager) Installed with accordance of all ADA standards.

- a) Paper towel dispenser - Georgia-Pacific Cormatic VuAll (P15) #HV200K Smoked plastic high capacity 13 5/8" x 13" x 9" - minimum one per washroom
- b) Toilet tissue dispenser – SCA (Tork). 56T1 – Eclipse Quikview 9" Twin. Jumbo roll, smoked plastic 12" x 20 1/2" x 6"
- c) Sanitary napkin disposal bin - one per each female water closet Rubbermaid #6140 with Rigid liner
- d) Sanitary napkin vendor - one per female washroom
- e) Equip toilet compartments for the disabled with peened finish type 304 stainless steel grab bars, lengths to comply with ANSI A117.1-2003
- f) Liquid soap dispenser - Bobrick Impact plastic. – B-40 Classic Series
- g) Shelves - one per restroom
- h) Toilet partitions - use of solid plastic or metal partitions should be considered. Ceiling hung mounted only, with self-closing stall door hinges. Provide extra blocking in the walls for solid fastening. Urinal screen must be wall mounted.
- i) One large, continuous mirror should be provided in each restroom.
- j) Faucets to be water conserving and touch- free - Zurn or Sloan.
- k) Flushometers – Zurn or Sloan.
- l) Hand dryers - Sloan "optimum".
- m) Trash Receptacles – Rubbermaid Untouchable square container - #3569, 23 gallon capacity. Untouchable top # 2689.

2. Flagpoles

- a. Use a secure system whereby flagpole cannot be lowered accidentally or by vandals.
- b. Provide (if needed) three flag poles for displaying Federal, State, and City flags. The Federal flagpole shall be higher than the other two.
- c. Flag poles are to be lighted and have timers for on/off operation.

3. Building Signage

ADA Compliant - tactile letters and braille for signs identifying public areas. Include international ADA Symbol of accessibility at restroom signs.

4. Drinking Fountains

At least one water fountain should be provided on every floor near restrooms and meet ADA criteria.

5. Fire Extinguishers

Provide ULC listed wall mounted minimum 10 lb. ABC type fire extinguishers in all service rooms. In finished areas provide extinguishers in a recessed metal or plastic cabinet.

6. Raised Access Floors - consider where possible.

7. Baby Changing Station

In public restrooms (men's and women's) and family restrooms, a horizontal, wall-mounted baby changing station Koala Kare Model KB100 or equal shall be installed. In certain situations, consider having a permanent personal baby changing table.