

LIGHTING WATTAGE WORKSHEET Space-by-Space Method

To comply with Fort Collins adopted commercial energy code 2018 IECC, a lighting wattage worksheet must be submitted for new buildings and whenever 50% or more of the lighting changed, added or replaced for a tenant finish. Find the applicable allowances recorded in section C405. Record these allowances with floor area to the allowance table. Sum up the Total Interior Lighting Power Allowance for this table. Keeping this allowance in mind, list every new light fixture and its individual wattage on the Proposed Interior Connected Lighting Power worksheet. Sum the proposed lighting and verify that this is equal or less than the Allowance. When the proposed is greater than the Allowance, lighting fixtures must be removed or replaced with lower wattage fixtures. Along with a lighting plan, submit the completed Lighting Wattage worksheets for review and approval. The lighting wattage form from the ComCheck program can also be used.

WATTAGE ALLOWANCE: SPECIFIC SPACE METHOD (2018 IECC table C405.3.2(2)

| Room Number | Specific Space Activity | Area square feet | Allowed watts/sq.ft. | Total allowed watts |
|----------------|-------------------------|---------------------|-------------------------|---------------------|
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | Total Interior | | | |

Total Interior Lighting Power Allowance:

PROPOSED INTERIOR CONNECTED LIGHTING POWER

| | | Number of | Watts per | Proposed |
|----------|---|----------------|--------------|----------|
| Location | Fixture description (lamp/bulb type and quantity) | fixtures | fixture | watts |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| L | Total Interior I | ialatina Matta | an Dronocod. | |

Total Interior Lighting Wattage Proposed:

TABLE C405.3.2(2) INTERIOR LIGHTING POWER ALLOWANCES:

SPACE-BY-SPACE METHOD

| | JFACL-DT-3 | | |
|---|----------------------|--|--|
| COMMON SPACE TYPES ^a | LPD (watts/sq.ft) | | |
| Atrium | , , | | |
| Less than (x) 40 fast in height | 0.03 per | | |
| Less than (<) 40 feet in height | ft/height | | |
| C restor than (>) 40 fast in height | 0.40+0.02 | | |
| Greater than (>) 40 feet in height | per ft/height | | |
| Audience seating area | | | |
| In an auditorium | 0.63 | | |
| In a convention center | 0.82 | | |
| In a gymnasium | 0.65 | | |
| In a motion picture theater | 1.14 | | |
| In a penetentiary | 0.28 | | |
| In a performing arts theater | 2.03 | | |
| In a religious building | 1.53 | | |
| In a sports arena | 0.43 | | |
| Otherwise | 0.43 | | |
| Banking activity area | 0.86 | | |
| Breakroom (See Lounge/breakroom) | | | |
| Classroom/lecture hall/training room | | | |
| In a penetentiary | 1.34 | | |
| Otherwise | 0.96 | | |
| Computer room | 1.33 | | |
| Conference/meeting/multipurpose | 1.07 | | |
| Copy /print room | 0.56 | | |
| Corridor | T | | |
| In a facility for the visually impaired | 0.92 | | |
| (not used primarily by staff) ^b | | | |
| In a hospital | 0.92 | | |
| In a manufacturing facility | 0.29 | | |
| Otherwise | 0.66 | | |
| Courtroom | 1.39 | | |
| Dining area | 1 | | |
| In a bar/lounge or leisure dining | 0.93 | | |
| In a cafeteria or fast food dining | 0.63 | | |
| In a facility for the visually impaired (not used primarily by staff)b | 2.00 | | |
| In family dining | 0.71 | | |
| In a penetentiary | 0.96 | | |
| Otherwise | 0.63 | | |
| Electrical/mechanical room | 0.43 | | |
| Emergency vehicle garage | 0.41 | | |
| Food preparation area | 1.06 | | |
| Guestroom ^{c,d} | 0.77 | | |
| Laboratory | | | |
| In or as a classroom | 1.20 | | |
| | 1.20 | | |

| | LPD | | | |
|---|---------------|--|--|--|
| COMMON SPACE TYPES ^a | (watts/sq.ft) | | | |
| Otherwise | 1.45 | | | |
| Laundry/washing area | 0.43 | | | |
| Loading dock, interior | 0.58 | | | |
| Lobby | | | | |
| For an elevator | 0.68 | | | |
| In a facility for the visually impaired | | | | |
| not used primarily by staff) ^b | | | | |
| In a hotel | 1.06 | | | |
| In a motion picture theater | 0.45 | | | |
| In a performing arts theater | 1.7 | | | |
| Otherwise | 1.0 | | | |
| Locker room | 0.48 | | | |
| Lounge/breakroom | | | | |
| In a healthcare facility | 0.78 | | | |
| Otherwise | 0.62 | | | |
| Office | | | | |
| Enclosed | 0.93 | | | |
| Open plan | 0.81 | | | |
| Parking area, interior | 0.14 | | | |
| Pharmacy area | 1.34 | | | |
| Restroom | | | | |
| In a facility for the visually impaired | 0.96 | | | |
| (not used primarily by staff) ^b | | | | |
| Otherwise | 0.85 | | | |
| Sales area | 1.22 | | | |
| Seating area, general | 0.42 | | | |
| Stairway (see space containing stairway) |) | | | |
| Stairwell | 0.58 | | | |
| Storage room | 0.46 | | | |
| Vehicular maintenance area | 0.56 | | | |
| Workshop | 1.14 | | | |
| BUILDING TYPE SPECIFIC SPACE TYPES ^a | LPD | | | |
| | (watts/sq.ft) | | | |
| Automotive (see vehicular maintenace a | area) | | | |
| Convention center-exhibit space | 0.88 | | | |
| Dormitory-living quarters ^{c,d} | 0.54 | | | |
| Facility for the visually impaired ^b | | | | |
| In a chapel (not used by primary staff) | 1.06 | | | |
| In rec room (not used by primary staff) | 1.80 | | | |
| Fire station-sleeping quarters ^c | 0.20 | | | |
| Gymnasium/fitness center | | | | |
| In an exercise area | 0.50 | | | |
| In a playing area | 0.82 | | | |
| (continued) | | | | |

| BUILDING TYPE SPECIFIC SPACE TYPES ^a | LPD | | | |
|---|---------------|--|--|--|
| | (watts/sq.ft) | | | |
| Healthcare facility | | | | |
| In an exam/treatment room | 1.68 | | | |
| In an imaging room | 1.06 | | | |
| In a medical supply room | 0.54 | | | |
| In a nursery | 1.00 | | | |
| In a nurse's station | 0.81 | | | |
| In an operating room | 2.17 | | | |
| In an patient room ^c | 0.62 | | | |
| In a physical therapy room | 0.84 | | | |
| In a recovery room | 1.03 | | | |
| Library | | | | |
| In a reading area | 0.82 | | | |
| In the stacks | 1.20 | | | |
| Manufacturing facility | | | | |
| In a detailed manufacturing area | 0.93 | | | |
| In an equipment room | 0.65 | | | |
| In an extra-high-bay area > 50' high | 1.05 | | | |
| In a low-bay-area 25'-50' high | 0.75 | | | |
| In a low-bay-area < 25' high | 0.96 | | | |
| Museum | | | | |
| In a general exhibition area | 1.05 | | | |
| In a restoration room | 0.85 | | | |
| Performing arts theater dressing rm | 0.36 | | | |
| Post office-sorting area | 0.68 | | | |
| Religious buildings | | | | |
| In a fellowship hall | 0.55 | | | |
| In a worship/pulpit/choir area | 1.53 | | | |
| Retail facilities | | | | |
| In a dressing/fitting room | 0.5 | | | |
| In a mall concourse | 0.9 | | | |
| Sports arena-playing area | | | | |
| For a Class I facility ^e | 2.47 | | | |
| For a Class II facility ^f | 1.96 | | | |
| For a Class III facility ^g | 1.7 | | | |
| For a Class IV facility ^h | 1.13 | | | |
| Transportation facility | | | | |
| In a baggage/carousel area | 0.45 | | | |
| In an airport concourse | 0.31 | | | |
| At a terminal ticket counter | 0.62 | | | |
| Warehouse-storage area | | | | |
| For med to bulky, palletized items | 0.35 | | | |
| For smaller, hand-carried items | 0.69 | | | |