

Historic Preservation Services

Community Development & Neighborhood Services 281 North College Avenue P.O. Box 580 Fort Collins, CO 80522.0580

970.416.4250 preservation@fcgov.com fcgov.com/historicpreservation

CERTIFICATE OF APPROPRIATENESS ISSUED: August 16, 2021 EXPIRATION: August 16, 2022

Timothy L. Cochran & Carol Leigh Murray 630 Peterson Street Fort Collins, CO 80524

Dear Property Owner:

This letter provides you with confirmation that the proposed changes to your designated Fort Collins landmark property, theAddie R. Debolt House at 630 Peterson Street have been approved by the City's Historic Preservation Division because the proposed work meets the criteria and standards in Chapter 14, <u>Article IV</u> of the Fort Collins Municipal Code.

1) Installation of fourteen (14) solar panels and accompanying electrical equipment on rear half of building roof.

Notice of the approved application has been provided to building and zoning staff to facilitate the processing of any permits that are needed for the work.

Please note that all ensuing work must conform to the approved plans. Any non-conforming alterations are subject to stop-work orders, denial of Certificate of Occupancy, and restoration requirements and penalties.

If the approved work is not completed prior to the expiration date noted above, you may apply for an extension by contacting staff at least 30 days prior to expiration. Extensions may be granted for up to 12 additional months, based on a satisfactory staff review of the extension request.

Property owners can appeal staff design review decisions by filing a written notice of appeal to the Director of Community Development & Neighborhood Services within fourteen (14) days of this decision. If you have any questions regarding this approval, or if I may be of any assistance, please do not hesitate to contact me. I may be reached at <u>jbertolini@fcgov.com</u>, or 970-416-4250.

Sincerely,

Jim Bertolini Historic Preservation Planner

Applicable Code	Summary of Code Requirement and Analysis (Rehabilitation)	Standard Met
Standard		(Y/N)
SOI #1	A property will be used as it was historically or be given a new use that requires minimal change to its distinctive materials, features, spaces, and spatial relationships; No change in use is proposed.	Y
SOI #2	The historic character of a property will be retained and preserved.	Y
	The removal of distinctive materials or alteration of features, spaces, and spatial relationships that characterize a property will be avoided.	
	The revised plans submitted on July 9 opted to remove the forward facing panels on the front (west) gable. The remaining solar panels are all on rear elevations of the historic home or on the south-facing slope of a non-historic addition at the rear (east) of the main historic building. The visibility of the panels will be automate low and meets this Standard	
SOI #2	Will be extremely low and meets this Standard.	
501 #3	Each property will be recognized as a physical record of its time, place, and use. Changes that create a false sense of historical development, such as adding conjectural features or elements from other historic properties, will not be undertaken.	N/A
SOI #4	Changes to a property that have acquired historic significance in their own right will be retained and preserved.	N/A
SOI #5	Distinctive materials, features, finishes, and construction techniques or examples of craftsmanship that characterize a property will be preserved.	N/A
SOI #6	Deteriorated historic features will be repaired rather than replaced. Where the severity of deterioration requires replacement of a distinctive feature, the new feature will match the old in design, color, texture, and, where possible, materials. Replacement of missing features will be substantiated by documentary and physical evidence.	N/A
SOI #7	Chemical or physical treatments, if appropriate, will be undertaken using the gentlest means possible. Treatments that cause damage to historic materials will not be used.	N/A
SOI #8	Archeological resources will be protected and preserved in place. If such resources must be disturbed, mitigation measures will be undertaken.	N/A
	No excavation is proposed as part of this project.	

SOI #9	New additions, exterior alterations, or related new construction shall not destroy historic materials that characterize the property. The new work shall be differentiated from the old and shall be compatible with the massing, size, scale, and architectural features to protect the historic integrity of the property and its environment. The three sets of solar panels and accompanying equipment, totaling fourteen panels, are located on rear and/or non-historic elements of the property and will have minimal-to-no visibility from public rights-of-way on Peterson Street. They are flush- mounted and accompanying equipment,	Y
SOI #10	New additions and adjacent or related new construction will be undertaken in such a manner that, if removed in the future, the essential form and integrity of the historic property and its environment would be unimpaired. The new solar panels and accompanying equipment are fully reversible, and can be removed from the roof without significant damage to historic roof framing or other character-defining features.	Y



Date: 7/7/2021 Permit #: 8306 Project Name: Carol Cochran Address: 630 Peterson St - Fort Collins, Colorado 80524

To whom it may concern,

Panels need to be moved around to not be on the front of the home. This permit pack reflects these changes.

Please reach out to me directly if you have any questions.

McKay Ashton PV Design Engineering Mckay.ashton@blueravensolar.com design@blueravensolar.com 385-498-6700 Elizabeth Kellam PV Design Manager Elizabeth.kellam@blueravensolar.com design@blueravensolar.com 385-498-6700



The Future of Energy. Today.

GENERAL NOTES

CODE AND STANDARDS

1. ALL WORK SHALL COMPLY WITH 2020 NATIONAL ELECTRIC CODE (NEC), 2018 INTERNATIONAL BUILDING CODE (IBC), 2018 INTERNATIONAL RESIDENTIAL CODE (IRC), 2018 INTERNATIONAL PLUMBING CODE (IPC), AND ALL STATE AND LOCAL BUILDING, ELECTRICAL, AND PLUMBING CODES.

2. DRAWINGS HAVE BEEN DETAILED ACCORDING TO UL LISTING REQUIREMENTS.

SITE NOTES / OSHA REGULATION

1. A LADDER SHALL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS

2. THE PV MODULES ARE CONSIDERED NON-COMBUSTIBLE AND THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM. 3. THE SOLAR PV INSTALLATION SHALL NOT OBSTRUCT ANY PLUMBING, MECHANICAL, OR BUILDING ROOF VENTS. 4. ROOF COVERINGS SHALL BE DESIGNED, INSTALLED, AND MAINTAINED IN ACCORDANCE WITH THIS CODE AND THE APPROVED MANUFACTURER'S INSTRUCTIONS SUCH THAT THE ROOF COVERING SHALL SERVE TO PROTECT THE BUILDING OR STRUCTURE.

SOLAR CONTRACTOR

1. MODULE CERTIFICATIONS WILL INCLUDE UL1703, IEC61646, IEC61730.

2. IF APPLICABLE, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE MARKED GROUNDING LUG HOLES PER THE MANUFACTURER'S INSTALLATION REQUIREMENTS

3. AS INDICATED BY DESIGN, OTHER NRTL LISTED MODULE GROUNDING DEVICES MAY BE USED IN PLACE OF STANDARD GROUNDING LUGS AS SHOWN IN MANUFACTURER DOCUMENTATION AND APPROVED BY THE AHJ. 4. CONDUIT AND WIRE SPECIFICATIONS ARE BASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO

LIMIT UP-SIZING AS REQUIRED BY FIELD CONDITIONS. 5 CONDUIT POINT OF PENETRATION FROM EXTERIOR TO INTERIOR TO BE INSTALLED AND SEALED WITH A

SUITABLE SEALING COMPOUND. 6. DC WIRING LIMITED TO MODULE FOOTPRINT W/ ENPHASE AC SYSTEM.

7. ENPHASE WIRING SYSTEMS SHALL BE LOCATED AND SECURED UNDER THE ARRAY W/ SUITABLE WIRING CLIPS. 8. MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC UNLESS NOT AVAILABLE

9 ALL INVERTERS MOTOR GENERATORS PHOTOVOLTAIC MODULES PHOTOVOLTAIC PANELS AC

PHOTOVOLTAIC MODULES, DC COMBINERS, DC-TO-DC CONVERTERS, SOURCE CIRCUIT COMBINERS. AND CHARGE CONTROLLERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER NEC 690.4(B).

10. ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE.

11. TERMINALS AND LUGS WILL BE TIGHTENED TO MANUFACTURER TORQUE SPECIFICATIONS (WHEN PROVIDED) IN ACCORDANCE WITH NEC CODE 110.14(D) ON ALL ELECTRICAL CONNECTIONS.

EQUIPMENT LOCATIONS

1. PROPER ACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL BE PROVIDED AS PER SECTION NEC 110.26.

2. EQUIPMENT INSTALLED IN DIRECT SUNLIGHT MUST BE RATED FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY NEC 690 31(A) AND NEC TABLE 310 15(B)

3. ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC

APPLICABLE CODES

4. ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE.

PROJECT INFORMATION:

NUMBER OF STORIES: 1 **CONDUIT RUN: Exterior** ECOBEE QTY: 0 LIGHT BULB QTY: 0 **PV METER: Not Required**

ROOF TYPE (1) INFORMATION:

ROOF TYPE: Comp Shingle FRAMING TYPE: Rafter SHEATHING TYPE: SKIP STANDOFF: SFM Infinity Switchblade Flashkit RACKING: Unirac SFM Infinity @ 48" OC Portrait / 72" OC Landscape NUMBER OF ATTACHMENTS: 27

ROOF TYPE (2) INFORMATION (IF APPLICABLE): *SEE PV4.2

SYSTEM TO BE INSTALLED INFORMATION:

SYSTEM SIZE: 4.55 kW DC MODULE TYPE: (14) REC Solar REC325TP3M INVERTER TYPE: Enphase IQ7-60-2-US MONITORING: Enphase IQ Combiner 3 X-IQ-AM1-240-3

AERIAL VIEW

ы

Peterson (

υ

eters



DESIGN CRITERIA

NECESSARY ADDITIONAL WORK NEEDED FOR INSTALLATION



_							
		LEGEND		-			
)	۲	JUNCTION BOX	DILLE	DAVEN			
$\left\{ \left \right. \right. \right\}$	M	UTILITY METER	BLUE RAVEN				
$\langle $	MSP	MAIN SERVICE PANEL	1403 N. Res Orem, U	search Way T 84097			
$\left \right $	AC	AC DISCONNECT	800.37 WWW.BLUERAV	7.4480 /ENSOLAR.COM			
$\left \right $	СВ	COMBINER BOX	USED FOR THE BE EXCEPT BLUE RA	ED SHALL NOT BE NEFIT OF ANYONE VEN SOLAR NOR			
$\left \right $	LC	LOAD CENTER	SHALL IT BE DISCLO IN PART TO OT RECIPIENTS ORGA	DSED IN WHOLE OR HERS OUTSIDE NIZATION, EXCEPT			
$\Big)$	SUB	SUBPANEL	IN CONNECTION W USE OF THE RESPE WITHOUT THE WRI OF BLUE RAVE	ITH THE SALE AND CTIVE EQUIPMENT, TTEN PERMISSION EN SOLAR LLC.			
$\left\{ \right $	PV	PV METER	NAB	CEP			
$\left \right $	TS	TRANSFER SWITCH	CERT	IFIED			
$\Big)$		FIRE SETBACK	PV INSTA PROFES	LLATION SIONAL Gurney			
\langle		TRENCHING	#PV-0117	19-015866			
3		PROPERTY LINE	BRS FIELD OPS 385-498-6700				
Ś	SCA	ALE: 1/16" = 1'-0"					
			CUSTOMER INFORMATION: Carol Cochran 630 Peterson St Eart Colline, Colorado 80524	DC SYSTEM SIZE: 4.55 kW DC			
)			Adam	Cook			
$\left\langle \right\rangle$			PLOT DATE: July 7	, 2021			
			PROJECT NUMBER:	326			
$\left. \right\rangle$			SHEET NAME: SITE	PLAN			
)			REVISION: B	PAGE NUMBER:			





15	(1) (1) (1) (1)	10 AWG THHN/THWN-2, CU., BLACK (L1) 10 AWG THHN/THWN-2, CU., RED (L2) 10 AWG THHN/THWN-2, CU., WHITE (N) 10 AWG THHN/THWN-2, CU., GREEN (EGC)	14.0 A AC 240 V AC	3	(1) (1) (1)	10 AWG THHN/THWN-2, CU., BLACK (L1) 10 AWG THHN/THWN-2, CU., RED (L 2) 10 AWG THHN/THWN-2, CU., GREEN (EGC) OR 10 - 2 UF-B W/G, THHN/THWN-2, SOLID CU.	MAX	14.0 A AC 240 V AC	2	(1) (1) (1)	10 AWG THHN/THWN-2, CU., BLACK (L1) 10 AWG THHN/THWN-2, CU., RED (L2) 10 AWG THHN/THWN-2, CU., GREEN (EGC) OR 10 - 2 UF-B W/G, THHN/THWN-2, SOLID CU.	MAX	14.0 A AC 240 V AC	1	(1) 1 (1)	2-2 TC-ER, 6 AWG
	(1)	3/4 INCH EMT	EXTERIOR		(1)	3/4 INCH EMT		EXTERIOR		(1)	3/4 INCHEMT	1	EXTERIOR			
	(2)	6 AWG THHN/THWN-2, CU., BLACK (L1)														
116	(2)	6 AWG THHN/THWN-2, CU., RED (L2)		DES	IGNE	FR NOTES										
	(2)	6 AWG THHN/THWN-2, CU., WHITE (N)														
	(1)	10 AWG THHN/THWN-2, CU., GREEN (EGC)		EXTE		OL SUB PANEL ADD-IN WE WILL FEED A NEW SUBPA	NFI W	ITH THE EXI	STING	SOA BRE	AKER THEN INSTALL NEW 60A BREAKER IN 1		ONDUIT TO F	3F RAN	ATIFA	ST 7/8 IN A
	(1)	1 INCH IMC		NEW	UB TC	O FEED THE INTERIOR SUBPANEL. ALSO INSTALL PV I	BREAK	ER IN NEW S	SUBPAN	IEL.THE	AC DISCONNECT MUST REQUIRE A TOOL TO	2. TERN	INALS AND I	LUGS W	ILL BE 1	FIGHTENED

OPEN. USE A NUT AND BOLT TO FASTEN THE DISCONNECT COVER.

(E) 100A MAIN SERVICE PANEL NO MAIN BREAKER **PV AC DISCONNECT** ENPHASE IQ COMBINER 3 NON-FUSED LOCKABLE, VISIBLE OPEN *JUNCTION BOX X-IQ-AM1-240-3 (6 OR LESS HANDLED **OPTIONAL IF UF-B** (N) 125A SUBPANEL (SOLAR LOAD ONLY) DISCONNECTS- NEC 230.71) 30A, 240V, 2-POLE CABLE USED FOR ENTIRE HOMERUN N) 20A / 2F JB -01 (N) 60A / 2P --TO (E) LOADS (E) LOADS (E) 60A / 2P (N) 20A / 2P -010 G 120/240 VAC 60HZ 1 PHASE TO UTILITY GRID TO (E) LOADS (16) (E) GROUNDING _ ELECTRODE(S)

INTERCONNECTION NOTES

705.12(B)(3) THE FOLLOWING METHOD(S) SHALL BE USED TO DETERMINE THE RATINGS OF BUSBARS: (2) WHERE TWO SOURCES, ONE A PRIMARY POWER SOURCE AND THE OTHER ANOTHER POWER SOURCE, ARE LOCATED AT OPPOSITE ENDS OF A BUSBAR THAT CONTAINS LOADS, THE SUM OF 125 PERCENT OF THE POWER-SOURCE(S) OUTPUT CIRCUIT CURRENT AND THE RATING OF THE OVERCURRENT DEVICE PROTECTING THE BUS BAR SHALL NOT EXCEED 120 PERCENT OF THE AMPACITY OF THE BUSBAR.



MODULE SPECIFICATIONS	REC Solar REC325TP3M	DESIGN LOCATION AND TEMPERATURES						122	CONDUCTOR SIZE CA	LCULATIONS
RATED POWER (STC)	325 W	TEMPERATURE DATA SOURCE			A	SHRAE 2%	AVG. HI	GH TEMP	MICROINVERTER TO	MAX. SHORT CIRCUIT
MODULE VOC	39.5 V DC	STATE					(Colorado	JUNCTION BOX (1)	MAX. CURF
MODULEVMP	34.1 V DC	CITY					Fo	rt Collins		CONDUCTOR (TC-ER,
MODULE IMP	9.54 A DC	WEATHER STATION				FORT	COLLINS	(AWOS)		COND
MODULE ISC	10.36 A DC	ASHRAE EXTREME LOW TEMP (°C)						-23		AMB. TEMP. AM
VOC CORRECTION	-0.28 %/°C	ASHRAE 2% AVG. HIGH TEMP (°C)						34		
VMP CORRECTION	-0.37 %/°C	184 							JUNCTION BOX TO	MAX. SHORT CIRCUIT
SERIES FUSE RATING	20 A DC	SYSTEM ELECTRICAL SPECIFICATIONS	CIR 1	CIR 2	CIR 3	CIR 4	CIR 5	CIR 6	JUNCTION BOX (2)	MAX. CURF
ADJ. MODULE VOC @ ASHRAE LOW TEMP	44.8 V DC	NUMBER OF MODULES PER MPPT	14						COND	JCTOR (THWN-2, COPPE
ADJ. MODULE VMP @ ASHRAE 2% AVG. HIGH T	EMP 28.9 V DC	DC POWER RATING PER CIRCUIT (STC)	4550							COND
		TOTAL MODULE NUMBER			14 MO	DULES	10-	·		COND
MICROINVERTER SPECIFICATIONS Enpha	ase IQ7 Microinverters	STC RATING OF ARRAY 4550W DC					AMB. TEMP. AM			
POWER POINT TRACKING (MPPT) MIN/MAX	22 - 48 V DC	AC CURRENT @ MAX POWER POINT (IMP	14.0							
MAXIMUM INPUT VOLTAGE	48 V DC	MAX. CURRENT (IMP X 1.25)	17.5						JUNCTION BOX TO	MAX. SHORT CIRCUIT
MAXIMUM DC SHORT CIRCUIT CURRENT	15 A DC	OCPD CURRENT RATING PER CIRCUIT	20	+	-				COMBINER BOX (3)	MAX. CURF
MAXIMUM USABLE DC INPUT POWER	350 W	MAX. COMB. ARRAY AC CURRENT (IMP)			14	.0			COND	JCTOR (THWN-2, COPPE
MAXIMUM OUTPUT CURRENT	1 A AC	MAX. ARRAY AC POWER			3360\	N AC				COND
AC OVERCURRENT PROTECTION	20 A		1					1.77		COND
MAXIMUM OUTPUT POWER	240 W	AC VOLTAGE RISE CALCULATIONS	DIST (FT)	COND.	<pre>/RISE(V)</pre>	VEND(V	%VRISE	IQ7-7		AMB. TEMP. AM
CEC WEIGHTED EFFICIENCY	97 %	VRISE SEC. 1 (MICRO TO JBOX)	25.2	12 Cu.	0.71	240.71	0.30%	í (,
	10	VRISE SEC. 2 (JBOX TO COMBINER BOX)	35	10 Cu.	1.24	241.24	0.52%	0	COMBINER BOX TO	INVERT
AC PHOTOVOLATIC MODULE MARKING (NEC 65	90.52)	VRISE SEC. 3 (COMBINER BOX TO POI)	5	10 Cu.	0.18	240.18	0.07%		MAIN PV OCPD (15)	MAX. CURRENT (RAT
NOMINAL OPERATING AC VOLTAGE	240 V AC	TOTAL VRISE			2.14	242.14	0.89%	NS	COND	JCTOR (THWN-2, COPPE
NOMINAL OPERATING AC FREQUENCY	47 - 68 HZ AC							12		COND
MAXIMUM AC POWER	240 VA AC	PHOTOVOLTAIC AC DISCONNECT OUTPU	TLABEL (N	EC 690.54	4)			1.1		COND
MAXIMUM AC CURRENT	1.0 A AC	AC OUTPUT CURRENT					14.0	AAC		AMB. TEMP. AM
MAXIMUM OCPD RATING FOR AC MODULE	20 A AC	NOMINAL AC VOLTAGE					240	VAC		

GROUNDING NOTES

WIRING & CONDUIT NOTES

 Introduction between the service interference in	 APPLICATIONS. 2. BOLTED CONNECTION REQUIRED IN DC DISCONNECTS ON THE WHITE GROUNDED CONDUCTOR (USE POLARIS BLOCK OR NEUTRAL BAR). 3. ANY CONNECTION ABOVE LIVE PARTS MUST BE WATERTIGHT. REDUCING WASHERS DISALLOWED ABOVE LIVE PARTS MUST BUS RECOMMENDED 4. UV RESISTANT CABLE TIES (NOT ZIP TIES) USED FOR PERMANENT WIRE MANAGEMENT OFF THE ROOF SURFACE TO BE USED FOR WIRE MANAGEMENT ADD AS FLASHED ROOF PENETARTIONS FOR INTERIOR CONDUIT RUNS. 6. ALL PV CABLES AND HOMERUN WIRES BE TYPE USE2, AND SINGLE-CONDUCTOR CABLE LISTED AND DIDENTIFIED AS PV WIRE, TYPE TC-ER, OR EQUIVALENT; ROUTED TO SOURCE CIRCUIT COMBINER BOXES AS REQUIRED. 7. ALL CONDUCTORS AND OCPD SIZES AND TYPES SPECIFIED ACCORDING TO [NEC 690.8] FOR MULTIPLE CONDUCTORS. 8. ALL PV CC CONDUCTORS IN CONDUIT EXPOSED TO SUNLIGHT SHALL BE INSTALLED AT LEAST 7/8' ABOVE THE ROOF SURFACE TO POTOC SURFACE TO POTOCTOR. 8. ALL PV DC CONDUCTORS IN CONDUIT EXPOSED TO SUNLIGHT SHALL BE INSTALLED AT LEAST 7/8' ABOVE THE ROOF SURFACE TO POTOCTOR SHALL BE USE2, 90°C RATED, WET AND UV RESISTANT, AND UL LISTED RATED FOR ROW. UV RATED SPIRAL WRAP SHALL BE USED TO PROTECT WIRE FROM SHARP EDGES. 10. PHASE AND NEUTRAL CONDUCTORS SHALL BE USE 2, 90°C RATED, WET AND UV RESISTANT, AND UL LISTED FARED FOR GOV. UV RATED SPIRAL WRAP SHALL BE USED TO PROTECT WIRE FROM SHARP EDGES. 11. AWIRE DELTA CONDUCTORS SHALL BE DUAL RATED THHN/THWN-2 INSULATED, 90°C RATED, WET AND UV RESISTANT, ANTED SPIRAL WRAP SHALL BE USED OR CORDUCT ON SHARP EDGES. 12. PHASE AND NEUTRAL CONDUCTORS SHALL BE DUAL RATED THHN/THWN-2 INSULATED, 90°C RATED, WET AND UV RESISTANT, RATED SPIRAL WARP SHALL BE USED CIRCUIT SOLADAS FOLLOWS: DC POSITIVE GROUNDED SYSTEMS DC CONDUCTORS SHALL BE COLOR CODED AS FOLLOWS: DC POSITIVE GROUNDED SYSTEMS DC CONDUCTORS SHALL BE COLOR CODED AS FOLLOWS: DC POSITIVE - REPLOY (MARKED GREY), DC NEGATIVE - GREY (DC MARKED GREY)) 14. NEGATIVE GROUNDED SYSTEMS DC CONDUCTORS COLOR CODED:<	
--	---	--

			15.4	
JIT CURRRENT (ISC) =	14.0	A AC		
URRENT (ISC X1.25) =	17.5	A AC		
ER, COPPER (90°C)) =	12	AWG		BLUE
NDUCTOR RATING =	30	A		DLUL
AMP. CORRECTION =	0.96			1403 N. P.
ADJUSTED AMP. =	28.8	>	17.5	Orem,
JIT CURRRENT (ISC) =	14.0	A AC		800.3
URRENT (ISC X1.25) =	17.5	A AC		WWW.BLUERA
PPER (75°C TERM.)) =	10	AWG		CONFIDENTIAL- HEREIN CONTAIN
ONDUCTOR RATING =	35	A		USED FOR THE B
NDUIT FILL DERATE =	1			SHALL IT BE DISCL
AMP. CORRECTION =	0.71			IN PART TO O
ADJUSTED AMP. =	24.85	>	17.5	IN CONNECTION V
JIT CURRRENT (ISC) =	14.0	A AC		WITHOUT THE WE
URRENT (ISC X1.25) =	17.5	A AC		OF BLUE RAV
PPER (75°C TERM.)) =	10	AWG		
NDUCTOR RATING =	35	A		/NAE
NDUIT FILL DERATE =	1			CER
AMP. CORRECTION =	0.96			
ADJUSTED AMP. =	33.6	>	17.5	PV INST.
ERTER RATED AMPS =	14.0	A AC	i i	Scott
RATED AMPS X1.25) =	17.5	A AC		#PV-011
PPER (75°C TERM.)) =	10	AWG		CONTE
NDUCTOR RATING =	35	A		BRS FI
NDUIT FILL DERATE =	1			385-4
AMP. CORRECTION =	0.96			
ADJUSTED AMP. =	33.6	>	17.5	
				1
				ΙĔ
				Σ
				L R
				ШЩ
				ن من ا
				NE NE
				aro 30 l
				DRAWING BY:
				Adam
				PLOT DATE:
				July 7
				PROJECT NUMBER
				330
				SHEET NAME:
				ELEC

F RAVEN SOLAR Research Way , UT 84097 .377.4480 AVENSOLAR.COM L- THE INFORMATION AINED SHALL NOT BE BENEFIT OF ANYONE RAVEN SOLAR NOR CLOSED IN WHOLE OR OTHERS OUTSIDE (GANIZATION, EXCEPT N WITH THE SALE AND SPECTIVE EQUIPMENT, WRITTEN PERMISSION AVEN SOLAR LLC. BCEP TIFIED **TALLATION** SSIONAL tt Gurney 1719-015866 RACTOR: ELD OPS 98-6700 Fort Collins, Colorado 80524 SIZE: DC SYSTEM S 4.55 kW DC n Cook 7, 2021 0326 CALCS PAGE NUMBER: REVISION: PV6 В

STANDARD LABELS

ADDITIONAL LABELS



LABELING NOTES

1) LABELS CALLED OUT ACCORDING TO ALL COMMON CONFIGURATIONS. ELECTRICIAN TO DETERMINE EXACT REQUIREMENTS IN THE FIELD PER CURRENT NEC AND LOCAL CODES AND MAKE APPROPRIATE ADJUSTMENTS. 2) LABELING REQUIREMENTS BASED ON THE 2017 & 2020 NEC CODE, OSHA STANDARD 19010.145, ANSIZ535. 3) MATERIAL BASED ON THE REQUIREMENTS OF THE AHJ

4) LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED AND SHALL NOT BE HANDWRITTEN [NEC 110.21]

*ELECTRICAL DIAGRAM SHOWN ABOVE IS FOR LABELING PURPOSES ONLY. NOT AN ACTUAL REPRESENTATION OF EQUIPMENT AND CONNECTIONS TO BE INSTALLED. LABEL LOCATIONS PRESENTED MAY VARY DEPENDING ON TYPE OF INTERCONNECTION METHOD AND LOCATION PRESENTED ON 3 LINE DIAGRAM. 3 LINE DIAGRAM ON PV5 TO REFLECT ACTUAL REPRESENTATION OF PROPOSED SCOPE OF WORK



̈́Β́

Data Sheet **Enphase Microinverters** Region: AMERICAS

Enphase IQ 7 and IQ 7+ **Microinverters**



The high-powered smart grid-ready Enphase IQ 7 Micro[™] and Enphase IQ 7+ Micro[™] dramatically simplify the installation process while achieving the highest system efficiency.

Part of the Enphase IQ System, the IQ 7 and IQ 7+ Microinverters integrate with the Enphase IQ Envoy[™], Enphase IQ Battery[™], and the Enphase Enlighten[™] monitoring and analysis software.

IQ Series Microinverters extend the reliability standards set forth by previous generations and undergo over a million hours of power-on testing, enabling Enphase to provide an industry-leading warranty of up to 25 years.

Easy to Install

- · Lightweight and simple
- Faster installation with improved, lighter two-wire cabling
- Built-in rapid shutdown compliant (NEC 2014 & 2017)

Productive and Reliable

- · Optimized for high powered 60-cell/120 half-cell and 72cell/144 half-cell* modules
- More than a million hours of testing
- · Class II double-insulated enclosure
- UL listed

Smart Grid Ready

- Complies with advanced grid support, voltage and frequency ride-through requirements
- · Remotely updates to respond to changing grid requirements
- Configurable for varying grid profiles
- Meets CA Rule 21 (UL 1741-SA)

* The IQ 7+ Micro is required to support 72-cell/144 half-cell modules.

Enphase IO 7 and IO 7+ Microinverters

	1		
INPUT DATA (DC)	IQ7-60-2-US		IQ7PLUS-72
Commonly used module pairings ¹	235 W - 350 W +		235 W - 440 V
Module compatibility	60-cell/120 half	-cell PV modules	60-cell/120 h
	only		cell/144 half-
Maximum input DC voltage	48 V		60 V
Peak power tracking voltage	27 V - 37 V		27 V - 45 V
Operating range	16 V - 48 V		16 V - 60 V
Min/Max start voltage	22 V / 48 V		22 V / 60 V
Max DC short circuit current (module lsc)	15 A		15 A
Overvoltage class DC port	Ш		II
DC port backfeed current	0 A		0 A
PV array configuration	1 x 1 ungrounde AC side protecti	ed array; No addi ion requires max	onal DC side prote 20A per branch cir
OUTPUT DATA (AC)	IQ 7 Microinve	erter	IQ 7+ Micro
Peak output power	250 VA		295 VA
Maximum continuous output power	240 VA		290 VA
Nominal (L-L) voltage/range ²	240 V / 211-264 V	208 V / 183-229 V	240 V / 211-264 V
Maximum continuous output current	1.0 A (240 V)	1.15 A (208 V)	1.21 A (240 V
Nominal frequency	60 Hz		60 Hz
Extended frequency range	47 - 68 Hz		47 - 68 Hz
AC short circuit fault current over 3 cycles	5.8 Arms		5.8 Arms
Maximum units per 20 A (L-L) branch circuit ³	16 (240 VAC)	13 (208 VAC)	13 (240 VAC)
Overvoltage class AC port		× /	
AC port backfeed current	18 mA		18 mA
Power factor setting	1.0		1.0
Power factor (adjustable)	0.85 leading ().85 lagging	0.85 leading.
EFFICIENCY	@240 V	@208 V	@240 V
Peak efficiency	97.6 %	97.6 %	97.5 %
CEC weighted efficiency	97.0 %	97.0 %	97.0 %
MECHANICAL DATA			
Ambient temperature range	-40°C to +65°C		
Relative humidity range	4% to 100% (cor	ndensing)	
Connector type	MC4 (or Amphe	nol H4 UTX with	additional Q-DCC-
Dimensions (HxWxD)	212 mm x 175 m	nm x 30.2 mm (w	ithout bracket)
Weight	1.08 kg (2.38 lbs	s)	
Cooling	Natural convect	ion - No fans	
Approved for wet locations	Yes		
Pollution degree	PD3		
Enclosure	Class II double-	insulated corros	ion resistant polyn
Environmental category / UV exposure rating	NEMA Type 6 / (outdoor	
FEATURES			
Communication	Power Line Com	munication (PL	2)
Monitoring	Enlighten Mana	ger and MyEnligh	1/ Iten monitoring op
Disconnecting means	The AC and DC disconnect regu	connectors have uired by NEC 690	been evaluated an
Compliance	CA Rule 21 (UL UL 62109-1, UL1 CAN/CSA-C22.2 This product is 2017, and NEC 2 for AC and DC c	1741-SA) 741/IEEE1547, F(2 NO. 107.1-01 UL Listed as PV F 2020 section 690 onductors, when	CC Part 15 Class B, Rapid Shut Down E .12 and C22.1-2015 i installed accordin

To learn more about Enphase offerings, visit enphase.com

1. No enforced DC/AC ratio. See the compatibility calculator at https://enphase.com/en-us/support/module-compatibility. Nominal voltage range can be extended beyond nominal if required by the utility.
 Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.



To learn more about Enphase offerings, visit enphase.com

© 2020 Enphase Energy. All rights reserved. Enphase, the Enphase logo, Enphase IQ 7, Enphase IQ 7+, Enphase IQ Battery, Enphase Enlighten, Enphase IQ Envoy, and other trademarks or service names are the trademarks of Enphase Energy, Inc. Data subject to change. 2020-08-12

2	-	U	S	

N + alf-cell and 72cell PV modules

ection required; rcuit oinverter

208 V / 183-229 V) 1.39 A (208 V)

11 (208 VAC)

. 0.85 lagging

@208 V 97.3 % 97.0 %

5 adapter

neric enclosure

tions.

Envov

nd approved by UL for use as the load-break

ICES-0003 Class B,

quipment and conforms with NEC 2014, NEC Rule 64-218 Rapid Shutdown of PV Systems, ng manufacturer's instructions.





1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



CONTRACTOR: **BRS FIELD OPS** 385.498.6700

HEET NAME SPEC SHEET

AGE NUMBER

SS

REVISION

0

Enphase **IQ Combiner 3**

(X-IQ-AM1-240-3)





The **Enphase IQ Combiner 3**[™] with Enphase IQ Envoy[™] consolidates interconnection equipment into a single enclosure and streamlines PV and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.

Smart

- Includes IQ Envoy for communication and control
- Flexible networking supports Wi-Fi, Ethernet, or cellular
- Optional AC receptacle available for PLC bridge
- Provides production metering and optional consumption monitoring

Simple

- · Reduced size from previous combiner
- Centered mounting brackets support single stud mounting
- Supports back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- 80 A total PV or storage branch circuits

Reliable

- Durable NRTL-certified NEMA type 3R enclosure
- Five-year limited warranty
- UL listed

Enphase IQ Combiner 3

MODEL NUMBER	
IQ Combiner 3 X-IQ-AM1-240-3	IQ Combiner 3 with Enphase IQ Envoy™ printed production metering (ANSI C12.20 +/- 0.5%) and
ACCESSORIES and REPLACEMENT PARTS (no	ot included, order separately)
Enphase Mobile Connect [™] CELLMODEM-03 (4G/12-year data plan) CELLMODEM-01 (3G/5-year data plan) CELLMODEM-M1 (4G based LTE-M/5-year data plan) Consumption Monitoring* CT CT-200-SPLIT * Consumption monitoring is required for Enphase Storage System	Plug and play industrial grade cellular modem v microinverters. (Available in the US, Canada, Me where there is adequate cellular service in the in Split core current transformers enable whole ho s
Wireless USB adapter COMMS-KIT-01	Installed at the IQ Envoy. For communications wi Enpower [™] smart switch. Includes USB cable for or and allows redundant wireless communication w
BRK-10A-2-240 BRK-15A-2-240 BRK-20A-2P-240	Circuit breaker, 2 pole, 10A, Eaton BR210 Circuit breaker, 2 pole, 10A, Eaton BR210 Circuit breaker, 2 pole, 15A, Eaton BR215 Circuit breaker, 2 pole, 20A, Eaton BR220
EPLC-01	Power line carrier (communication bridge pair),
XA-PLUG-120-3	Accessory receptacle for Power Line Carrier in
XA-ENV-PCBA-3	Replacement IQ Envoy printed circuit board (PC
ELECTRICAL SPECIFICATIONS	
Rating	Continuous duty
System voltage	120/240 VAC, 60 Hz
Eaton BR series busbar rating	125 A
Max. continuous current rating (output to grid)	65 A
Max. fuse/circuit rating (output)	90 A
Branch circuits (solar and/or storage)	Up to four 2-pole Eaton BR series Distributed Ge
Max. continuous current rating (input from PV)	64 A
Max. total branch circuit breaker rating (input)	80A of distributed generation / 90A with IQ Env
Production Metering CT	200 A solid core pre-installed and wired to IQ Er
MECHANICAL DATA	
Dimensions (WxHxD)	49.5 x 37.5 x 16.8 cm (19.5" x 14.75" x 6.63"). He
Weight	7.5 kg (16.5 lbs)
Ambient temperature range	-40° C to +46° C (-40° to 115° F)
Cooling	Natural convection, plus heat shield
Enclosure environmental rating	Outdoor, NRTL-certified, NEMA type 3R, polycar
Wire sizes	 20 A to 50 A breaker inputs: 14 to 4 AWG cop 60 A breaker branch input: 4 to 1/0 AWG copp Main lug combined output: 10 to 2/0 AWG co Neutral and ground: 14 to 1/0 copper conduct Always follow local code requirements for conduct
Altitude	To 2000 meters (6,560 feet)
INTERNET CONNECTION OPTIONS	
Integrated Wi-Fi	802.11b/g/n
Ethernet	Optional, 802.3, Cat5E (or Cat 6) UTP Ethernet c
Cellular	Optional, CELLMODEM-01 (3G) or CELLMODEM (not included)
COMPLIANCE	
Compliance, Combiner	UL 1741, CAN/CSA C22.2 No. 107.1, 47 CFR, Pa
Compliance, IQ Envoy	UL 60601-1/CANCSA 22.2 No. 61010-1

To learn more about Enphase offerings, visit enphase.com



© 2018 Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ Combiner 3, and other trademarks or service

To learn more about Enphase offerings, visit enphase.com

circuit board for integrated revenue grade PV d optional* consumption monitoring (+/- 2.5%).	BLUE	RAVEN
vith data plan for systems up to 60	1403 N RESEARCH OREM, 1	H WAY, BUILDING J UT 84097
exico, Puerto Rico, and the US Virgin Islands, nstallation area.) ome consumption metering (+/- 2.5%).	800-37 WWW.BLUERA	77-4480 VENSOLAR.COM
th Enphase Encharge [™] storage and Enphase connection to IQ Envoy or Enphase IQ Combiner [™] /ith Encharge and Enpower. BR240, BR250, and BR260 circuit breakers. quantity - one pair IO Combiner 3 (required for EPLC-01)	CONFIDENTIAL - 1 HEREIN CONTAIN USED FOR TH ANYONE EXCE SOLAR NOR DISCLOSED IN W TO OTHERS OUT ORGANIZATIO CONNECTION WI USE OF THE EQUIPMENT, WRITTEN PERM RAVEN S	THE INFORMATION IED SHALL NOT BE BE BENEFIT OF PT BLUE RAVEN S SHALL IT BE (HOLE OR IN PART "SIDE RECIPIENTS DN, EXCEPT IN TH THE SALE AND "RESPECTIVE WITHOUT THE MISSION OF BLUE OLAR LLC.
CB) for Combiner 3		
, 	PV INSTA PROFES scott # PV-011	CEP IFIED ALLATION SSIONAL Gumey 719-015866
eneration (DG) breakers only (not included)	CONTR BRS FIE 385.49	ACTOR: ELD OPS 98.6700
oy breaker included		
nvoy		
eight is 21.06" (53.5 cm with mounting brackets).		
per conductors per conductors opper conductors otors tors ductor sizing.		
cable (not included) 1-03 (4G) or CELLMODEM-M1 (4G based LTE-M)		
art 15, Class B, ICES 003 ass 0.5 (PV production)		
	SHEET NAME	HEET
	PAGE NUMBER	REVISION
	SS	0

REC TWINPEAK 3 MONO BLACK SERIES





	Standard	RECE	ProTrust
Installed by an REC Certified Solar Professional	No	Yes	Yes
System Size	Any	≤25kW	25-500 kW
Product Warranty (yrs)	20	25	25
Power Warranty (yrs)	25	25	25
Labor Warranty (yrs)	0	25	10
Power in Year 1	97.5%	97.5%	97.5%
Annual Degradation	0.7%	0.7%	0.7%
Power in Year 25 See warranty document	80.7% ts for details	80.7% Some con	80.7% ditions apply.

REC Group is an international pioneering solar energy company dedicated to empowerin Consumers with iternational puncturing solar energy Company decidates to empowering consumers with clean, affordable solar power in order to facilitate globale energy transitions. Committed to quality and innovation, REC offers photovoltaic modules with leading high quality, backed by an exceptional low warranty claims rate of less than 100pm. Founded in Norway in 1996, REC employs 2,000 people and has an annual solar panel capacity of 1.8 GW. Withover 10 GW installed worldwide, REC is empowering more than 16 million people with clean solar energy. REC Group is a Bluestar Elkem company withheadquarters in Norway, operational headquarters in Singapore, and regional bases in North America, Europe, and Asia-Pacific.

N REC

REC TWINPEAK 3 MONO BLACK

PREMIUM SOLAR PANELS WITH SUPERIOR PERFORMANCE

REC TwinPeak 3 Mono Black Series solar panels feature an innovative design with high panel efficiency and power output, enabling customers to get the most out of the space used for the installation.

Combined with industry-leading product quality and the reliability of a strong and established European brand, REC TwinPeak 3 Mono Black panels are ideal for residential and commercial rooftops worldwide.









IN SHADED CONDITIONS









MORE POWER OUTPUT PER M²



intertek Total Quality. Assured

UNIRAC INC. LETTER REPORT

SCOPE OF WORK ADDITION OF MODULES TO THE UNIRAC SFM CDR 102393982LAX-002

REPORT NUMBER 104430210LAX-001a

ISSUE DATE 24-Sept-2020

PAGES

3

DOCUMENT CONTROL NUMBER

GFT-OP-10a (21-June-2019) © 2019 INTERTEK



intertek Total Quality. Assured

LETTER REPORT

September 24, 2020

Klaus Nicolaedis Unirac Inc. 1411 Broadway Blvd NE Albuquerque, NM 87102-1545 USA klaus.nicolaedis@unirac.com

Subject: Addition of modules to the Unirac SFM CDR 102393982LAX-002

Dear Klaus,

This letter report represents the results of our evaluation of the above referenced product(s) to the requirements contained in the following standards:

Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels [UL 2703:2015 Ed.1]

SECTION 1

SUMMARY

This investigation was authorized by quote # Qu-01101732 dated 08-17-2020. The scope of the project was to evaluate and add module frames to the SFM CDR 102393982LAX-002.

SECTION 2

EVALUATION

The following PV modules were evaluated for bonding/grounding purposes and are approved to be installed using the Unirac SFM model:

Manufacturer	Model
	Q.PEAK DUO L-G7, Q.PEAK DUO L-G7.1,
	Q.PEAK DUO L-G7.2, Q.PEAK DUO L-G7.3,
	Q.PEAK DUO L-G8, Q.PEAK DUO L-G8.1,
	Q.PEAK DUO L-G8.2, Q.PEAK DUO L-G8.3
REC	TP3M, TP3M Black
Silfab	SIL-xxx-NT, SIL-xxx-ML, SIL-xxx-NL,
Sillab	SIL-xxx-BL, SIL-xxx-HL

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Version: 6-March-2017

Page 2 of 3

25791 Commercentre Drive Lake Forest, CA 92630

Telephone: 949-448-4100 Facsimile: 949-448-4111 www.intertek.com



Intertek Report No. 104430210LAX-001a SECT Intertek Project No. G104430210 PRO.

> Ph: 505-462-2190 Issua No.

IDECTION 3 PROJECT STATUS Issuance of this le No. G104430210. If there are any q services offered Project Manager.	ek & ACTION etter report provides results uestions regarding the result by Intertek, please do not	of the evaluation ts contained in thi hesitate to contained	Unirac Inc. Intertek Report No: 104430210LAX-001a covered by Intertek Project s report, or any of the other act your dedicated Intertek	1403 N RESEARCH WAY, BUILDING J OREM, UT 84097 800-377-4480 WWW.BLUERAVENSOLAR.COM CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.
Completed by:	Abhinav Prakash	Reviewed by:	Adam Muliawan	NABCEP
Title: Signature:	Project Engineer	Title: Signature	Reviewer Johan Multime	CERTIFIED PV INSTALLATION PROFESSIONAL Scott Gurney # PV-011719-015866
Date	09-24-2020	Date:	09-25-2020	CONTRACTOR:
certification marks.				
Version: 6-March-201	7 Page	3 of 3	GFT-OP-10a	SHEET NAME SPEC SHEET PAGE NUMBER SS 0

Date	09-24-2020

GFT-OP-10a

Product data sheet Characteristics

DU221RB

Safety switch, general duty, non fusible, 30A, 2 poles, 3 hp, 240 VAC, NEMA 3R, bolt-on provision

Product availability : Stock - Normally stocked in distribution facility

SQUARE



Price* : 177.00 USD



Main

TTTGTT -		
Product	Single Throw Safety Switch	
Current Rating	30 A	
Certifications	UL listed file E2875	
Enclosure Rating	NEMA 3R	
Disconnect Type	Non-fusible disconnect switch	
Factory Installed Neutral	None	
Mounting Type	Surface	
Number of Poles	2	
Electrical Connection	Lugs	
Duty Rating	General duty	
Voltage Rating	240 V AC	
Wire Size	AWG 14AWG 6 copper AWG 12AWG 6 aluminium	

Complementary

Short-circuit withstand	200 kA	
Maximum Horse Power Rating	3 hp 240 V AC 60 Hz 1 phase NEC 430.52	
Tightening torque	30 lbf.in (3.39 N.m) 0.000.02 in² (2.0813.3 mm²) AWG 14AWG 6)	
Height	9.63 in (244.60 mm)	
Width	7.75 in (196.85 mm)	
Depth	3.75 in (95.25 mm)	

* Price is "List Price" and may be subject to a trade discount - check with your local distributor or retailer for actual price.

Apr 21, 2021

1 Buchs Part	Selv	neide	
COMPANY OF	~ 0	Contraction of the second	1

Ordering and shipping de	tails
Category	00106 - D & DU SW,NEMA3R, 30-200A
Discount Schedule	DE1A
OTIN	00705001100010

GTIN	00785901490340
Nbr. of units in pkg.	1
Package weight(Lbs)	4.65 lb(US) (2.11 kg)
Returnability	Yes
Country of origin	MX
Packing Units	
Unit Type of Package 1	PCE
Package 1 Height	5.40 in (13.716 cm)
Package 1 width	7.80 in (19.812 cm)
Package 1 Length	9.90 in (25.146 cm)
Unit Type of Package 2	CAR
Number of Units in Package 2	5
Package 2 Weight	24.60 lb(US) (11.158 kg)
Package 2 Height	10.80 in (27.432 cm)
Package 2 width	10.50 in (26.67 cm)
Package 2 Length	23.80 in (60.452 cm)
Unit Type of Package 3	PAL
Number of Units in Package 3	160
Package 3 Weight	814.00 lb(US) (369.224 kg)
Package 3 Height	46.50 in (118.11 cm)
Package 3 width	40.00 in (101.6 cm)
Package 3 Length	48.00 in (121.92 cm)
Offer Sustainability	
Sustainable offer status	Green Premium product
California proposition 65	WARNING: This product can expose you to chemicals inc is known to the State of California to cause cancer and bin more information go to www.P65Warnings.ca.gov

REACh Regulation	REACh Declaration
REACh free of SVHC	Yes
EU RoHS Directive	Compliant EU RoHS Declaration
Toxic heavy metal free	Yes
Mercury free	Yes
RoHS exemption information	Yes
China RoHS Regulation	China RoHS declaration Pro-active China RoHS declaration (out of China RoHS leg
Environmental Disclosure	Product Environmental Profile
PVC free	Yes

Contractual warranty

Warranty

2

18 months

Life Is On Schneider



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

cluding: Lead and lead compounds, which rth defects or other reproductive harm. For

gal scope)

SHEET	NAME:

SPEC SHEETS

REVISION:

0

PAGE NUMBER: SS

Specification Sheet

PV Junction Box for Composition/Asphalt Shingle Roofs

A. System Specifications and Ratings

- o Maximum Voltage: 600 Volts
- o Maximum Current: 60 Amps
- o Allowable Wire: 14 AWG 6 AWG
- Spacing: Please maintain a spacing of at least ½" between uninsulated live parts and fittings for conduit, armored cable, and uninsulated lie parts of opposite polarity. 0
- Enclosure Rating: Type 3R
- Roof Slope Range: 2.5 12:12 Max Side Wall Fitting Size: 1"
- Max Floor Pass-Through Fitting Size: 1" Ambient Operating Conditions: -35°C - +75°C
- 0 Compliance: 0
 - JB-1: UL1741
 - Approved wire connectors: must conform to UL1741
- System Marking: Intertek Symbol and File # 5015705 0
- Periodic Re-inspections: If re-inspections yield loose components, loose fasteners, or any corrosion between components, components that are found to be affected are to be replaced immediately.

Table 1: Typical Wire Size, Torque Loads and Ratings

		2 Conductor	Torque				
	1 Conductor		Туре	NM	Inch Lbs	Voltage	Current
ABB ZS6 terminal block	10-24 awg	16-24 awg	Sol/Str	0.5-0.7	6.2-8.85	600V	30 amp
ABB ZS10 terminal block	6-24 awg	12-20 awg	Sol/Str	1.0-1.6	8.85-14.16	600V	40 amp
ABB ZS16 terminal bock	4-24 awg	10-20 awg	Sol/Str	1.6-2.4	14.6-21.24	600V	60 amp
ABB M6/8 terminal block	8-22 awg		Sol/Str	.08-1	8.85	600V	50 amp
Ideal 452 Red WING-NUT Wire Connector	8-18 awg		Sol/Str			600V	
Ideal 451 Yellow WING-NUT Wire Connector	10-18 awg		Sol/Str			600V	
Ideal, In-Sure Push-In Connector Part #39	10-14 awg		Sol/Str			600V	
International Hudraulics 252/0	10-14 awg		Sol/Str	4	35		
International Hydraulics 252/0	8 awg		Sol/Str	4.5	40		
Brumall 4.5.2	4-6 awg	·	Sol/Str		45	20/	2017
bruman 4-5,5	10-14 awg		Sol/Str		35	200	<i></i>
Blackburn LL414	4-14 awg		Sol/Str				

Table 2: Minimum wire-bending space for conductors through a wall opposite terminals in mm (inches)

Wire size	e, AWG or	Wires per terminal (pole)								
		1		1 2		2	3		4 or More	
kcmil	(mm2)	mm	(inch)	mm	(inch)	mm	(inch)	mm	(inch)	
14-10	(2.1-5.3)	Not specified			-		-		-	
8	(8.4)	38.1	(1-1/2)			9	-		-	
6	(13.3)	50.8	(2)		4 J	1	• ·		-	

www.ezsolarproducts.com





N

3

4





Carlon



* Not CSA Certified

NEC and National Electrical Code are registered trademarks of the National Fire Protection Association, Inc.



United States Tel: 901.252.8000 800.816.7809 Fax: 901.252.1354 Technical Services Tel: 888.862.3289

Thomas@Betts



VIEW SHOWN LESS COVER FOR CLARITY

3.70

[94]

Carlon[•]

[94]

ARE IN METRIC UNITS.	DESCRIPTION:	MOL DED	NON-MET/	
REVISIONS				
SEE ERN 2016195 FOR APPROVAL SIGNATURES	ORIGINAL PROJECT	NO / (ERN NO) SHEET NO:	REV. I
& RELEASE DATE. PROJECT NO: 5AM000006	,	()	2 OF 2	F
THIS DRAWING IS INTENDED FOR	DESCRIPTIVE PURPOSES (Copyright Thom	DNLY, AND THE RIG	GHT IS RESERVED TO I rielory, All Rights	Reserved



SYSTEM BONDING & GROUNDING PAGE



Star Washer is Single Use Only

TERMINAL TORQUE. Install Conductor and torque to the following: 4-6 AWG: 35in-lbs 8 AWG: 25 in-lbs 10-14 AWG: 20 in-lbs

LUG DETAIL & TORQUE INFO Ilsco Lay-In Lug (GBL-4DBT)

- 10-32 mounting hardware
- Torque = 5 ft-lb
- AWG 4-14 Solid or Stranded

SFN SUN FRAME



TERMINAL TOROUE. Install Conductor and torque to the following: 4-14 AWG: 35in-lbs

LUG DETAIL & TORQUE INFO Ilsco Flange Lug(SGB-4)

- 1/4" mounting hardware .
- Torque = 75 in-lb
- AWG 4-14 Solid or Stranded

WEEBLUG Single Use Only



TERMINAL TOROUE, Install Conductor and torque to the following: 6-14 AWG: 7ft-lbs

LUG DETAIL & TORQUE INFO Wiley WEEBLug (6.7)

- 1/4" mounting hardware
- Torque = 10 ft-lb
- AWG 6-14 Solid or Stranded



a ground lug to any module at a location on the module specified by the module manufacturer.









UL CODE COMPLIANCE NOTES Installation guide Page

SYSTEM LEVEL FIRE CLASSIFICATION

The system fire class rating requires installation in the manner specified in the SUNFRAME MICRORAIL (SFM) Installation Guide. SFM has been classified to the system level fire portion of UL 1703. This UL 1703 classification has been incorporated into the UL 2703 product certification. SFM has achieved Class A, B & C system level performance for low slope & steep sloped roofs when used in conjunction with type 1 and type 2 modules. Class A, B & C system level fire

performance is inherent in the SFM design, and no additional mitigation measures are required. The fire classification rating is valid for any roof pitch. There is no required minimum or maximum height limitation above the roof deck to maintain the Class A, B & C fire rating for SFM. SUNFRAME MICRORAIL[™] components shall be mounted over a fire resistant roof covering rated for the application.

Module Type	Roof Slope	System Level Fire Rating	Microrail Direction	Module Orientation	Mitigation Require
Type 1 and Type 2	Steep Slope & Low Slope	Class A, B & C	East-West	Landscape OR Portrait	None Required

UL2703 TEST MODULES

See page "S" for a list of modules that were electrically and mechanically tested or qualified with the SUNFRAME MICRORAIL (SFM) components outlined within this Installation Guide.

- Maximum Area of Module = 22.3 sqft
- UL2703 Design Load Ratings:
 - Downward Pressure 113 PSF / 5400 Pa a)
 - Upward Pressure 50 PSF / 2400 Pa b)
 - Down-Slope Load 30 PSF / 1400 Pa C)
- Tested Loads:
 - Downward Pressure 170 PSF / 8000 Pa a)
 - b) Upward Pressure - 75 PSF / 3500 Pa
 - c) Down-Slope Load - 45 PSF / 2100 Pa
- Maximum Span = 6ft
- Use with a maximum over current protection device OCPD of 30A
- System conforms to UL Std 2703, certified to LTR AE-001-2012
- Rated for a design load of 2400 Pa / 5400 Pa with 24 inch span

LABEL MARKINGS

- System fire class rating: See installation instructions for installation requirements to achieve a specified system fire class rating with Unirac.
- Unirac SUNFRAME MICRORAIL[™] is listed to UL 2703.
- All splices within a system are shipped with marking indicating date and location of manufacture.







SHEET NAME:

SPEC SHEETS

REVISION:

0

AGE NUMBER SS

SFN SUN FRAME MICRORAIL™

TESTED / CERTIFIED MODULE LIS Installation guid

Manufacture	Module Model / Series	Manufacture	Module Model / Series	Manufacture	Module Model / Series
Aleo	P-Series	Hansol	TD-AN3, TD-AN4,		LR4-60(HIB/HIH/HPB/HI
	CHSM6612P, CHSM6612P/HV, CHSM6612M,		UB-AN1, UD-AN1		LR4-72(HIH/HPH)-xxxM
Astronergy	CHSM6612M/HV, CHSM6610M (BL)(BF)/(HF),	Heliene	36M, 60M, 60P, 72M & 72P Series		LR6-60(BP/HBD/HIBD)->
	CHSM72M-HC AXN6M610T, AXN6P610T,	HT Solar	HT60-156(M) (NDV) (-F), HT 72-156(M/P)	LONGI	LR6-60(BK)(PE)(HPB)(HP LR6-60(BK)(PE)(PB)(PH)-
Auxin	AXN6M612T & AXN6P612T	Hyundai	KG, MG, TG, RI, RG, TI, MI, HI & KI Series		LR6-72(BP)(HBD)(HIBD)-
	AXIblackpremium 60 (35mm),	ITEK	iT, iT-HE & iT-SE Series		LR6-72(HV)(BK)(PE)(PH)(
	AXIpower 60 (35mm),	Japan Solar	JPS-60 & JPS-72 Series		(55mm) I R6-77(BK)(HV)(PE)(PB)(
Axitec	AXIpower 72 (40mm),		JAP6 60-xxx, JAM6-60-xxx/SI, JAM6(K)-60/	Mission Solar Energy	MSE Series
	AXIpremium 72 (40mm)		xxx, JAP6(k)-72-xxx/4BB, JAP72SYY-xxx/ZZ,	Mitsubishi	MJE & MLE Series
	DNA-120-ME26		JAP6(k)-60-xxx/4BB, JAP60SYY-xxx/ZZ,	Neo Solar Power Co.	D6M & D6P Series
Aptos	DNA-144-MF26	JA Solar	olar JAM6(k)-72-xxx/ZZ, JAM72SYY-xxx/ZZ, JAM6(k)-60-xxx/ZZ, JAM60SYY-xxx/ZZ. i. YY: 01, 02, 03, 09, 10 ii. ZZ: SC, PR, BP, HiT, JB, MW	Panasonic	VBHNxxxSA15 & SA16,
Boviet	BVM6610, BVM6612	liate			VBHNxxxSA17 & SA18. VBHNxxxSA17(E/G) & S/
BYD	P6K & MHK-36 Series		IVM & IVMC Corior		VBHNxxxKA01 & KA03
	CS6V-M, CS6P-P, CS6K-M, CS5A-M,	Kuocora	VII Series	-	VBHNxxxZA01, VBHNxxx
	CS6K-MS, CS6U-P, CS6U-M, CS6X-P, CS6K-MS,	LGxxxN2T-A4	I GyvyN2T_A4		VBHNXXXZAU5, VBHNXX
Canadian Solar	CS6K-M, CS6K-P, CS6P-P, CS6P-M, CS3U-P,		LGxxx(A1C/E1C/E1K/N1C/N1K/N2T/N2W/ Q1C/Q1K/S1C/S2W)-A5 LGxxx(A1C/M1C/M1K/N1C/N1K/Q1C/Q1K/ QAC/QAK)-A6 LG Electronics LGxxx(N2T/N2W)-E6 LGxxx(N1C/N1K/N2W/S1C/S2W)-G4 LGxxxN2T-J5 LGxxx(N1K/N2T/N2W)-L5 LGxxx(N1C/Q1C/Q1K)-N5 LGxxx(N1C/N1K/N2W/Q1C/Q1K)-V5	Peimar	SGxxxM (FB/BF)
Callaulari Sotai	CS3U-MS, CS3K-P, CS3K-MS, CS1K-MS, CS3K,			Phono Solar	PS-60, PS-72
	CS3U, CS3U-MB-AG, CS3K-MB-AG, CS6K, CS6U, CS3L, CS3W, CS1H-MS, CS1U-MS			Q.Cells	Plus, Pro, Peak, G3, G4, G Pro, Peak L-G2, L-G4, L-G
Centrosolar America	C-Series & E-Series	LG Electronics			Alpha (72) (Black)
CertainTeed	CT2xxMxx-01, CT2xxPxx-01, CTxxxMxx-02, CTxxxM-03,	LO LICCOUNTS			N-Peak (Black) PEAK Energy Series PEAK Energy BLK2 Serie
Debui	DH-60M			REC	PEAK Energy 72 Series
Eco Solarov	Orion 1000 & Apollo 1000				TwinPeak Series
EreeVolt	Mana DEPC	h	5 În		TwinPeak 2 Series
co	CCL D6 & CCL M6 Series				TwinPeak 2 BLK2 Series
OLL	GLEFFO & GLEFFIO Series				TwinPeak 25(M)72(XV)

Please see the SFM UL2703Construction Data Report at Unirac.com to ensure the exact solar module selected is approved for use with S SFM Infinity is not compatible with module frame height of less than 30mm and more than 40mm. See page J for further information.

		-
Tis	BLUE	RAVEN
	1403 N. Re Orem, U	search Way IT 84097
DE : PAGE	800.37 WWW.BLUERAV	7.4480 /ENSOLAR.COM
PH)-xxxM	CONFIDENTIAL-T HEREIN CONTAIN USED FOR THE BE EXCEPT BLUE RA SHALL IT BE DISCLO IN PART TO OT RECIPIENTS ORGA IN CONNECTION W USE OF THE RESPE WITHOUT THE WR OF BLUE RAVE	HE INFORMATION ED SHALL NOT BE INEFIT OF ANYONE VEN SOLAR NOR OSED IN WHOLE OR HERS OUTSIDE INIZATION, EXCEPT (ITH THE SALE AND CTIVE EQUIPMENT, ITTEN PERMISSION EN SOLAR LLC.
xxxM (30mm)		
-xxxM (40mm) -xxxM (30mm)		CEP \ IFIED
(PB)(HPH)-xxxM (PH)-xxxM (40mm)	PV INSTA PROFES Scott 0 #PV-0117	ALLATION SSIONAL Gurney 19-015866
	CONTR BRS FIE 385-49	ACTOR: ELD OPS 18-6700
A18E, & KA04, xZA02, xZA04		
5, G6(+), G7, G8(+) 5, L-G6, L-G7		
25		
5		
m)		
	SHEET NAME:	
SFM.	SPEC S	SHEETS
1.	REVISION:	PAGE NUMBER:
	0	SS

intertek

Total Quality. Assured.

AUTHORIZATION TO MARK

ED 16.3.15 (15-Oct-20) Mandatory

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Unirac, Inc		Manufacturer:
Address:	1411 Broadway Blvd Albuquerque, NM 87	NE 102	Address:
Country:	USA		Country:
Contact:	Klaus Nicolaedis Todd Ganshaw		Contact:
Phone:	505-462-2190 505-843-1418		Phone:
FAX:	NA		FAX:
Email:	klaus.nicolaedis@uni toddg@unirac.com	irac.com	Email:
Party Autho Report Issu	rized To Apply Mark: ing Office:	Same as Manufacture Lake Forest, CA	Arrain a Court
Control Nur	mber: <u>5003705</u>	Authorized by:	for L Matthew Snyder Certification Manager
			Dus
			tek

This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Interfek's Client and is provided pursuant to the Certification agreement between Interfek and its Client. Interfek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client Is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must finit be approved in writing by Interlek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

> Intertek Testing Services NA Inc. 545 East Algonquin Road, Arlington Heights, IL 60005 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat- Plate Photovoltaic Modules and Panels [UL 2703: 2015 Ed.1]		
	Photovoltaic Module Racking Systems [CSA LTR AE-001:2012]		
Product:	Photovoltaic Mounting System	n, Sun Frame Microrail Installation G	Guide, PUB2021JAN13
Brand Name:	Unirac		
Models:	Unirac SFM		
ATM for Repor	t 102393982LAX-002	Page 1 of 3	ATM Issued: 13-May-2021

intertek

Total Quality. Assured.

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Unirac, Inc		Manufacturer:
Address:	1411 Broadway Blvd Albuquerque, NM 87	NE 102	Address:
Country:	USA		Country:
Contact:	Klaus Nicolaedis Todd Ganshaw		Contact:
Phone:	505-462-2190 505-843-1418		Phone:
FAX:	NA		FAX:
Email:	klaus.nicolaedis@uni toddg@unirac.com	irac.com	Email:
Party Autho Report Issui	rized To Apply Mark: ng Office:	Same as Manufacture Lake Forest, CA	lot
Control Nun	nber: <u>5014989</u>	Authorized by:	for L. Matth



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertex's Client and is provided pursuant to the Certification agreement between Intertex and its Client, Intertex's responsibility and liability are limited to the terms and conditions of the agreement. Intertak assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc. 545 East Algonquin Road, Arlington Heights, IL 60005 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Mounting Systems, Mounting Plate Photovoltaic Modules a	Devices, Clamping/Retention Device nd Panels [UL 2703: 2015 Ed.1]
	Photovoltaic Module Racking	Systems [CSA LTR AE-001:2012]
Product: Photovoltaic Mounting System, Sun Frame Microrail Instal		n, Sun Frame Microrail Installation G
Brand Name:	Unirac	
Models:	Unirac SFM	
ATM for Report	102393982LAX-002	Page 2 of 3



ew Snyder, Certification Manager

es, and Ground Lugs for Use with Flat-

uide, PUB2021JAN13

ATM Issued: 13-May-2021 ED 16.3.15 (15-Oct-20) Mandatory



intertek

Total Quality. Assured.

Listing Constructional Data Report (CDR)

Report Number	102393982LAX-002	Original 11-Apr-2016	Revised: 18-Jan-2021
Standard(s)	Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for with Flat-Plate Photovoltaic Modules and Panels [UL 2703: 2015 Ed.1] Photovoltaic Module Racking Systems [CSA LTR AE-001:2012]		Devices, and Ground Lugs for Use 2015 Ed.1] 2012]
Applicant	Unirac, Inc	Manufacturer 2	
Address	1411 Broadway Blvd NE Albuquerque, NM 8710	Address	
Country	USA	Country	
Contact	Klaus Nicolaedis Todd Ganshaw	Contact	
Phone	505-462-2190 505-843-1418	Phone	
FAX	NA	FAX	
Email	klaus.nicolaedis@unira toddg@unirac.com	c.com Email	
Manufacturer 3		Manufacturer 4	
Address		Address	
Country		Country	
Contact		Contact	
Phone		Phone	
FAX	17	FAX	
Email		Email	

Report No. 102393982LAX-002 Unirac, Inc Page 2 of 122

2.0 Product D	escription
Product	Photovoltaic Mounting System, Sun Frame Microrail Installation
Brand name	Unirac
	The product covered by this report is the Sun Frame Micro Ra Rack Mounting System. This system is designed to provide by photovoltaic modules. The mounting system employs anodize that are roof mounted using the slider, outlined in section 4 of within this product, whereas the 3" Micro Rail, Floating Splice, electrically bond the modules together forming the path to grow The Micro Rails are installed onto the module frame by using with black oxide with a stainless type 300 bonding pin, torque modules to the bracket. The beading pin of the Micro Pail who
Description	the anodized coating of the photovoltaic module frame (at bot creating a bonded connection from module to module.
	The grounding of the entire system is intended to be in accord National Electrical Code, including NEC 250: Grounding and I Photovoltaic Systems or the Canadian Electrical Code, CSA (revision in effect in the jurisdiction in which the project resides be adhered in addition to the national electrical codes. The Gi photovoltaic module, torqued in accordance with the installation document.
	Other optional grounding includes the use of the Enphase UL which requires a minimum of 2 micro-inverters mounted to the engage cable.

Page 1 of 122

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has even been under an Intertek certification program. Issued: 11-Apr-2016 Revised: 18-Jan-2021

on Guide, PUB2021JAN13

tail roof mounted Photovoltaic bonding and grounding to ed or mill finish aluminum brackets of this report. There are no rails e, and 9" Attached Splice ound.

g a stainless steel bolt anodized ed to 20 ft-lbs, retaining the nen bolted and torqued, penetrate bttom flange) to contact the metal,

rdance with the latest edition of the Bonding, and NEC 690: Solar C22.1 Part 1 in accordance to the s. Any local electrical codes must Grounding Lug is secured to the ion manual provided in this

2703 certified grounding system, the same rail, and using the same



ED 16.3.15 (15-Oct-20) Mandat	òty
-------------------------------	-----

Report No. 102393982LAX-002 Unirac, Inc Page 3 of 122

Issued: 11-Apr-2016 Revised: 18-Jan-2021

2.0 Product Description Models Unirac SFM Model Similarity NA Fuse Rating: 30A Module Orientation: Portrait or Landscape Maximum Module Size: 17.98 ft² UL2703 Design Load Rating: 33 PSF Downward, 33 PSF Upward, 10 PSF Down-Slope Tested Loads - 50 psf/2400Pa Downward, 50psf/2400Pa Uplift, 15psf/720Pa Down Slope Trina TSM-255PD05.08 and Sunpower SPR-E20-327 used for Mechanical Loading Increased size ML test: Maximum Module Size: 22.3 ft² UL2703 Design Load Rating: 113 PSF Downward, 50 PSF Upward, 30 PSF Down-Slope LG355S2W-A5 used for Mechanical Loading test. Mounting configuration: Four mountings on each long side of panel with the longest span of UL2703 Design Load Rating: 46.9 PSF Downward, 40 PSF Upward, 10 PSF Down-Slope LG395N2W-A5, LG360S2W-A5 and LG355S2W-A5 used for used for Mechanical Loading Ratings test. Mounting configuration: Six mountings for two modules used with the maximum span of 74.5" IEC 61646 Test Loads - 112.78 psf/5400Pa Downward, 50psf/2400Pa Uplift Fire Class Resistance Rating: Class A for Steep Slope Applications when using Type 1 Modules. Can be installed at any interstitial gap. Installations must include Trim Rail. Class A for Steep Slope Applications when using Type 2 Modules. Can be installed at any interstitial gap. Installations must include Trim Rail Class A Fire Rated for Low Slope applications with Type 1 or 2 listed photovoltaic modules. This system was evaluated with a 5" gap between the bottom of the module and the roof's surface See section 7.0 illustractions # 1, 1a, 1aa, and 1ab for a complete list of PV modules evaluated with these racking systems NA Other Ratings

Report No. 102393982LAX-002 Unirac, Inc Page 39 of 122

7.0 Illustrations

Illustration 1- Other ratings

Manufacture	Module Model / Series
Aleo	P-Series
Astronergy	CH5M6612P, CH5M6612P/HV, CH5M6612M CH5M6612M/HV, CH5M6610M (BL)(BF)/(H CH5M72M-HC
Auxin	AXN6M610T, AXN6P610T, AXN6M612T & AXN6P612T
Axitec	AXI Power, AXI Premium, AXI Black Premiu
Boviet	BVM6610, BVM6612
BYD	P6K & MHK-36 Series
Canadian Solar	CS6V-M, CS6P-P, CS6K-M, CS5A-M, CS6K-MS, CS6U-P, CS6U-M, CS6X-P, CS6K-M CS6K-M, CS6K-P, CS6P-P, CS6P-M, CS3U-P, CS3U-MS, CS3K-P, CS3K-MS, CS1K-MS, CS3 CS3U, CS3U-MB-AG, CS3K-MB-AG, CS6K, CS6U, CS3L, CS3W, CS1H-MS, CS1U-MS
Centrosolar America	C-Series & E-Series
CertainTeed	CT2xxMxx-01, CT2xxPxx-01, CTxxxMxx-02, CTxxxM-03, CTxxxMxx-04, CTxxxHC11-04
Dehui	DH-60M
Eco Solargy	Orion 1000 & Apollo 1000
FreeVolt	Mono PERC
GCL	GCL-P6 & GCL-M6 Series
Hansol	TD-AN3, TD-AN4, UB-AN1, UD-AN1
Heliene	36M, 60M, 60P, 72M & 72P Series
HT Solar	HT60-156(M) (NDV) (-F), HT 72-156(M/P)
Hyundai	KG, MG, TG, RI, RG, TI, MI, HI & KI Series
ITEK	iT, IT-HE & IT-SE Series
Japan Solar	JPS-60 & JPS-72 Series

ED 16.3.15 (15-Oct-20) Mandatory



Report No. 102393982LAX-002 Unirac, Inc Issued: 11-Apr-2016 Revised: 18-Jan-2021

7.0 Illustrations

T

Illustration 1a - Other Ratings Continue

Manufacture	Module Model / Series
JA Solar	JAP6 60-xxx, JAM6-60-xxx/SI, JAM6(K)-60/ xxx, JAP6(k)-72-xxx/48B, JAP72SYY-xxx/ZZ, JAP6(k)-60-xxx/48B, JAP60SYY-xxx/ZZ, JAM6(k)-72-xxx/ZZ, JAM72SYY-xxx/ZZ, JAM6(k)-60-xxx/ZZ, JAM60SYY-xxx/ZZ. i. YY: 01, 02, 03, 09, 10 ii. ZZ: SC, PR, BP, HiT, IB, MW
linko	JKM & JKMS Series
Kyocera	KU Series
LG Electronics	LG xxx S1C-A5, LG xxx N1C-A5, LGxxxQ1C(Q1K)-A5, LGxxxN1C(N1K)-A5, LGxxxS1CA5, LGxxxA1C-A5, LGxxxN2T-A4, LGxxxN2T-A5, LGxxxN2W-A5 LGxxxS2W-A5, LGxxxE1C-A5, LGxxxS2W-G4 LGxxxN1C(N1K)-G4, LGxxxN2W-G4, LGxxxS1C-G4, LGxxxE1K-A5, LGxxxN2T-J5, LGxxxN1K(N1C)-V5, LGxxxQ1C(N2W)-V5,
LONGI	LR6-60 & LR6-72 Series, LR4-60 & LR4-72 Series
Mission Solar Energy	MSE Series
Mitsubishi	MJE & MLE Series
Neo Solar Power Co.	D6M & D6P Series
Panasonic	VBHNXXXSA15 & SA16, VBHNXXXSA17 & SA18, VBHNXXXSA17(E/G) & SA18E, VBHNXXXKA01 & KA03 & KA04, VBHNXXXZA01, VBHNXXXZA02, VBHNXXXZA03, VBHNXXXZA04
Peimar	SGxxxM (FB/BF)
Phono Solar	PS-60, PS-72
Q.Cells	Plus, Pro, Peak, G3, G4, G5, G6(+), G7, G8(+) Pro, Peak L-G2, L-G4, L-G5, L-G6, L-G7

Report No. 102393982LAX-002 Unirac, Inc Page 41 of 122

7.0 Illustrations

Illustration 1aa - Other Ratings Continue

Manufacture	Module Model / Series
REC	PEAK Energy Series, PEAK Energy BLK2 Series,
	PEAK Energy 72 Series, TwinPeak 2 Series, TwinPeak 2 BLK2 Series, TwinPeak Series
Renesola	Vitrus2 Series & 156 Series
Risen	RSM Series
S-Energy	SN72 & SN60 Series (40mm)
Seraphim	SEG-6 & SRP-6 Series
Sharp	NU-SA & NU-SC Series
Silfab	SLA, SLG & BC Series
Solaria	PowerXT
SolarWorld	Sunmodule Protect, Sunmodule Plus
Sonali	5S 230 - 265
Suntech	STP
Suniva	MV Series & Optimus Series
Sun Edison/Flextronics	F-Series, R-Series & FLEX FXS Series
SunPower	X-Series, E-Series & P-Series
Talesun	TP572, TP596, TP654, TP660, TP672, Hipor M, Smart
Tesla	SC, SC B, SC B1, SC B2
Trina	PA05, PD05, DD05, DE06, DD06, PE06, PD14, PE14, DD14, DE14, DE15, PE15H
Upsolar	UP-MooxP(-B), UP-MooxM(-B)
URE	D7MxxxH8A, D7KxxxH8A, D7MxxxH7A
Vikram	Eldora, Solivo, Somera
Waaree	AC & Adiya Series
Winaico	WST & WSP Series
Yingli	YGE & YLM Series

ED 16.3.15 (15-Oct-20) Mandatory



CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

SHEET NAME:

SPEC SHEETS

REVISION:

0

PAGE NUMBER:

Issued: 11-Apr-2016 Revised: 18-Jan-2021

ED 16.3.15 (15-Oct-20) Mandatory

S

SYSTEM COMPONENTS INSTALLATION GUIDE PAGE



Trimrail[™] and Module Clips

Sub-Components:

- 1. Trim Rail
- 2. Module Clip
- 3. T-Bolt
- Tri-Drive Nut 4.

Trimrail™

Functions:

- Required front row structural support (with module clips)
- Module mounting
- Installation aid ٠
- . Aesthetic trim

Features:

- Mounts directly to L-feet ٠
- Aligns and captures module leading edge .
 - Supports discrete module thicknesses from 32, 33, 35, 38, and 40mm

Module Clips

Functions:

- Required front row structural support (with trimrail)
- Module mounting •

Features:

- Mounts to Trimrail[™] with T-bolt and tri-drive nut
- Manually adjustable to fit module thicknesses 32, 33, 35, ٠ 38, and 40mm.



Trimrail[™] Flashkit

Sub-Components:

L-Foot Hex bolt Tri-drive nut Channel Nut Scocket Head Cap Screw 3"Channel/Slider w/grommet 3" Wide Flashing Structural Screw & SS EPDM Washer

Functions:

- Attach Trimrail[™] to roof attachment / flashing
- Patented roof sealing technology at roof attachment point •

Features:

- Slot provides vertical adjustments to level array
- Slider provides north/south adjustment along the slope of the roof
- Shed and Seal Technology

Trimrail[™] Splice

Sub-Components:

- 1. Structural Splice Extrusion
- 2. Bonding Clip

Functions:

- Front row structural support
- Installation aid

Features:

- Tool-less installation





1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.

Structurally connects 2 pieces of Trimrail[™] Electrically bonds 2 pieces of Trimrail[™]

Aligns and connects Trimrail[™] pieces

/NABCEP\			
CERI	IFIED		
PV INST			
PROFES	Gurney		
# PV-011	719-015866		
CONTRACTOR:			
385.498.6700			
SPEC SHEFT			
	REVISION		
- 33	0		

SYSTEM COMPONENTS INSTALLATION GUIDE PAGE



SFM Slider Flashkit

S

Sub-Components:

- 1. Slider w/grommet
- 2. Structural Screw & SS EPDM washer
- 3. 3" Wide Flashing

Functions:

- Patented Shed & Seal roof sealing technology at roof attach-. ment point
- For use with compatible 2" Microrail or 8" Attached Splices ٠

Features:

- . Slider provides north/south adjustment along the slope of the roof
- Shed and Seal Technology ٠



Module-to-Module N-S Bonding

Sub-Components:

- 1. Clamp
- Bonding Pins (2) 2.
- 3. 5/16" Socket Head Cap Screw
- 4. Clamp Base

Functions/ Features:

- Row to row bonding
- Single Use Only
- Fits module sizes 32-40mm



Trim -to- Module Bonding Clamp and Floating Trim Clamp

Sub-Components:

- 1. Wedge
- Bonding Pin 2.
- 3. T-Bolt
- Nut 4.
- Cast Base 5.

Functions/Features:

- Module to Trimrail[™] bonding single use only •
- Attaches Trimrail[™] to module when fewer than 2 rafter attachment points are available
- Fits module sizes 32-40mm
- Fits module sizes 32-40mm



Wire Bonding Clip w/ 8AWG

Functions:

- Row to row bonding
- Module to Trimrail[™] bonding
- Single Use Only

Features:

Tool-less installation



MLPE Mounting Assembly

Sub-Components:

- 1. MLPE Mount Base
- 2. 5/16 Socket Head Cap Screw
- 3. Bonding Pin

Functions:

- MLPE to module bonding

Features:

UL2703 Recognized

MLPE = Module Level Power Electronics, e.g. microinverter or power optimizer



Securely mounts MLPE to module frames

Mounts easily to typical module flange



1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



CONTRACTOR: **BRS FIELD OPS** 385.498.6700

HEET NAME SPEC SHEET

AGE NUMBER SS

REVISION 0







Place flashings

PILOT HOLES: marked attachement points

Drill pilot holes for lag screws or structural screws (as necessary) at





INSTALL SLIDERS AND TRIMRAIL ROOF ATTACHMENTS:

• Insert flashings per manufacturer instructions

NOTE: Use Lag screw or structural fastener with a maximum diameter of 5/16"

- Attach sliders to rafters •
- Verify proper row to row spacing for module size (Mod NS + 1") ٠
- Ensure that TrimrailTM roof attachments in each row have sufficient • engagement with slider dovetails for proper attachment.

