

## **Historic Preservation Services**

Community Development & Neighborhood Services 281 North College Avenue P.O. Box 580 Fort Collins, CO 80522.0580

970.416.4250 preservation@fcgov.com fcgov.com/historicpreservation

## CERTIFICATE OF APPROPRIATENESS ISSUED: November 9, 2021 EXPIRATION: November 9, 2022

Janice Devore 1617 Sheely Dr. Fort Collins, CO 80526

Dear Property Owner:

This letter provides you with confirmation that the proposed changes to your designated Fort Collins landmark property, the McCluskey House at 1617 Sheely Drive have been approved by the City's Historic Preservation Division because the proposed work meets the criteria and standards in Chapter 14, <u>Article IV</u> of the Fort Collins Municipal Code.

1) Rooftop solar installation on rear (southwest-facing) roof.

Notice of the approved application has been provided to building and zoning staff to facilitate the processing of any permits that are needed for the work.

Please note that all ensuing work must conform to the approved plans. Any non-conforming alterations are subject to stop-work orders, denial of Certificate of Occupancy, and restoration requirements and penalties.

If the approved work is not completed prior to the expiration date noted above, you may apply for an extension by contacting staff at least 30 days prior to expiration. Extensions may be granted for up to 12 additional months, based on a satisfactory staff review of the extension request.

Property owners can appeal staff design review decisions by filing a written notice of appeal to the Director of Community Development & Neighborhood Services within fourteen (14) days of this decision. If you have any questions regarding this approval, or if I may be of any assistance, please do not hesitate to contact me. I may be reached at <u>jbertolini@fcgov.com</u>, or 970-416-4250.

Sincerely,

Jim Bertolini Historic Preservation Planner

Applicable Code Standard	Summary of Code Requirement and Analysis (Rehabilitation)	Standard Met
SOI #1	A property will be used as it was historically or be given a new use that requires minimal change to its distinctive materials, features, spaces, and spatial relationships; The house will remain in residential use.	Y
SOI #2	The historic character of a property will be retained and preserved. The removal of distinctive materials or alteration of features, spaces, and spatial relationships that characterize a property will be avoided.	N/A
SOI #3	Each property will be recognized as a physical record of its time, place, and use. Changes that create a false sense of historical development, such as adding conjectural features or elements from other historic properties, will not be undertaken. The solar panels are clearly distinguished as new technology that post-dates the historic period of the Sheely Drive Landmark District.	Y
SOI #4	Changes to a property that have acquired historic significance in their own right will be retained and preserved.	N/A
SOI #5	Distinctive materials, features, finishes, and construction techniques or examples of craftsmanship that characterize a property will be preserved.	N/A
SOI #6	Deteriorated historic features will be repaired rather than replaced. Where the severity of deterioration requires replacement of a distinctive feature, the new feature will match the old in design, color, texture, and, where possible, materials. Replacement of missing features will be substantiated by documentary and physical evidence.	N/A
SOI #7	Chemical or physical treatments, if appropriate, will be undertaken using the gentlest means possible. Treatments that cause damage to historic materials will not be used.	N/A
SOI #8	Archeological resources will be protected and preserved in place. If such resources must be disturbed, mitigation measures will be undertaken.	N/A

SOI #9	New additions, exterior alterations, or related new construction shall not destroy historic materials that characterize the property. The new work shall be differentiated from the old and shall be compatible with the massing, size, scale, and architectural features to protect the historic integrity of the property and its environment. The solar panels will be flush-mounted and located on the rear (southwest-facing) slope of the building. They will have little to no visibility from the public right-of-way and are not disrupting the historic, low-slung gabled roof shape and massing of the historic Ranch-style building.	Y
SOI #10	New additions and adjacent or related new construction will be undertaken in such a manner that, if removed in the future, the essential form and integrity of the historic property and its environment would be unimpaired. Rooftop solar installations are typically reversible with no loss of historic material or features, and this appears to be the case here.	Y







VSE Project Number: U2001.2556.211

October 28, 2021

Blue Raven Solar, LLC ATTENTION: Carson Grover 1220 S. 630 E., Suite 430 American Fork, UT 84003

## REFERENCE: Janice Devore Residence: 1617 Sheely Drive, Fort Collins, CO 80526 Blue Raven Solar, LLC Project: 372602 Solar Array Installation

To Whom It May Concern:

Per your request, we have reviewed the existing structure at the above referenced site. The purpose of our review was to determine the adequacy of the existing structure to support the proposed installation of solar panels on the roof as shown on the panel layout plan.

Based upon our review, we conclude that the existing structure is adequate to support the proposed solar panel installation.

## **Design Parameters**

Code: International Building Code, 2018 Edition Risk Category: II Design wind speed, Vult: 140 mph (3-sec gust) per ASCE 7-16 Wind exposure category: C Ground snow load, Pg: 30 psf Minimum roof snow load, Pm: 30 psf (not reducible)

## **Existing Roof Structure**

Roof structure: 2x8 rafters @ 24" o.c. (Not Vaulted) & 4x8 rafters @ 48" o.c. (Vaulted) Roofing material: composite shingles Roof pitch: 11:12

## **Connection to Roof**

Mounting connection: (1) 5/16" lag screw w/ min. 2.5" threaded embedment into framing at max. 48" o.c. along rails (2) rails per row of panels, evenly spaced; panel length perpendicular to the rails not to exceed 40 in. Rail cantilever shall not exceed 50% of connection spacing.

## **Conclusions**

Based upon our review, we conclude that the existing structure is adequate to support the proposed solar panel installation. The gravity loads, and thus the stresses of the structural elements, in the area of the solar array are either decreased or increased by no more than 5%. Therefore, the requirements of Section 806.2 of the 2018 IEBC are met and the structure is permitted to remain unaltered.



The solar array will be flush-mounted (no more than 10" above the roof surface) and parallel to the roof surface. Thus, we conclude that any additional wind loading on the structure related to the addition of the proposed solar array is negligible. The attached calculations verify the capacity of the connections of the solar array to the existing roof against wind (uplift), the governing load case. Because the increase in lateral forces is less than 10%, this addition meets the requirements of the exception in Section 806.3 of the 2018 IEBC. Thus the existing lateral force resisting system is permitted to remain unaltered.

## **Limitations**

Installation of the solar panels must be performed in accordance with manufacturer recommendations. All work performed must be in accordance with accepted industry-wide methods and applicable safety standards. The contractor must notify Vector Structural Engineering, LLC should any damage, deterioration or discrepancies between the as-built condition of the structure and the condition described in this letter be found. Connections to existing roof framing must be staggered, except at array ends, so as not to overload any existing structural member. The use of solar panel support span tables provided by others is allowed only where the building type, site conditions, site-specific design parameters, and solar panel configuration match the description of the span tables. The design of the solar panel racking (mounts, rails, etc.) and electrical engineering is the responsibility of others. Waterproofing around the roof penetrations is the responsibility of others. Vector Structural Engineering assumes no responsibility for improper installation of the solar array.

## VECTOR STRUCTURAL ENGINEERING, LLC



10/28/2021

Eric Sumsion, P.E. CO License: 56167 - Expires: 10/31/2021 Project Engineer

Enclosures

ESS/wrm



### PROJECT: Janice Devore Residence Components and Cladding Wind Calculations Label: Solar Panel Array Note: Calculations per ASCE 7-16 SITE-SPECIFIC WIND PARAMETERS: Basic Wind Speed [mph]: 140 Notes: Exposure Category: С **Risk Category:** Ш ADDITIONAL INPUT & CALCULATIONS: Height of Roof, h [ft]: 15 (Approximate) Comp/Cladding Location: Gable Roofs $27^{\circ} < \theta \le 45^{\circ}$ **Enclosure Classification: Enclosed Buildings** Zone 1, 2e, 2r GCp: 1.80 0.80 Figure 30.3-2D Zone 1, 2e, 2r $\gamma_a$ : Fig. (negative coeff.) 29.4-8 Zone 2n, 3r GCp: 2.00 Zone 2n, 3r $\gamma_a$ : 0.80 Zone 3e GCp: Zone 3e $\gamma_a$ : 0.80 2.67 9.5 Table 26.11-1 α: z<sub>a</sub> [ft]: 900 Table 26.11-1 K<sub>h</sub>: 0.85 Table 26.10-1 K<sub>e</sub>: 0.83 Table 26.9-1 K<sub>zt</sub>: 1 Equation 26.8-1 K<sub>d</sub>: 0.85 Table 26.6-1 Velocity Pressure, q<sub>h</sub> [psf]: 30.2 Equation 26.10-1 $\gamma_{E}$ : 1.50 Section 29.4.4 $p = q_h (GC_p)(\gamma_E)(\gamma_a)$ WIND PRESSURES: Equation 29.4-7

Zone 1, 2e, 2r, p [psf]:	65.2	psf (1.0 W)
Zone 2n, 3r, p [psf]:	72.4	psf (1.0 W)
Zone 3e, p [psf]:	96.7	psf (1.0 W)

(a = 3 ft)



Janice Devore Residence

PROJECT:

JOB NO.: U2001.2556.211 SUBJECT: WIND PRESSURE Vaulted

### Components and Cladding Wind Calculations Label: Solar Panel Array Note: Calculations per ASCE 7-16 SITE-SPECIFIC WIND PARAMETERS: Basic Wind Speed [mph]: 140 Notes: Exposure Category: С **Risk Category:** П ADDITIONAL INPUT & CALCULATIONS: Height of Roof, h [ft]: 15 (Approximate) Comp/Cladding Location: Gable Roofs $27^{\circ} < \theta \le 45^{\circ}$ Enclosure Classification: Enclosed Buildings Zone 1, 2e, 2r GCp: 1.68 0.75 Figure 30.3-2D Zone 1, 2e, 2r $\gamma_a$ : Fig. (negative coeff.) 29.4-8 Zone 2n, 3r GCp: 2.00 Zone 2n, 3r $\gamma_a$ : 0.80 Zone 3e GCp: Zone 3e $\gamma_a$ : 0.80 2.67 9.5 Table 26.11-1 α: z<sub>a</sub> [ft]: 900 Table 26.11-1 K<sub>h</sub>: 0.85 Table 26.10-1 K<sub>e</sub>: 0.83 Table 26.9-1 K<sub>zt</sub>: 1 Equation 26.8-1 K<sub>d</sub>: 0.85 Table 26.6-1 Velocity Pressure, q<sub>h</sub> [psf]: 30.2 Equation 26.10-1 $\gamma_{E}$ : 1.50 Section 29.4.4 $p = q_h (GC_p)(\gamma_E)(\gamma_a)$ WIND PRESSURES: Equation 29.4-7 Zone 1, 2e, 2r, p [psf]: 56.8 psf (1.0 W) Zone 2n, 3r, p [psf]: 72.4 psf (1.0 W) Zone 3e, p [psf]: psf (1.0 W) 96.7

(a = 3 ft)



## Calculate Uplift Forces on Connection

	Pressure (0.6 Dead -0.6 Wind) (psf)	Max Trib. Width <sup>1</sup> (ft)	Max Trib. Area <sup>2</sup> (ft <sup>2</sup> )	Max Uplift Force (lbs)
Zone 1, 2e, 2r	37.3	4.0	6.7	249
Zone 2n, 3r	41.7	4.0	6.7	278
Zone 3e	56.2	4.0	6.7	375

## **Calculate Connection Capacity**

Lag Screw Size [in]:	5/16	
C <sub>d</sub> :	1.6	NDS Table 2.3.2
Embedment <sup>3</sup> [in]:	2.5	
Grade:	SPF (G = 0.42)	
Nominal Capacity [lbs/in]:	205	NDS Table 12.2A
Number of Screws:	1	
Prying Coefficient:	1.4	
Total Capacity [lbs]:	586	

## **Determine Result**

Maximum Demand [lbs]:	375	
Lag Screw Capacity [lbs]:	586	
Result:	Capacity > Dema	and, Connection is adequate.

## <u>Notes</u>

1. 'Max Trib. Width' is the width along the rails tributary to the connection.

2. 'Max Trib Area' is the product of the 'Max. Trib Width' and 1/2 the panel width/height perpendicular to the rails. (2) rails per row of panels. Length of panels perpendicular to the rails shall not exceed 40".

3. Embedment is measured from the top of the framing member to the beginning of the tapered tip of the lag screw. Embedment in sheathing or other material is not effective. The length of the tapered tip is not part of the embedment length.



## Calculate Uplift Forces on Connection

	Pressure (0.6 Dead -0.6 Wind) (psf)	Max Trib. Width <sup>1</sup> (ft)	Max Trib. Area <sup>2</sup> (ft <sup>2</sup> )	Max Uplift Force (lbs)
Zone 1, 2e, 2r	32.3	4.0	13.3	431
Zone 2n, 3r	41.7	4.0	6.7	278
Zone 3e	56.2	4.0	6.7	375

## **Calculate Connection Capacity**

5/16	
1.6	NDS Table 2.3.2
2.5	
SPF (G = 0.42)	
205	NDS Table 12.2A
1	
1.4	
586	
	5/16 1.6 2.5 SPF (G = 0.42) 205 1 1.4 586

## **Determine Result**

Maximum Demand [lbs]:	431	
Lag Screw Capacity [lbs]:	586	
Result:	Capacity > Dema	and, Connection is adequate.

## <u>Notes</u>

1. 'Max Trib. Width' is the width along the panel seams tributary to the connection.

'Max Trib Area' is the product of the 'Max. Trib Width' and the panel width/height perpendicular to the direction of the connection spacing. Tributary area on connections at array edges are reduced by 50% as they
 Embedment is measured from the top of the framing member to the beginning of the tapered tip of the lag screw. Embedment in sheathing or other material is not effective. The length of the tapered tip is not part of the embedment length.



GRAVITY LOADS		Roof Pitch:	11.0 :12
	Design material	Increase due to	Material weight
ROOF DEAD LOAD (D)	weight [psf]	pitch	[psf]
Composite Shingles	2.7	1.36	2.0
1/2" Plywood	1.4	1.36	1.0
Framing	3.0		3.0
Insulation	0.0		0.0
1/2" Gypsum Clg.	0.0	1.36	0.0
M, E & Misc	0.0		0.0
Total Existing Roof DL	7.1		
PV Array DL	4.1	1.36	3
ROOF LIVE LOAD (Lr)			
Existing Design Roof Live Load [psf]	20	ASCE 7-16 Table 4.3	3-1
Roof Live Load With PV Array [psf]	0	2018 IBC, Section 160	7.13.5
	Ŭ	J	
SNOW LOAD (S):	Existing	w/ Solar Array	
		-	
Roof Slope [x:12]:	11.0	11.0	
Roof Slope [°]:	43	43	
Ground Snow Load, p <sub>g</sub> [psf]:	30	30	ASCE 7-16, Section 7.2
Terrain Category:	С	С	ASCE 7-16, Table 7.3-1
Exposure of Roof:	Fully Exposed	Fully Exposed	ASCE 7-16, Table 7.3-1
Exposure Factor, C <sub>e</sub> :	0.9	0.9	ASCE 7-16, Table 7.3-1
Thermal Factor, C <sub>t</sub> :	1.1	1.1	ASCE 7-16, Table 7.3-2
Risk Category:	II	II	ASCE 7-16, Table 1.5-1
Importance Factor, I <sub>s</sub> :	1.0	1.0	ASCE 7-16, Table 1.5-2
Flat Roof Snow Load, p <sub>f</sub> [psf]:	21	21	ASCE 7-16, Equation 7.3-1
Minimum Roof Snow Load, p <sub>m</sub> [psf]:	30	30	ASCE 7-16, Section 7.3.4
Unobstructed Slippery Surface?	No	Yes	ASCE 7-16, Section 7.4
Slope Factor Figure:	Figure 7-2b	Figure 7-2b	ASCE 7-16, Section 7.4
Roof Slope Factor, C <sub>s</sub> :	0.85	0.46	ASCE 7-16, Figure 7.4-1
Sloped Roof Snow Load, p <sub>s</sub> [psf]:	18	10	ASCE 7-16, Equation 7.4-1
Design Snow Load, S [psf]:	30	30	



Summary of Loads

	Existing	With PV Array
D [psf]	7	11
Lr [psf]	20	0
S [psf]	30	30

Maximum Gravity Loads:

	Existing	With PV Array	_	
(D + Lr) / Cd [psf]	22	12	ASCE 7-16, Section 2.4.1	
(D + S) / Cd [psf]	32	36	ASCE 7-16, Section 2.4.1	
(Cd = Load Duration Easter = 0.0 for D, 1.15 for S, and 1.25 for Lr)				

(Cd = Load Duration Factor = 0.9 for D, 1.15 for S, and 1.25 for Lr)

Maximum Gravity Load [psf]:	32	36

Maximum Member Forces:

GEOMETRY

Span(ft)	12.6	(Approximate)
Solar Panel Array Start, a (ft)	0.0	(Approximate)
Solar Panel Array Length, b (ft)	4.9	(Approximate)
Framing Spacing (ft)	2.0	

MEMBER FORCES

	Shear Capacity	Shear Demand	Ratio	_
Vertical Reaction, $V_1$ (lbs)	979	433	44%	ок
Vertical Reaction, V <sub>2</sub> (lbs)	979	412	42%	ок
	Existing	With PV Array	Ratio	
Moment @ Center, M (lbs-ft)	1275	1317	103%	ок

The gravity loads, and thus the stresses of the structural elements, in the area of the solar array are either decreased or increased by no more than 5%. Therefore, the requirements of Section 806.2 of the 2018 IEBC are met and the structure is permitted to remain unaltered.



Summary of Loads

	Existing	With PV Array
D [psf]	12	16
Lr [psf]	20	0
S [psf]	30	30

Maximum Gravity Loads:

	Existing	With PV Array	_
(D + Lr) / Cd [psf]	26	18	ASCE 7-16, Section 2.4.1
(D + S) / Cd [psf]	36	40	ASCE 7-16, Section 2.4.1
/Cd - Load Duration Factor - 0	Ofer D 1 15 for 6 and 1	2E for Lr)	-

(Cd = Load Duration Factor = 0.9 for D, 1.15 for S, and 1.25 for Lr)

Maximum Gravity Load [psf]:	36	40

Maximum Member Forces:

GEOMETRY

Span(ft)	12.6	(Approximate)
Solar Panel Array Start, a (ft)	0.0	(Approximate)
Solar Panel Array Length, b (ft)	4.9	(Approximate)
Framing Spacing (ft)	4.0	

MEMBER FORCES

	Shear Capacity	Shear Demand	Ratio	
Vertical Reaction, $V_1$ (lbs)	2284	974	43%	ок
Vertical Reaction, V <sub>2</sub> (lbs)	2284	931	41%	ок
	Existing	With PV Array	Ratio	_
Moment @ Center, M (lbs-ft)	2885	2971	103%	Ок

The gravity loads, and thus the stresses of the structural elements, in the area of the solar array are either decreased or increased by no more than 5%. Therefore, the requirements of Section 806.2 of the 2018 IEBC are met and the structure is permitted to remain unaltered.

## **GENERAL NOTES**

## **AERIAL VIEW**

## **CODE AND STANDARDS**

1. ALL WORK SHALL COMPLY WITH 2020 NATIONAL ELECTRIC CODE (NEC), 2018 INTERNATIONAL BUILDING CODE (IBC), 2018 INTERNATIONAL RESIDENTIAL CODE (IRC), 2018 INTERNATIONAL PLUMBING CODE (IPC), AND ALL STATE AND LOCAL BUILDING, ELECTRICAL, AND PLUMBING CODES. 2. DRAWINGS HAVE BEEN DETAILED ACCORDING TO UL LISTING REQUIREMENTS.

## SITE NOTES / OSHA REGULATION

1. A LADDER SHALL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS

2. THE PV MODULES ARE CONSIDERED NON-COMBUSTIBLE AND THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM. 3. THE SOLAR PV INSTALLATION SHALL NOT OBSTRUCT ANY PLUMBING, MECHANICAL, OR BUILDING ROOF VENTS. 4. ROOF COVERINGS SHALL BE DESIGNED, INSTALLED, AND MAINTAINED IN ACCORDANCE WITH THIS CODE AND THE APPROVED MANUFACTURER'S INSTRUCTIONS SUCH THAT THE ROOF COVERING SHALL SERVE TO PROTECT THE BUILDING OR STRUCTURE. 5.NO. OF SHINGLE LAYERS : 1

## SOLAR CONTRACTOR

1. MODULE CERTIFICATIONS WILL INCLUDE UL1703, IEC61646, IEC61730.

2. IF APPLICABLE, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE MARKED GROUNDING LUG HOLES PER THE MANUFACTURER'S INSTALLATION REQUIREMENTS.

3. AS INDICATED BY DESIGN, OTHER NRTL LISTED MODULE GROUNDING DEVICES MAY BE USED IN PLACE OF STANDARD GROUNDING LUGS AS SHOWN IN MANUFACTURER DOCUMENTATION AND APPROVED BY THE AHJ. 4. CONDUIT AND WIRE SPECIFICATIONS ARE BASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO

LIMIT UP-SIZING AS REQUIRED BY FIELD CONDITIONS. 5. CONDUIT POINT OF PENETRATION FROM EXTERIOR TO INTERIOR TO BE INSTALLED AND SEALED WITH A

SUITABLE SEALING COMPOUND

6. DC WIRING LIMITED TO MODULE FOOTPRINT W/ ENPHASE AC SYSTEM.

7. ENPHASE WIRING SYSTEMS SHALL BE LOCATED AND SECURED UNDER THE ARRAY W/ SUITABLE WIRING CLIPS. 8. MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC UNLESS NOT AVAL ABLE

9. ALL INVERTERS, MOTOR GENERATORS, PHOTOVOLTAIC MODULES, PHOTOVOLTAIC PANELS, AC PHOTOVOLTAIC MODULES, DC COMBINERS, DC-TO-DC CONVERTERS, SOURCE CIRCUIT COMBINERS, AND

CHARGE CONTROLLERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER NEC 690.4(B). 10. ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE.

11. TERMINALS AND LUGS WILL BE TIGHTENED TO MANUFACTURER TORQUE SPECIFICATIONS (WHEN PROVIDED) IN ACCORDANCE WITH NEC CODE 110.14(D) ON ALL ELECTRICAL CONNECTIONS.

## **EQUIPMENT LOCATIONS**

1. PROPER ACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL BE PROVIDED AS PER SECTION NEC 110.26.

2. EQUIPMENT INSTALLED IN DIRECT SUNLIGHT MUST BE RATED FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY NEC 690.31(A) AND NEC TABLE 310.15(B)

3. ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC APPLICABLE CODES.

4. ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE.

## **PROJECT INFORMATION:**

**NUMBER OF STORIES: 2 CONDUIT RUN:** Interior ECOBEE QTY: 1 LIGHT BULB QTY: 0 **PV METER:** Not Required

**ROOF TYPE (1) INFORMATION:** 

Ά 56167 10/28/202

**ROOF TYPE:** Comp Shingle FRAMING TYPE: Rafter

- SHEATHING TYPE: TONGUE AND GROOVE
- STANDOFF: SFM Infinity Switchblade Flashkit6
- RACKING: Unirac SFM Infinity @ 48" OC Portrait / 48" OC Landscape NUMBER OF ATTACHMENTS: 27

## **ROOF TYPE (2) INFORMATION (IF APPLICABLE):**

\*SFF PV4.2

## SYSTEM TO BE INSTALLED INFORMATION:

SYSTEM SIZE: 4.4 kW DC MODULE TYPE: (11) REC Solar REC400AA Pure **INVERTER TYPE:** Enphase IQ7PLUS-72-2-US MONITORING: Enphase IQ Combiner 3 X-IQ-AM1-240-3



INSTALLATION OF UTILITY INTERACTIVE PHOTOVOLTAIC SOLAR SYSTEM AND ANY NECESSARY ADDITIONAL WORK NEEDED FOR INSTALLATION.



DRAPER, UTAH 84020



_				
)	LEGEND			
)	JUNCTION BOX	DI LIE DAVEN		
$\left  \right $	M UTILITY METER	SOLAR		
$\left  \right\rangle$	MSP MAIN SERVICE PANEL	1403 N. Research Way Orem, UT 84097		
$\left. \right\rangle$		800.377.4480 WWW.BLUERAVENSOLAR.COM		
$\left\{ \right.$	CB COMBINER BOX	CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR		
$\sum$	LC LOAD CENTER	SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT		
) }	SUB SUBPANEL	IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.		
2	PV PV METER	NABCEP		
$\left  \right\rangle$	TS TRANSFER SWITCH	CERTIFIED		
)	FIRE SETBACK	PV INSTALLATION PROFESSIONAL		
$\left  \right\rangle$	TRENCHING	#PV-011719-015866		
)	PROPERTY LINE	BRS FIELD OPS 385-498-6700		
$\langle  $	SCALE: 1/16" = 1'-0"			
		<b>ATION:</b> 80526		
		CUSTOMER INFORM Janice DeVore 1617 Sheely Dr Fort Collins, Colorado DC SYSTEM SIZE: 4.4 kW DC		
5		DRAWING BY: Eric Thomas		
)		PLOT DATE:		
$\left\{ \right.$		October 20, 2021		
		372602		
$\left\{ \right\}$		SHEET NAME: SITE PLAN		
)		REVISION: PAGE NUMBER:		
)		A   PV2		



	LEGEND				-
	JUNCTION BOX		LUE		VEN
M	UTILITY METER	В	LUE	RA	SOLAR
MSP	MAIN SERVICE PANEL		1403 N. Re Orem, I	esearch JT 8409	Way 97
AC	AC DISCONNECT	v	800.3 VWW.BLUERA	77.4480 VENSC	) DLAR.COM
СВ	COMBINER BOX	CO HEF USE EX	NFIDENTIAL- REIN CONTAIN D FOR THE BI CEPT BLUE R	THE INF IED SH ENEFIT AVEN S	FORMATION ALL NOT BE OF ANYONE SOLAR NOR
LC	LOAD CENTER	SHAL I REC	N PART TO OT	THERS	OUTSIDE ION, EXCEPT
SUB	SUBPANEL	USE ( WITH	ONNECTION V OF THE RESP HOUT THE WR OF BLUE RAV	VITH TH ECTIVE RITTEN EN SOI	HE SALE AND E EQUIPMENT, PERMISSION LAR LLC.
PV	PV METER		NAE	BCE	P
TS	TRANSFER SWITCH		CER	٦IFII	ED
	FIRE SETBACK		PV INST PROFE	ALLA SSIO <sup>Gurney</sup>	TION NAL
	TRENCHING	_		719-015	.866 OR·
	PROPERTY LINE		BRS FII 385-49	ELD ( 98-67	OPS 00
SC	ALE: 1/8" = 1'-0"				
		CUSTOMER INFORMATION:	Janice DeVore 1617 Sheely Dr	Fort Collins, Colorado 80526	DC SYSTEM SIZE: 4.4 kW DC
		URAV	Eric T	hon	nas
		PLOT DATE: October 20, 2021			2021
		PROJECT NUMBER: 372602		2	
		SHEET NAME:			
		ROOF PLAN		AN	
		REVIS		PAGE	
			А		- v3





MODULE SPECIFICATIONS REC Solar	REC400AA Pure	DESIGN LOCATION AND TEMPERATURES CONDUCTOR SIZE CALCULATIONS	
RATED POWER (STC)	400 W	TEMPERATURE DATA SOURCE ASHRAE 2% AVG, HIGH TEMP MICROINVERTER TO MAX, SHORT CIRCUIT CURRENT (ISC) = 13.3 A AC	
MODULE VOC	48.8 V DC	STATE Colorado JUNCTION BOX (1) MAX. CURRENT (ISC X1.25) = 16.6 A AC	
MODULEVMP	42 1 V DC	CITY Fort Collins CONDUCTOR (TC-ER COPPER (90°C)) = 12 AWG	BLUE RAVEN
MODULEIMP	951 A DC	WEATHER STATION FOR COULINS (AWOS)	SOLAR
MODULEISC	10.25 A DC	AND TEMP AND CORPECTION - 34 0.96	1403 N. Research Way
VOC CORRECTION	0.25 ADC		Orem, UT 84097
VOC CORRECTION	-0.24 %/ C	ADJOSTED AWF, - 20.0 > 10.0	800.377.4480
VMP CORRECTION	-0.26 %/ C	JUNCTION BOX TO MAX. SHORT CIRCUIT CORRENT (ISC) = 15.5 A AC	WWW.BLUERAVENSOLAR.COM
SERIES FUSE RATING	25 A DC	$\frac{1}{10000000000000000000000000000000000$	CONFIDENTIAL- THE INFORMATION
ADJ. MODULE VOC @ ASHRAE LOW TEMP	54.4 V DC	NUMBER OF MODULES PER MPPT 11 CONDUCTOR (UF-B, COPPER (60°C)) = 18 12 AWG	USED FOR THE BENEFIT OF ANYONE
ADJ. MODULE VMP @ ASHRAE 2% AVG. HIGH TEMP	37.6 V DC	DC POWER RATING PER CIRCUIT (STC) 4400 CONDUCTOR RATING = 18 20 A	
		TOTAL MODULE NUMBER 11 MODULES CONDUIT FILL DERATE = 2 1	IN PART TO OTHERS OUTSIDE
MICROINVERTER SPECIFICATIONS Enphase IQ7+	+ Microinverters	STC RATING OF ARRAY 4400W DC AMB. TEMP. AMP. CORRECTION = 34 0.96	RECIPIENTS ORGANIZATION, EXCEPT
POWER POINT TRACKING (MPPT) MIN/MAX 22 -	60 V DC	AC CURRENT @ MAX POWER POINT (IMP) 13.3 ADJUSTED AMP. = 19.2 > 16.6	<ul> <li>USE OF THE RESPECTIVE EQUIPMENT,</li> </ul>
MAXIMUM INPUT VOLTAGE	60 V DC	MAX. CURRENT (IMP X 1.25) 16.6375 JUNCTION BOX TO MAX. SHORT CIRCUIT CURRENT (ISC) = 13.3 A AC	OF BLUE RAVEN SOLAR LLC.
MAXIMUM DC SHORT CIRCUIT CURRENT	15 A DC	OCPD CURRENT RATING PER CIRCUIT 20 COMBINER BOX (3) MAX. CURRENT (ISC X1.25) = 16.6 A AC	
MAXIMUM USABLE DC INPUT POWER	440 W	MAX. COMB. ARRAY AC CURRENT (IMP) 13.3 CONDUCTOR (UF-B. COPPER (60°C)) = 18 12 AWG	
MAXIMUM OUTPUT CURRENT	1 21 A AC	MAX ARRAY AC POWER 3190W AC CONDUCTOR RATING = 18 20 A	
AC OVERCLIPRENT PROTECTION	20.4		CERTIFIED
MA VIAUNA OUTPUT POWER	20 A		
CEC WEICUTED FEEICIENCY	290 W	AC VOLTAGE RISE CALCOLATIONS DIST (FT) COND. VRISE(V) VEND(V, %VRISE AND - 34 0.96	PV INSTALLATION
CEC WEIGHTED EFFICIENCY	97 %	VRISE SEC. 1 (MICKO 10 JBOX) 39.6 12 CU. 1.76 241.76 0.73%	- PROFESSIONAL
		VRISE SEC. Z (JBOX TO COMBINER BOX) 40 12 CU. 2.15 242.15 0.90% COMBINER BOX TO INVERTER RATED AMPS = 13.3 A AC	Scott Gurney
AC PHOTOVOLATIC MODULE MARKING (NEC 690.52)		VRISE SEC. 3 (COMBINER BOX TO POI) 10 10 Cu. 0.34 240.34 0.14% MAIN PV OCPD (15) MAX. CURRENT (RATED AMPS X1.25) = 16.64 A AC	
NOMINAL OPERATING AC VOLTAGE	240 V AC	TOTAL VRISE 4.25 244.25 CONDUCTOR (THWN-2, COPPER (75°C TERM.)) = 18 10 AWG	CONTRACTOR:
NOMINAL OPERATING AC FREQUENCY	47 - 68 HZ AC	CONDUCTOR RATING = 18 35 A	BRS FIELD OPS
MAXIMUM AC POWER	240 VA AC	PHOTOVOLTAIC AC DISCONNECT OUTPUT LABEL (NEC 690.54) CONDUIT FILL DERATE = 3 1	385-498-6700
MAXIMUM AC CURRENT	1.0 A AC	AC OUTPUT CURRENT 13.3 A AC AMB. TEMP. AMP. CORRECTION = 34 0.96	
MAXIMUM OCPD RATING FOR AC MODULE	20 A AC	NOMINAL AC VOLTAGE 240 V AC ADJUSTED AMP. = 33.6 > 16.6	
GROUNDING ELECTRODE SYSTEM IN ACCORDANCE WITH [NEC PROVIDED. PER [NEC 690.47], THE GROUNDING ELECTRODE SYSTE USED AND BE BONDED AT THE SERVICE ENTRANCE. IF EXIST INADEQUATE, OR IS ONLY METALLIC WATER PIPING, A SUPPLEMEN USED AT THE INVERTER LOCATION CONSISTING OF A UL LISTED 8 FT 2. THE GROUNDING ELECTRODE CONDUCTOR SHALL BE PROTECTE THE GROUNDING ELECTRODE AND THE PANEL (OR INVERTER) IF S PER [NEC 250.64(B)]. THE GROUNDING ELECTRODE CONDUCTOR SPLICES OR JOINTS AT BUSBARS WITHIN LISTED EQUIPMENT PER [NE 3. GROUNDING ELECTRODE CONDUCTOR SHALL BE NO LESS THAN COPPER AND BONDED TO THE EXISTING GROUNDING ELECTRODE TO 4. PV SYSTEM SHALL BE GROUNDED IN ACCORDANCE TO [NEC 250.21 PARTS OR MODULE FRAMES ACCORDING TO [NEC 690.46]. 5. MODULE SOURCE CIRCUITS SHALL BE GROUNDED IN ACCORDANCI 6. THE GROUNDING CONNECTION TO A MODULE SHALL BE ARRAN MODULE DOES NOT INTERRUPT A GROUNDED CONDUCTOR TO ANOT 7. EACH MODULE WILL BE GROUNDED CONDUCTOR TO ANOT 7. EACH MODULE METALATION INSTRUCTIONS. 8. ENCLOSURES SHALL BE PROPERLY PREPARED WITH REMOVAL OF GROUNDING EQUIPMENT WITH TERMINATION GROUNDING LUGS. 9. GROUNDING SYSTEM COMPONENTS SHALL BE LISTED FOR THEIR EXPOSED TO THE FLEMENTS SHALL BE RATED FOR DIRECTED IN ACCORDING LUGS.	C 690.47] AND [NEC 250, EM OF AN EXISTING BI ITING SYSTEM IS INA ITAL GROUNDING ELEC F GROUND ROD WITH AM ED FROM PHYSICAL DA SMALLER THAN #6 AW WILL BE CONTINUOU IEC 250.64(C)]. 8 AWG AND NO GREAT O PROVIDE FOR A COM 1], [NEC TABLE 250.122] CE TO [NEC 690.42]. NGED SUCH THAT THE THER MODULE. NNECTION POINTS IDE F PAINT/FINISH AS APPI R PURPOSE, AND GROU	0.50-60] SHALL BE ACCESSIBLE, OR ACCESSIBLE, OR CACCESSIBLE, OR CACCESSIBLE, OR ACCESSIBLE, OR ACCESSIBLE, OR CONNECTION REQUIRED IN DC DISCONNECTS ON THE WHITE GROUNDED CONDUCTOR (USE POLARIS BLOCK OR NEUTRAL BAR).         3. ANY CONNECTION REQUIRED IN DC DISCONNECTS ON THE WHITE GROUNDED CONDUCTOR (USE POLARIS BLOCK OR NEUTRAL BAR).         3. ANY CONNECTION ABOVE LIVE PARTS MUST BE WATERTIGHT. REDUCING WASHERS DISALLOWED ABOVE LIVE PARTS, MEYERS HUBS RECOMMENDED US, EXCEPT FOR SURFACE IN ACCORDANCE WITH [NEC 110.2,110.3(A-B)].         5. SOLADECK JUNCTION DOSES MOUNTED FLUSS WITH ROOF SURFACE TO BE USED FOR WIRE MANAGEMENT AND AS FLASHED ROOF PENETRATIONS FOR INTERIOR CONDUIT RUNS.         6. ALL PV CABLES AND CONDERD FUNCTION STOR INTERIOR CONDUIT RUNS.         8. AND ALL METAL BANAGEMENT AND AS FLASHED ROOF DENETRATIONS FOR INTERIOR CONDUIT COMBINER BOXES AS REQUIRED.         7. ALL CONDUCTORS AND OCPD SIZES AND TYPES SPECIFIED ACCORDING TO [NEC 690.8] FOR MULTIPLE CONDUCTORS.         8. ALL PV CABLES AND DORDER TO SUNCIFIED ACCORDING TO [NEC 7ABLE 310.15 (B)(2)(A)], [NEC TABLE 310.15 (B)(3)(A), [NEC 310.15 (B)(3)(C)].         9. EXPOSED ROOF PV DC CONDUCTORS SHALL BE USE 2, 90°C RATED, WET AND UV RESISTANT, AND UL LISTED FARE DR ROUV, UV RATED SPIRAL WRAP SHALL BE USED TO PROTECT WIRE FROM SHAPP EDGES.         9. DASE AND NEITERAL CONDUCTORS SHALL BE USE 2, 90°C RATED, WET AND UV RESISTANT, AND UL LISTED FARE DR ROUV, UV RATED SPIRAL WRAP SHALL BE USED TO PROTECT WIRE FROM SHAPP EDGES.	<b>CUSTOMER INFORMATION</b> Janice DeVore 1617 Sheely Dr Fort Collins, Colorado 80526 <b>DC SYSTEM SIZE:</b> 4.4 kW DC
<ol> <li>10. GROUNDING AND BONDING CONDUCTORS SHALL BE COPPER, S EXPOSED.</li> <li>11. EQUIPMENT GROUNDING CONDUCTORS SHALL BE SIZED ACC MINIMUM OF 10 AWG WHEN NOT EXPOSED TO DAMAGE (6 AWG DAMAGE).</li> </ol>	SOLID OR STRANDED, A CORDING TO [NEC 69 SHALL BE USED WHE	AND BARE WHEN WET AND UV RESISTANT, RATED FOR 600V 11. 4-WIRE DELTA CONNECTED SYSTEMS HAVE THE PHASE WITH THE HIGHER VOLTAGE TO GROUND 190.45] AND BE A IEN EXPOSED TO 12. ALL SOURCE CIRCUITS SHALL HAVE INDIVIDUAL SOURCE CIRCUIT PROTECTION 13. VOLTAGE DROP LIMITED TO 2% FOR DC CIRCUITS AND 3% FOR AC CIRCUITS	DRAWING BY: Eric Thomas
<ol> <li>12. GROUNDING AND BONDING CONDUCTORS, IF INSULATED, SHALL E GREEN IF 4 AWG OR LARGER).</li> <li>13. ALL CONDUIT BETWEEN THE UTILITY AC DISCONNECT AND THE GROUNDED BUSHINGS AT BOTH ENDS.</li> </ol>	BE COLOR CODED GRE	Itel (OR MARKED)       14. NEGATIVE GROUNDED SYSTEMS DC CONDUCTORS SHALL BE COLOR CODED AS FOLLOWS: DC POSITIVE- RED (OR MARKED RED), DC NEGATIVE- GREY (OR MARKED GREY)         ITION SHALL HAVE       15. POSITIVE GROUNDED SYSTEMS DC CONDUCTORS COLOR CODED: DC POSITIVE- GREY (OR MARKED GREY), DC NEGATIVE- BLACK (OR MARKED BLACK)	October 20, 2021
14. SYSTEM GEC SIZED ACCORDING TO [NEC 690.47], [NEC TAE ACCORDING TO [NEC 250.166], MINIMUM 8 AWG WHEN INSULATED, 6 A 15. EXPOSED NON-CURRENT CARRYING METAL PARTS OF MO CONDUCTOR ENCLOSURES SHALL BE GROUNDED IN ACCORDANCE V REGARDLESS OF VOLTAGE	IBLE 250.66], DC SYST AWG WHEN EXPOSED T IODULE FRAMES, EQU WITH [NEC 250.134] OR	TO DAMAGE. PHASE C OR L3- BLUE, NEUTRAL- WHITE/GRAY 20IPMENTS, AND * USE-2 IS NOT INDOOR RATED BUT PV CABLE IS RATED THWN/THWN-2 AND MAY BE USED INSIDE R [NEC 250.136(A)] ** USE-2 IS AVAILABLE AS UV WHITE 17 RIGID CONDUIT JE INSTAIL ED. (AND/OR NIPPLES) MUST HAVE A PULL BUSHING TO PROTECT WIRES	PROJECT NUMBER: 372602
		18. IF CONDUIT DETERMINED TO BE RAN THROUGH ATTIC IN FIELD THEN CONDUIT WILL BE EITHER EMT, FMC, OR MC CABLE IF <u>DC</u> CURRENT COMPLYING WITH [NEC 690.31], [NEC 250.118(10)]. DISCONNECTING MEANS SHALL COMPLY WITH [NEC 690.13] AND [NEC 690.15]. 19. CONDUIT RAN THROUGH ATTIC WILL BE AT LEAST 18" BELOW ROOF SURFACE COMPLYING WITH [NEC	SHEET NAME: ELEC CALCS
		230.6(4)] AND SECURED NO GREATER THAN 6' APART PER [NEC 330.30(B)].	REVISION: PAGE NUMBER:
			A PV6



## STANDARD LABELS

## **ADDITIONAL LABELS**



## LABELING NOTES

1) LABELS CALLED OUT ACCORDING TO ALL COMMON CONFIGURATIONS. ELECTRICIAN TO DETERMINE EXACT REQUIREMENTS IN THE FIELD PER CURRENT NEC AND LOCAL CODES AND MAKE APPROPRIATE ADJUSTMENTS. 2) LABELING REQUIREMENTS BASED ON THE 2017 & 2020 NEC CODE, OSHA STANDARD 19010.145, ANSIZ535. 3) MATERIAL BASED ON THE REQUIREMENTS OF THE AHJ

4) LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED AND SHALL NOT BE HANDWRITTEN [NEC 110.21]

\*ELECTRICAL DIAGRAM SHOWN ABOVE IS FOR LABELING PURPOSES ONLY. NOT AN ACTUAL REPRESENTATION OF EQUIPMENT AND CONNECTIONS TO BE INSTALLED. LABEL LOCATIONS PRESENTED MAY VARY DEPENDING ON TYPE OF INTERCONNECTION METHOD AND LOCATION PRESENTED ON 3 LINE DIAGRAM. 3 LINE DIAGRAM ON PV5 TO REFLECT ACTUAL REPRESENTATION OF PROPOSED SCOPE OF WORK

LABEL U6 IE SUPPLY SIDE TAP SIGN TO BE LOCATED AT MAIN SERVICE PANEL.

## LABEL U7

IF SUPPLY SIDE TAP: SIGN TO BE LOCATED AT FUSED AC DISCONNECT.



1403 N. Research Way Orem, UT 84097

800 377 4480 WWW BI UFRAVENSOLAR COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BILLE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC



**PV INSTALLATION** PROFESSIONAL Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

**CUSTOMER INFORMATION** Colorado 80526 SIZE Sheely Dr Janice DeVore Fort Collins, DC

SYSTEM ( КV DC 4

4.

1617 DRAWING BY Eric Thomas PLOT DATE:

October 20, 2021

PROJECT NUMBER:

372602

LABELS

AGE NUMBER:

PV7

SHEET NAME

REVISION:

Α

Data Sheet **Enphase Microinverters** Region: AMERICAS

## Enphase IQ 7 and IQ 7+ **Microinverters**



The high-powered smart grid-ready Enphase IQ 7 Micro<sup>™</sup> and Enphase IQ 7+ Micro<sup>™</sup> dramatically simplify the installation process while achieving the highest system efficiency.

Part of the Enphase IQ System, the IQ 7 and IQ 7+ Microinverters integrate with the Enphase IQ Envoy<sup>™</sup>, Enphase IQ Battery<sup>™</sup>, and the Enphase Enlighten<sup>™</sup> monitoring and analysis software.

IQ Series Microinverters extend the reliability standards set forth by previous generations and undergo over a million hours of power-on testing, enabling Enphase to provide an industry-leading warranty of up to 25 years.

## Easy to Install

- Lightweight and simple
- · Faster installation with improved, lighter two-wire cabling
- Built-in rapid shutdown compliant (NEC 2014 & 2017)

## Productive and Reliable

- Optimized for high powered 60-cell/120 half-cell and 72cell/144 half-cell\* modules
- More than a million hours of testing
- · Class II double-insulated enclosure
- UL listed

## Smart Grid Ready

- Complies with advanced grid support, voltage and frequency ride-through requirements
- · Remotely updates to respond to changing grid requirements
- Configurable for varying grid profiles
- Meets CA Rule 21 (UL 1741-SA)

\* The IQ 7+ Micro is required to support 72-cell/144 half-cell modules.

## Enphase IO 7 and IO 7+ Microinverters

		_	
INPUT DATA (DC)	IQ7-60-2-US		IQ7PLUS-72-
Commonly used module pairings <sup>1</sup>	235 W - 350 W +		235 W - 440 W
Module compatibility	60-cell/120 half-	cell PV modules	60-cell/120 ha
	only		cell/144 half-c
Maximum input DC voltage	48 V		60 V
Peak power tracking voltage	27 V - 37 V		27 V - 45 V
Operating range	16 V - 48 V		16 V - 60 V
Min/Max start voltage	22 V / 48 V		22 V / 60 V
Max DC short circuit current (module lsc)	15 A		15 A
Overvoltage class DC port	II		Ш
DC port backfeed current	0 A		0 A
PV array configuration	1 x 1 ungrounde AC side protection	d array; No additio on requires max 2(	al DC side prote A per branch cire
OUTPUT DATA (AC)	IQ 7 Microinve	rter	IQ 7+ Microi
Peak output power	250 VA		295 VA
Maximum continuous output power	240 VA		290 VA
Nominal (L-L) voltage/range <sup>2</sup>	240 V /	208 V /	240 V /
	211-264 V	183-229 V	211-264 V
Maximum continuous output current	1.0 A (240 V)	1.15 A (208 V)	1.21 A (240 V)
Nominal frequency	60 Hz		60 Hz
Extended frequency range	47 - 68 Hz		47 - 68 Hz
AC short circuit fault current over 3 cycles	5.8 Arms		5.8 Arms
Maximum units per 20 A (L-L) branch circuit <sup>3</sup>	16 (240 VAC)	13 (208 VAC)	13 (240 VAC)
Overvoltage class AC port			
AC port backfeed current	18 mA		18 mA
Power factor setting	1.0		1.0
Power factor (adjustable)	0.85 leading 0	.85 lagging	0.85 leading
EFFICIENCY	@240 V	@208 V	@240 V
Peak efficiency	97.6 %	97.6 %	97.5 %
CEC weighted efficiency	97.0 %	97.0 %	97.0 %
MECHANICAL DATA			
Ambient temperature range	-40°C to +65°C		
Relative humidity range	4% to 100% (con	densing)	
Connector type	MC4 (or Ampher	nol H4 UTX with ad	ditional Q-DCC-5
Dimensions (HxWxD)	212 mm x 175 m	m x 30.2 mm (with	out bracket)
Weight	1.08 kg (2.38 lbs	5)	
Cooling	Natural convection	on - No fans	
Approved for wet locations	Yes		
Pollution degree	PD3		
Enclosure	Class II double-in	nsulated, corrosior	n resistant polym
Environmental category / UV exposure rating	NEMA Type 6 / c	outdoor	
FEATURES			
Communication	Power Line Com	munication (PLC)	
Monitoring	Enlighten Manager and MyEnlighten monitoring op Both options require installation of an Enphase IQ I		
Disconnecting means	The AC and DC of disconnect requ	connectors have be ired by NEC 690.	en evaluated and
Compliance	CA Rule 21 (UL 1 UL 62109-1, UL1 CAN/CSA-C22.2 This product is L 2017, and NEC 2 for AC and DC co	1741-SA) 741/IEEE1547, FCC 2 NO. 107.1-01 JL Listed as PV Raj 020 section 690.12 onductors, when in	Part 15 Class B, bid Shut Down Ec 2 and C22.1-2015 stalled according

No enforced DC/AC ratio. See the compatibility calculator at <u>https://enphase.com/en-us/support/module-compatibility</u>
 Nominal voltage range can be extended beyond nominal if required by the utility.
 Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.



## **ENPHASE**. To learn more about Enphase offerings, visit **enphase.com**

© 2020 Enphase Energy. All rights reserved. Enphase, the Enphase logo, Enphase IQ 7, Enphase IQ 7+, Enphase IQ Battery, Enphase Enlighten, Enphase IQ Envoy, and other trademarks or service names are the trademarks of Enphase Energy, Inc

To learn more about Enphase offerings, visit enphase.com

2-US	BLUE	SOLAR
rell PV modules	1403 N RESEARCI OREM,	H WAY, BUILDING J UT 84097
	800-37 WWW.BLUERA	77-4480 VENSOLAR.COM
ction required; cuit nverter 208 V / 183-229 V	CONFIDENTIAL - 1 HEREIN CONTAIN USED FOR TH ANYONE EXCE SOLAR NOF DISCLOSED IN W TO OTHERS OUT ORGANIZATIO CONNECTION WI USE OF THE EQUIPMENT, WRITTEN PERM RAVEN S	THE INFORMATION ED SHALL NOT BE IE BENEFIT OF PT BLUE RAVEN SHALL IT BE (HOLE OR IN PART SIDE RECIPIENTS DN, EXCEPT IN TH THE SALE AND RESPECTIVE WITHOUT THE 1ISSION OF BLUE OLAR LLC.
1.39 A (208 V) 11 (208 VAC)	NAB CERT PV INSTA PROFES Scott # PV-011	CEP IFIED ALLATION SSIONAL Gurney 719-015866
. 0.85 lagging @208 V 97.3 %	CONTR BRS FIE 385.49	ACTOR: ELD OPS 98.6700
adapter) eric enclosure		
ions. nvoy. d approved by UL for use as the load-break		
ICES-0003 Class B, Juipment and conforms with NEC 2014, NEC Rule 64-218 Rapid Shutdown of PV Systems, g manufacturer's instructions.		
tibility.		
	SHEET NAME	HEET
Data subject to change. 2020-08-12	PAGE NUMBER	

# Enphase **IQ Combiner 3**

(X-IQ-AM1-240-3)

The **Enphase IQ Combiner 3**<sup>™</sup> with Enphase IQ Envoy<sup>™</sup> consolidates interconnection equipment into a single enclosure and streamlines PV and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.



# LISTED

Smart

- Includes IQ Envoy for communication and control
- Flexible networking supports Wi-Fi, Ethernet, or cellular
- Optional AC receptacle available for PLC bridge
- Provides production metering and optional consumption monitoring

## Simple

- · Reduced size from previous combiner
- Centered mounting brackets support single stud mounting
- Supports back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- 80 A total PV or storage branch circuits

## Reliable

- Durable NRTL-certified NEMA type 3R enclosure
- Five-year limited warranty
- UL listed

## Enphase IQ Combiner 3

MODEL NOMBER								
IQ Combiner 3 X-IQ-AM1-240-3	IQ Combiner 3 with Enphase IQ Envoy™ printed production metering (ANSI C12.20 +/- 0.5%) an							
ACCESSORIES and REPLACEMENT PARTS (n	ot included, order separately)							
Enphase Mobile Connect <sup>™</sup> CELLMODEM-03 (4G/12-year data plan) - CELLMODEM-01 (3G/5-year data plan) CELLMODEM-M1 (4G based LTE-M/5-year data plan) Consumption Monitoring* CT CT-200-SPLIT * Consumption monitoring is required for Enphase Storage System	Plug and play industrial grade cellular modem microinverters. (Available in the US, Canada, M ) where there is adequate cellular service in the Split core current transformers enable whole h							
Wireless USB adapter COMMS-KIT-01 Circuit Breakers BRK-10A-2-240 BRK-15A-2-240 BRK-20A-2P-240	Installed at the IQ Envoy. For communications w Enpower <sup>™</sup> smart switch. Includes USB cable for and allows redundant wireless communication v Supports Eaton BR210, BR215, BR220, BR230, Circuit breaker, 2 pole, 10A, Eaton BR210 Circuit breaker, 2 pole, 15A, Eaton BR215 Circuit breaker, 2 pole, 20A, Eaton BR220							
EPLC-01	Power line carrier (communication bridge pair)							
XA-PLUG-120-3	Accessory receptacle for Power Line Carrier in							
XA-ENV-PCBA-3	Replacement IQ Envoy printed circuit board (PC							
ELECTRICAL SPECIFICATIONS								
Rating								
System voltage	120/240 VAC, 60 Hz							
Laton BR series busbar rating	125 A							
Max. continuous current rating (output to grid)	65 A							
Max. fuse/circuit rating (output)	90 A							
Branch circuits (solar and/or storage)	Up to four 2-pole Eaton BR series Distributed G							
Max. continuous current rating (input from PV)	64 A							
Max. total branch circuit breaker rating (input)	80A of distributed generation / 90A with IQ Env							
Production Metering CI	200 A solid core pre-installed and wired to IQ E							
Dimensions (WxHxD)	49.5 x 37.5 x 16.8 cm (19.5" x 14.75" x 6.63"). H							
weight	7.5 kg (16.5 lbs)							
Ambient temperature range	-40° C to +46° C (-40° to 115° F)							
Cooling	Natural convection, plus heat shield							
Wire sizes	<ul> <li>20 A to 50 A breaker inputs: 14 to 4 AWG cop</li> <li>60 A breaker branch input: 4 to 1/0 AWG cop</li> <li>Main lug combined output: 10 to 2/0 AWG co</li> <li>Neutral and ground: 14 to 1/0 copper conduct</li> <li>Always follow local code requirements for con-</li> </ul>							
Integrated Wi-Fi	802 11b/a/n							
Ethernet	Optional 802.3 Cat5E (or Cat 6) UTP Ethernet							
Cellular	Optional, CELLMODEM-01 (3G) or CELLMODE							
COMPLIANCE	(not included)							
Compliance, Combiner	UL 1741, CAN/CSA C22.2 No. 107.1, 47 CFR. Pa							
Compliance, IQ Envoy	Production metering: ANSI C12.20 accuracy cl UL 60601-1/CANCSA 22.2 No. 61010-1							

To learn more about Enphase offerings, visit enphase.com



© 2018 Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ Combiner 3, and other trademarks or service 

To learn more about Enphase offerings, visit enphase.com

		-
circuit board for integrated revenue grade PV d optional* consumption monitoring (+/- 2.5%).	BLUE	RAVEN
vith data plan for systems up to 60	1403 N RESEARCH OREM, I	H WAY, BUILDING J UT 84097
nstallation area.) ome consumption metering (+/- 2.5%).	800-37 WWW.BLUERA	77-4480 VENSOLAR.COM
th Enphase Encharge <sup>™</sup> storage and Enphase connection to IQ Envoy or Enphase IQ Combiner <sup>™</sup> /ith Encharge and Enpower. BR240, BR250, and BR260 circuit breakers. quantity - one pair IO Combiner 3 (required for EPLC-01)	CONFIDENTIAL - 1 HEREIN CONTAIN USED FOR TH ANYONE EXCE SOLAR NOF DISCLOSED IN W TO OTHERS OUT ORGANIZATIC CONNECTION WI USE OF THE EQUIPMENT, WRITTEN PERM RAVEN S	THE INFORMATION IED SHALL NOT BE BE BENEFIT OF PT BLUE RAVEN & SHALL IT BE (HOLE OR IN PART "SIDE RECIPIENTS DN, EXCEPT IN TH THE SALE AND RESPECTIVE WITHOUT THE MISSION OF BLUE OLAR LLC.
CB) for Combiner 3		
	PV INSTA PROFES scott # PV-011	CEP IFIED ALLATION SSIONAL Gurney 719-015866
eneration (DG) breakers only (not included)	CONTR BRS FIE 385.49	ACTOR: ELD OPS 98.6700
oy breaker included		
nvoy		
eight is 21.06" (53.5 cm with mounting brackets).		
rhanata construction		
per conductors per conductors opper conductors tors ductor sizing.		
cable (not included) 1-03 (4G) or CELLMODEM-M1 (4G based LTE-M)		
art 15, Class B, ICES 003 ass 0.5 (PV production)		
	SHEET NAME	HEET
	PAGE NUMBER	REVISION
	SS	0



## PRODUCT SPECIFICATIONS

C 61215:2016, IEC 61730:2016, UL 61730							
C 62804	PID						
EC 61701	Salt Mist						
C 62716	Ammonia Resistance						
L 61730	Fire Type Class 2						
C 62782	Dynamic Mechanical Load						
C 61215-2:2016	Hailstone (35mm)						
C 62321	Lead-free acc. to RoHS EU 863/2015						
014001:2004, ISO 9001:2015, OHSAS 18001:2007, IEC 62941							



	Standard	REC	ProTrust
istalled by an REC Certified olar Professional	No	Yes	Yes
ystem Size	All	≤25 kW	25-500 kW
roduct Warranty (yrs)	20	25	25
ower Warranty (yrs)	25	25	25
abor Warranty (yrs)	0	25	10
ower in Year 1	98%	98%	98%
nnual Degradation	0.25%	0.25%	0.25%
ower in Year 25	92%	92%	92%

See warranty documents for details. Conditions apply

)perational temperature:	-40+185°F (-40+85°C)
laximum system voltage:	1000 V
/laximum test load (front):	+ 7000 Pa (146 lbs/sq ft)*
/laximum test load (rear):	- 4000 Pa (83.5 lbs/sq ft)*
lax series fuse rating:	25 A
lax reverse current:	25 A
*See installat	ion manual for mounting instruction

Design load = Test load / 1.5 (safety factor)

ominal Module Operating Temperature:	44°C (±2°C)
emperature coefficient of P <sub>MAX</sub> :	-0.26 %/°C
emperature coefficient of V <sub>oc</sub> :	-0.24 %/°C
emperature coefficient of I <sub>sc</sub> :	0.04 %/°C

The temperature coefficients stated are linear value:

-	ľ																																			
	l																																			
90	ľ		-	-	-	ł	-														-	-		-	-							-				
95	ľ	-	2	7				1									1			-	-	-	-	-					1			-			1	
••	ľ		-	-	-		1			-			ł	-	-	-		-	-	-	-	-	1			-										
os																																				



1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



CONTRACTOR: BRS FIELD OPS 385.498.6700

SHEET NAME

SPEC SHEET

PAGE NUMBER

SS

REVISION

## Product data sheet Characteristics

## DU221RB

Safety switch, general duty, non fusible, 30A, 2 poles, 3 hp, 240 VAC, NEMA 3R, bolt-on provision

Product availability : Stock - Normally stocked in distribution facility

## SQUARE D



Price\* : 177.00 USD



### Main

141CHL1		
Product	Single Throw Safety Switch	
Current Rating	30 A	
Certifications	UL listed file E2875	
Enclosure Rating	NEMA 3R	
Disconnect Type	Non-fusible disconnect switch	
Factory Installed Neutral	None	
Mounting Type	Surface	
Number of Poles	2	
Electrical Connection	Lugs	
Duty Rating	General duty	
Voltage Rating	240 V AC	
Wire Size	AWG 14AWG 6 copper AWG 12AWG 6 aluminium	

### Complementary

and the second se		
Short-circuit withstand	200 kA	
Maximum Horse Power Rating	3 hp 240 V AC 60 Hz 1 phase NEC 430.52	
Tightening torque	30 lbf.in (3.39 N.m) 0.000.02 ir <sup>a</sup> (2.0813.3 mm <sup>a</sup> ) AWG 14AWG 6)	
Height	9.63 in (244.60 mm)	
Width	7.75 in (196.85 mm)	
Depth	3.75 in (95.25 mm)	

\* Price is "List Price" and may be subject to a trade discount - check with your local distributor or retailer for actual price. Apr 21, 2021

Lileisin Schoolder

Ordering and shipping details	
Category	00106 - D & DU SW,NEMA3R, 30-200A
Discount Schedule	DE1A
GTIN	00785901490340
Nbr. of units in pkg.	1
Package weight(Lbs)	4.65 lb(US) (2.11 kg)
Returnability	Yes
Country of origin	MX
Packing Units	
Unit Type of Package 1	PCE
Package 1 Height	5.40 in (13.716 cm)
Package 1 width	7.80 in (19.812 cm)
Package 1 Length	9.90 in (25.146 cm)
Unit Type of Package 2	CAR
Number of Units in Package 2	5
Package 2 Weight	24.60 lb(US) (11.158 kg
Package 2 Height	10.80 in (27.432 cm)
Package 2 width	10.50 in (26.67 cm)
Package 2 Length	23.80 in (60.452 cm)
Unit Type of Package 3	PAL
Number of Units in Package 3	160
Package 3 Weight	814.00 lb(US) (369.224 kg)
Package 3 Height	46.50 in (118.11 cm)
Package 3 width	40.00 in (101.6 cm)
Package 3 Length	48.00 in (121.92 cm)
Offer Sustainability	
Sustainable offer status	Green Premium product
California proposition 65	WARNING: This product can expose you to chemicals is known to the State of California to cause cancer and more information on to wear P65Warnings can new

Galifornia proposition do	is known to the State of California to cause cancer and bir more information go to www.P65Warnings.ca.gov
REACh Regulation	REACh Declaration
REACh free of SVHC	Yes
EU RoHS Directive	Compliant EU RoHS Declaration
Toxic heavy metal free	Yes
Mercury free	Yes
RoHS exemption information	Yes
China RoHS Regulation	China RoHS declaration Pro-active China RoHS declaration (out of China RoHS le
Environmental Disclosure	Product Environmental Profile
PVC free	Yes

### Contractual warranty

Warranty

18 months

2

1

Libb Cn Schneider



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



**PV INSTALLATION** PROFESSIONAL Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

including: Lead and lead compounds, which irth defects or other reproductive harm. For

gal scope)

SHEET NAME:

SPEC SHEETS

REVISION:

PAGE NUMBER: SS

0

**Specification Sheet** 

PV Junction Box for Composition/Asphalt Shingle Roofs

## A. System Specifications and Ratings

- o Maximum Voltage: 600 Volts
- Maximum Current: 60 Amps
- Allowable Wire: 14 AWG 6 AWG
- Spacing: Please maintain a spacing of at least ½" between uninsulated live parts and fittings for conduit, armored cable, and uninsulated lie parts of opposite polarity. 0
- Enclosure Rating: Type 3R 0
- Roof Slope Range: 2.5 12:12
- Max Side Wall Fitting Size: 1" 0
- Max Floor Pass-Through Fitting Size: 1"
- Ambient Operating Conditions: -35°C +75°C 0
- Compliance: 0
  - JB-1: UL1741
  - Approved wire connectors: must conform to UL1741
- System Marking: Intertek Symbol and File # 5015705
- Periodic Re-inspections: If re-inspections yield loose components, loose fasteners, or any corrosion between components, components that are found to be affected are to be replaced immediately.

Table	1; T	ypical	Wire	Size,	Torque	Loads and	Ratings
-------	------	--------	------	-------	--------	-----------	---------

					Torque		
	1 Conductor	2 Conductor	Туре	NM	Inch Lbs	Voltage	Current
ABB ZS6 terminal block	10-24 awg	16-24 awg	Sol/Str	0.5-0.7	6.2-8.85	600V	30 amp
ABB ZS10 terminal block	6-24 awg	12-20 awg	Sol/Str	1.0-1.6	8.85-14,16	600V	40 amp
ABB ZS16 terminal bock	4-24 awg	10-20 awg	Sol/Str	1.6-2.4	14.6-21.24	600V	60 amp
ABB M6/8 terminal block	8-22 awg		Sol/Str	.08-1	8.85	600V	50 amp
Ideal 452 Red WING-NUT Wire Connector	8-18 awg		Sol/Str			600V	
Ideal 451 Yellow WING-NUT Wire Connector	10-18 awg		Sol/Str			600V	
Ideal, In-Sure Push-In Connector Part #39	10-14 awg		Sol/Str			600V	
International Undersulies 252/0	10-14 awg		Sol/Str	4	35	_	
international Hydraulics 252/0	8 awg		Sol/Str	4.5	40		
Reumall & E 2	4-6 awg		Sol/Str		45	200011	
bruman 4-5,5	10-14 awg		Sol/Str		35	200	000
Blackburn LL414	4-14 awg		Sol/Str				

Table 2: Minimum wire-bending space for conductors through a wall opposite terminals in mm (inches)

Wire size	e, AWG or	Wires per terminal (pole)							
			1		2		3	4 or	More
kcmil	(mm2)	mm	(inch)	mm	(inch)	mm	(inch)	mm	(inch)
14-10	(2.1-5.3)	Not sp	pecified		•	3	-	1	×.
8	(8.4)	38.1	(1-1/2)	9	-	3	• 2		-
6	(13.3)	50.8	(2)		-		-		-

www.ezsolarproducts.com



-	PART NUMBER	DESCRIPTION	QTY.
	B-1 Body w/ E-Z LOK ECHNOLOGY	POLYCARBONATE WITH UV INHIBITORS	-
	18-1 Lid w/ Gasket	POLYCARBONATE WITH UV INHIBITORS	-
the PT	0-32 x 1-1/4" Phillips oan head bolt		s
	#8 x 1-1/4" Philips oan head screw		4

N

3

4





# Carlon



NEC and National Electrical Code are registered trademarks of the National Fire Protection Association, Inc.

www.tnb.com

United States Tel: 901.252.8000 800.816.7809 Fax: 901.252.1354

Tel: 888.862.3289

**Technical Services** 

Thomas@Betts A-269



# SYSTEM BONDING & GROUNDING PAGE



Star Washer is Single Use Only

TERMINAL TOROUE, Install Conductor and torque to the following: 4-6 AWG: 35in-lbs 8 AWG: 25 in lbs 10-14 AWG: 20 in-lbs

## LUG DETAIL & TORQUE INFO Ilsco Lay-In Lug (GBL-4DBT)

- 10-32 mounting hardware
- Torque = 5 ft-lb
- AWG 4-14 Solid or Stranded

SFN SUN FRAME



TERMINAL TOROUE, Install Conductor and torque to the following: 4-14 AWG: 35in-lbs

## LUG DETAIL & TORQUE INFO Ilsco Flange Lug(SGB-4)

- 1/4" mounting hardware .
- Torque = 75 in-lb

NOTE: ISOLATE COPPER FROM ALUMINUM CONTACT TO PREVENT CORROSION

AWG 4-14 - Solid or Stranded

## WEEBLUG Single Use Only



TERMINAL TOROUE. Install Conductor and torque to the following: 6-14 AWG: 7ft-lbs

## LUG DETAIL & TORQUE INFO Wiley WEEBLug (6.7)

- 1/4" mounting hardware
- Torque = 10 ft-lb
- AWG 6-14 Solid or Stranded

System bonding is accomplished through modules. System grounding accomplished by attaching a ground lug to any module at a location on the module specified by the module manufacturer.









# UL CODE COMPLIANCE NOTES Installation guide Page

## SYSTEM LEVEL FIRE CLASSIFICATION

The system fire class rating requires installation in the manner specified in the SUNFRAME MICRORAIL (SFM) Installation Guide. SFM has been classified to the system level fire portion of UL 1703. This UL 1703 classification has been incorporated into the UL 2703 product certification. SFM has achieved Class A, B & C system level performance for low slope & steep sloped roofs when used in conjunction with type 1 and type 2 modules. Class A, B & C system level fire performance is inherent in the SFM design, and no additional mitigation measures are required. The fire classification rating is valid for any roof pitch. There is no required minimum or maximum height limitation above the roof deck to maintain the Class A, B & C fire rating for SFM. SUNFRAME MICRORAIL<sup>™</sup> components shall be mounted over a fire resistant roof covering rated for the application.

Module Type	Roof Slope	System Level Fire Rating	Microrail Direction	Module Orientation	Mitigation Require
Type 1 and Type 2	Steep Slope & Low Slope	Class A, B & C	East-West	Landscape OR Portrait	None Required

## **UL2703 TEST MODULES**

See page "S" for a list of modules that were electrically and mechanically tested or qualified with the SUNFRAME MICRORAIL (SFM) components outlined within this Installation Guide.

- Maximum Area of Module = 22.3 sqft
- UL2703 Design Load Ratings:
  - Downward Pressure 113 PSF / 5400 Pa a)
  - b) Upward Pressure - 50 PSF / 2400 Pa
  - Down-Slope Load 30 PSF / 1400 Pa c)
- Tested Loads:
  - Downward Pressure 170 PSF / 8000 Pa a)
  - b) Upward Pressure - 75 PSF / 3500 Pa
  - c) Down-Slope Load – 45 PSF / 2100 Pa
- Maximum Span = 6ft
- Use with a maximum over current protection device OCPD of 30A
- System conforms to UL Std 2703, certified to LTR AE-001-2012
- Rated for a design load of 2400 Pa / 5400 Pa with 24 inch span

## LABEL MARKINGS

- System fire class rating: See installation instructions for installation requirements to achieve a specified system fire class rating with Unirac.
- Unirac SUNFRAME MICRORAIL<sup>™</sup> is listed to UL 2703.
- All splices within a system are shipped with marking indicating date and location of manufacture.



2 INCH MINIMUM MODULE ENGAGEMENT





REVISION:

AGE NUMBER

0

SS

## SFN SUN FRAME MICRORAIL™

# **TESTED / CERTIFIED MODULE LIS** Installation Guid

Manufacture	Module Model / Series	Manufacture	Module Model / Series	Manufacture	Module Model / Series
Aleo	P-Series	Hansol	TD-AN3, TD-AN4,		LR4-60(HIB/HIH/HPB/HI
Astronerov	CHSM6612P, CHSM6612P/HV, CHSM6612M, CHSM6612M/HV, CHSM6610M (BL)(BF)/(HF).	Heliene	36M, 60M, 60P, 72M & 72P Series		LR6-60(BP/HBD/HIBD)->
	CHSM72M-HC	HT Solar	HT60-156(M) (NDV) (-F), HT 72-156(M/P)	LONGI	LR6-60(BK)(PE)(HPB)(HP LR6-60(BK)(PE)(PB)(PH)-
Auxin	AXN6M612T & AXN6P612T	Hyundai	KG, MG, TG, RI, RG, TI, MI, HI & KI Series		LR6-72(BP)(HBD)(HIBD)-
	AXIblackpremium 60 (35mm).	ITEK	iT, iT-HE & iT-SE Series		LR6-72(HV)(BK)(PE)(PH)(
	AXIpower 60 (35mm),	Japan Solar	JPS-60 & JPS-72 Series		(35mm)
Axitec	AXIpower 72 (40mm),		JAP6 60-xxx, JAM6-60-xxx/SI, JAM6(K)-60/	Mission Solar Energy	MSE Series
	AXIpremium 60 (35mm),		xxx, JAP6(k)-72-xxx/4BB, JAP72SYY-xxx/ZZ,	Mitsubishi	MJE & MLE Series
	AXIpremium 72 (40mm).		JAP6(k)-60-xxx/4BB, JAP60SYY-xxx/ZZ, JAM6(k)-72-xxx/ZZ, JAM72SYY-xxx/ZZ, JAM6(k)-60-xxx/ZZ, JAM60SYY-xxx/ZZ. i. YY: 01, 02, 03, 09, 10 ii. ZZ: SC, PR, BP, HIT, IB, MW JKM & JKMS Series	Neo Solar Power Co.	D6M & D6P Series
Aptos	DNA-120-MF26	JA Solar			VBHNxxxSA15 & SA16,
Boviet	BVM6610, BVM6612			Panasonic	VBHNxxxSA17 & SA18. VBHNxxxSA17(E/G) & SA VBHNxxxKA01 & KA03 &
BYD	P6K & MHK-36 Series	linko			
	Inite of the control	KII Series		VBHNxxxZA01, VBHNxxx	
Canadian Solar		Nyocera	LGxxxN2T-A4 LGxxx(A1C/E1C/E1K/N1C/N1K/N2T/N2W/ Q1C/Q1K/S1C/S2W)-A5 LGxxx(A1C/M1C/M1K/N1C/N1K/Q1C/Q1K/		VDHINXXXZAUS, VDHINXX
				Peimar	SGxxxM (FB/BF)
Canadian Solar				Phono Solar	PS-60, PS-72
CS3U, CS CS6U, CS	CS3U, CS3U-MB-AG, CS3K-MB-AG, CS6K, CS6U, CS3L, CS3W, CS1H-MS, CS1U-MS	LG Electronics		Q.Cells	Plus, Pro, Peak, G3, G4, G Pro, Peak L-G2, L-G4, L-G
Centrosolar America	C-Series & E-Series		LGxxx(N2T/N2W)-E6		Alpha (72) (Black)
CertainTeed	CT2xxMxx-01, CT2xxPxx-01, CTxxxMxx-02, CTxxxM-03, CTxxxMxx-04, CTxxxHC11-04		LGxxx(N1C/N1K/N2W/S1C/S2W)-G4 LGxxxN2T-J5 LGxxx(N1K/N2T/N2W)-L5		N-Peak (Black) PEAK Energy Series PEAK Energy BLK2 Serie
Dehui	DH-60M		LGxxx(N1C/Q1C/Q1K)-N5	REC	TwinPeak Series
Eco Solargy	Orion 1000 & Apollo 1000		LGxxx (N1C/N1K/N2W/Q1C/Q1K)-V5	]	TwinPeak 2 Series
FreeVolt	Mono PERC				TwinPeak 2 BLK2 Series
GCL	GCL-P6 & GCL-M6 Series				TwinPeak 25(M)72(XV)
					TwinDook 3 Series (38m)

Please see the SFM UL2703Construction Data Report at Unirac.com to ensure the exact solar module selected is approved for use with S SFM Infinity is not compatible with module frame height of less than 30mm and more than 40mm. See page J for further information

		-
2 T	BLUE	SOLAR
	1403 N. Re Orem, U	search Way T 84097
DE¦PAGE	800.37 WWW.BLUERAN	7.4480 /ENSOLAR.COM
PH)-xxxM	CONFIDENTIAL- T HEREIN CONTAIN USED FOR THE BE EXCEPT BLUE RA SHALL IT BE DISCLO IN PART TO OT RECIPIENTS ORGA IN CONNECTION W USE OF THE RESPE WITHOUT THE WRI OF BLUE RAVE	HE INFORMATION ED SHALL NOT BE NEFIT OF ANYONE VEN SOLAR NOR DSED IN WHOLE OR HERS OUTSIDE NIZATION, EXCEPT ITH THE SALE AND CTIVE EQUIPMENT, TTEN PERMISSION EN SOLAR LLC.
cxxM (30mm)		
-xxxM (40mm)	/NAB	CEP
-xxxM (30mm)	CERT	IFIED
(PB)(HPH)-xxxM	PV INSTA PROFES Scott 0 #PV-0117	LLATION SSIONAL Gurney 19-015866
	CONTR BRS FIE 385-49	ACTOR: ILD OPS 8-6700
A18E, & KA04, xZA02, xZA04		
5, G6(+), G7, G8(+) 5, L-G6, L-G7		
5		
5		
m)		
SFM.	SPEC S	HEETS
۱.	REVISION:	PAGE NUMBER:
	0	SS

# Intertek

## AUTHORIZATION TO MARK

ED 16.3.15 (15-Oct-20) Mandatory

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Unirac, Inc	Manufacturer:
Address:	1411 Broadway Blvd NE Albuquerque, NM 87102	Address:
Country:	USA	Country:
Contact:	Klaus Nicolaedis Todd Ganshaw	Contact:
Phone:	505-462-2190 505-843-1418	Phone:
FAX:	NA	FAX:
Email:	klaus.nicolaedis@unirac.com toddg@unirac.com	Email:
Party Autho Report Issui	rized To Apply Mark: Same ing Office: Lake I	rest, CA
Control Nun	nber: <u>5003705</u>	thorized by:

This document supersedes all previous Authorizations to Mark for the noted Report Number.

Intertek

This Authorization to Mark is for the exclusive use of Interfek's Client and is provided pursuant to the Certification agreement between Interfek and its Client. Interfek's responsibility and liability are imited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasionee by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and thes only in its entirety. Use of Intertek's Certification mark is restricted to the conditions taid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must finit be approved in writing by intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

> Intertek Testing Services NA Inc. 545 East Algonquin Road, Arlington Heights, IL 60005 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Mounting Systems, Mounting Plate Photovoltaic Modules a	Devices, Clamping/Retention Devices and Panels [UL 2703: 2015 Ed.1]	ces, and Ground Lugs for Use with Flat-
	Photovoltaic Module Racking	Systems [CSA LTR AE-001:2012]	
Product:	Photovoltaic Mounting Syste	m, Sun Frame Microrail Installation	Guide, PUB2021JAN13
Brand Name:	Unirac		
Models:	Unirac SFM		
ATM for Repor	t 102393982LAX-002	Page 1 of 3	ATM Issued: 13-May-2021

Intertek Total Quality, Assured

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Unirac, Inc		Manufacturer:
Address:	1411 Broadway Blvd Albuquerque, NM 87	NE 102	Address:
Country:	USA		Country:
Contact:	Klaus Nicolaedis Todd Ganshaw		Contact:
Phone:	505-462-2190 505-843-1418		Phone:
FAX:	NA		FAX:
Email:	klaus.nicolaedis@un toddg@unirac.com	irac.com	Email:
Party Autho Report Issui	rized To Apply Mark: ng Office:	Same as Manufacture Lake Forest, CA	Int
Control Nun	nber: <u>5014989</u>	Authorized by:	for L. Matth



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertsk's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertex's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertex name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

## Intertek Testing Services NA Inc. 545 East Algonquin Road, Arlington Heights, IL 60005 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Mounting Systems, Mounting Plate Photovoltaic Modules and	Devices, Clamping/Retention Device nd Panels [UL 2703: 2015 Ed.1]				
	Photovoltaic Module Racking Systems [CSA LTR AE-001:2012]					
Product:	Photovoltaic Mounting System	n, Sun Frame Microrail Installation G				
Brand Name:	Unirac					
Models:	Unirac SFM					
ATM for Report	102393982LAX-002	Page 2 of 3				

## AUTHORIZATION TO MARK



ew Snyder, Certification Manager

es, and Ground Lugs for Use with Flat-

uide, PUB2021JAN13

ATM Issued: 13-May-2021 ED 16.3.15 (15-Oct-20) Mandatory



# intertek

Total Quality. Assured.

## Listing Constructional Data Report (CDR)

Report Number	102393982LAX-002	Original 11-Apr-2016	Revised: 18-Jan-2021
Standard(s)	Mounting Systems, Mou with Flat-Plate Photovol Photovoltaic Module Ra	Inting Devices, Clamping/Retention taic Modules and Panels [UL 2703: cking Systems [CSA LTR AE-001:2	Devices, and Ground Lugs for Us 2015 Ed.1] 012]
Applicant	Unirac, Inc	Manufacturer 2	
Address	1411 Broadway Blvd NE Albuquerque, NM 87102	Address	
Country	USA	Country	
Contact	Klaus Nicolaedis Todd Ganshaw	Contact	
Phone	505-462-2190 505-843-1418	Phone	
FAX	NA	FAX	10
Email	klaus.nicolaedis@unirad toddg@unirac.com	c.com Email	2
Manufacturer 3		Manufacturer 4	·
Address		Address	
Country		Country	
Contact		Contact	
Phone		Phone	
FAX		FAX	
Email		Email	

Report No. 102393982LAX-002 Unirac, Inc Page 2 of 122

2.0 Product Description		
Product	Photovoltaic Mounting System, Sun Frame Microrail Installation	
Brand name	Unirac	
Description	The product covered by this report is the Sun Frame Micro Ra Rack Mounting System. This system is designed to provide be photovoltaic modules. The mounting system employs anodize that are roof mounted using the slider, outlined in section 4 of within this product, whereas the 3" Micro Rail, Floating Splice, electrically bond the modules together forming the path to gro The Micro Rails are installed onto the module frame by using with black oxide with a stainless type 300 bonding pin, torquer modules to the bracket. The bonding pin of the Micro Rail whe the anodized coating of the photovoltaic module frame (at bot creating a bonded connection from module to module. The grounding of the entire system is intended to be in accord National Electrical Code, including NEC 250: Grounding and B Photovoltaic Systems or the Canadian Electrical Code, CSA O revision in effect in the jurisdiction in which the project resides be adhered in addition to the national electrical codes. The Gr photovoltaic module, torqued in accordance with the installatio document.	
	which requires a minimum of 2 micro-inverters mounted to the engage cable.	

Page 1 of 122

This report is for the exclusive use of Intertex's Client and is provided pursuant to the agreement between Intertex and its Client. Intertex's responsibility and liability are limited to the terms and conditions of the agreement. Intertex assumes no flability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit coeping or distribution of this report and then only in its entirety. Any use of the leftex name or one of its marks for the sale or advertisement of the tested material product or service must first be approved in which go intertex. This report by their does not mply that the material product or service is or has ever been under an Intertex confication program.

Issued: 11-Apr-2016 Revised: 18-Jan-2021

## on Guide, PUB2021JAN13

ail roof mounted Photovoltaic onding and grounding to ed or mill finish aluminum brackets f this report. There are no rails , and 9" Attached Splice bund.

a stainless steel bolt anodized ad to 20 ft-lbs, retaining the nen bolted and torqued, penetrate attom flange) to contact the metal,

dance with the latest edition of the Bonding, and NEC 690: Solar C22.1 Part 1 in accordance to the s. Any local electrical codes must rounding Lug is secured to the on manual provided in this

L2703 certified grounding system, the same rail, and using the same



Report No. 102393982LAX-002 Unirac, Inc Page 3 of 122

Issued: 11-Apr-2016 Revised: 18-Jan-2021

2.0 Product Description

Models	Unirac SFM
Model Similarity	NA
Model Similarity Ratings	NA Fuse Rating: 30A Module Orientation: Portrait or Landscape Maximum Module Size: 17.98 ft <sup>3</sup> UL2703 Design Load Rating: 33 PSF Downward, 33 PSF Upward, 10 PSF Down-Slope Tested Loads - 50 psf/2400Pa Downward, 50psf/2400Pa Uplift, 15psf/720Pa Down Slope Trina TSM-255PD05.08 and Sunpower SPR-E20-327 used for Mechanical Loading Increased size ML test: Maximum Module Size: 22.3 ft <sup>2</sup> UL2703 Design Load Rating: 113 PSF Downward, 50 PSF Upward, 30 PSF Down-Slope LG355S2W-A5 used for Mechanical Loading test. Mounting configuration: Four mountings on each long side of panel with the longest span of 24" UL2703 Design Load Rating: 46.9 PSF Downward, 40 PSF Upward, 10 PSF Down-Slope LG395N2W-A5, LG360S2W-A5 and LG355S2W-A5 used for used for Mechanical Loading test. Mounting configuration: Six mountings for two modules used with the maximum span of 74.5" IEC 61646 Test Loads - 112.78 psf/5400Pa Downward, 50psf/2400Pa Uplift Fire Class Resistance Rating: - Class A for Steep Slope Applications when using Type 1 Modules. Can be installed at any interstitial gap. Installations must include Trim Rail. - Class A for Steep Slope Applications when using Type 2 Modules. Can be installed at any interstitial gap. Installations must include Trim Rail. - Class A fire Rated for Low Slope applications with Type 1 or 2 listed photovoltaic modules. This system was evaluated with a 5" gap between the bottom of the module and the roof's surface
-	with these racking systems
Other Ratings	NA

Report No. 102393982LAX-002 Unirac, Inc Page 39 of 122

## 7.0 Illustrations

Illustration 1- Other ratings

Manufacture	Module Model / Series			
Aleo	P-Series			
Astronergy	CH5M6612P, CH5M6612P/HV, CH5M6612P CH5M6612M/HV, CH5M6610M (BL)(BF)/(H CH5M72M-HC			
Auxin	AXN6M610T, AXN6P610T, AXN6M612T & AXN6P612T			
Axitec	AXI Power, AXI Premium, AXI Black Prem			
Boviet	BVM6610, BVM6612			
BYD	P6K & MHK-36 Series			
Canadian Solar	CS6V-M, CS6P-P, CS6K-M, CS5A-M, CS6K-MS, CS6U-P, CS6U-M, CS6X-P, CS6K-I CS6K-M, CS6K-P, CS6P-P, CS6P-M, CS3U-P, CS3U-MS, CS3K-P, CS3K-MS, CS1K-MS, CS3 CS3U, CS3U-MB-AG, CS3K-MB-AG, CS6K, CS6U, CS3L, CS3W, CS1H-MS, CS1U-MS			
Centrosolar America	C-Series & E-Series			
CertainTeed	CT2xxMxx-01, CT2xxPxx-01, CTxxxMxx-02, CTxxxM-03, CTxxxMxx-04, CTxxxHC11-04			
Dehui	DH-60M			
Eco Solargy	Orion 1000 & Apollo 1000			
FreeVolt	Mono PERC			
GCL	GCL-P6 & GCL-M6 Series			
Hansol	TD-AN3, TD-AN4, UB-AN1, UD-AN1			
Heliene	36M, 60M, 60P, 72M & 72P Series			
HT Solar	HT60-156(M) (NDV) (-F), HT 72-156(M/P)			
Hyundai	KG, MG, TG, RI, RG, TI, MI, HI & KI Series			
ITEK	iT, iT-HE & iT-SE Series			
Japan Solar	JPS-60 & JPS-72 Series			

ED 16.3.15 (15-Oct-20) Mandatory



Report No. 102393982LAX-002 Unirac, Inc Issued: 11-Apr-2016 Revised: 18-Jan-2021

## 7.0 Illustrations

T

Illustration 1a - Other Ratings Continue

Manufacture	Module Model / Series		
JA Solar	JAP6 60-xxx, JAM6-60-xxx/SI, JAM6(K)-60/ xxx, JAP6(k)-72-xxx/488, JAP72SYY-xxx/ZZ, JAP6(k)-60-xxx/488, JAP60SYY-xxx/ZZ, JAM6(k)-72-xxx/ZZ, JAM72SYY-xxx/ZZ, JAM6(k)-60-xxx/ZZ, JAM60SYY-xxx/ZZ. i. YY: 01, 02, 03, 09, 10 ii. ZZ: SC, PR, BP, HIT, IB, MW		
linko	JKM & JKMS Series		
Kyocera	KU Series		
LG Electronics	LG xxx S1C-A5, LG xxx N1C-A5, LGxxxQ1C(Q1K)-A5, LGxxxN1C(N1K)-A5, LGxxxS1CA5, LGxxA1C-A5, LGxxxN2T-A4, LGxxxS2T-A5, LGxxXPW-A5 LGxxxS2W-A5, LGxxxE1C-A5, LGxxxS2W-G4 LGxxxS1C-G4, LGxxxE1K-A5, LGxxxN2T-J5, LGxxxN1K(N1C)-V5, LGxxxQ1C(N2W)-V5,		
LONGI	LR6-60 & LR6-72 Series, LR4-60 & LR4-72 Series		
Mission Solar Energy	MSE Series		
Mitsubishi	MJE & MLE Series		
Neo Solar Power Co.	D6M & D6P Series		
Panasonic	VBHNXXXSA15 & SA16, VBHNXXXSA17 & SA18, VBHNXXXSA17(E/G) & SA18E, VBHNXXXKA01 & KA03 & KA04, VBHNXXXZA01, VBHNXXXZA02, VBHNXXXZA03, VBHNXXXZA04		
Peimar	SGxxxM (FB/BF)		
Phono Solar	PS-60, PS-72		
Q.Cells	Plus, Pro, Peak, G3, G4, G5, G6(+), G7, G8(+) Pro, Peak L-G2, L-G4, L-G5, L-G6, L-G7		

Report No. 102393982LAX-002 Unirac, Inc Page 41 of 122

## 7.0 Illustrations

Illustration 1aa - Other Ratings Continue

Manufacture	Module Model / Series		
	PEAK Energy Series,		
	PEAK Energy BLK2 Series,		
DEC	PEAK Energy 72 Series,		
nec.	TwinPeak 2 Series,		
	TwinPeak 2 BLK2 Series,		
	TwinPeak Series		
Renesola	Vitrus2 Series & 156 Series		
Risen	RSM Series		
S-Energy	SN72 & SN60 Series (40mm)		
Seraphim	SEG-6 & SRP-6 Series		
Sharp	NU-SA & NU-SC Series		
Silfab	SLA, SLG & BC Series		
Solaria	PowerXT		
Coloditional	Sunmodule Protect,		
Solarworld	Sunmodule Plus		
Sonali	55 230 - 265		
Suntech	STP		
Suniva	MV Series & Optimus Series		
Sun Edison/Flextronics	F-Series, R-Series & FLEX FXS Series		
SunPower	X-Series, E-Series & P-Series		
20010	TP572, TP596, TP654, TP660,		
Talesun	TP672, Hipor M, Smart		
Tesla	SC, SC B, SC B1, SC B2		
***	PA05, PD05, DD05, DE06, DD06, PE06,		
Irina	PD14, PE14, DD14, DE14, DE15, PE15H		
Upsolar	UP-MxxxP(-B), UP-MxxxM(-B)		
URE	D7MxxxH8A, D7KxxxH8A, D7MxxxH7A		
Vikram	Eldora, Solivo, Somera		
Waaree	AC & Adiya Series		
Winaico	WST & WSP Series		
Yinali	YGE & YLM Series		

ED 16.3.15 (15-Oct-20) Mandatory



CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

SHEET NAME:

SPEC SHEETS

REVISION:

0

SS

PAGE NUMBER:

Issued: 11-Apr-2016 Revised: 18-Jan-2021

ED 16.3.15 (15-Oct-20) Mandatory

From:	Deep Vora Intertek
To:	Klaus Nicolaedis
Cc:	Robert Danastasio; Sam Doshi Intertek
Subject:	RE: Unirac SFM module listing
Date:	Tuesday, July 27, 2021 6:31:09 PM
Attachments:	image003.png
	image004.png
	image005.png

Hello Klaus,

I can confirm that through your last UL 2703 report update for your Sun Frame Micro Rail PV Mounting System in May 2021, Intertek added the following list of solar module frames for REC PV module manufacturer after evaluation and frame profile comparison.

REC Alpha 72 is one of these added modules.

Please let me know if you need any other information.

REC Solar	Twin Peak 2SM 72	Yes	Twin Peak Series	es es twin Peak es Series es es		NA	Approved	
	Alpha Black	Yes			Yes		NA	Approved
	Alpha	Yes			Manufacturer	NA	Approved	
	Alpha 72	Yes			Similarity	NA	Approved	
	REC Twin Peak 2S 72	Yes Series			Yes Series	Email, and	NA	Approved
	Twin Peak 2S 72 XV	Yes				profile	NA	Approved
	Twin Peak 2SM 72 XV	Yes			Comparison	NA	Approved	
	N-Peak	Yes			Yes		NA	Approved
	N-Peak Black	Yes			NA	Approved		

Sunny regards, Deep Vora Photovoltaic Project Engineer



Total Quality, Assured 25800 Commercentre Drive Lake Forest, CA 92630 Email: <u>deep.vora@intertek.com</u> Mobile: +1 (480) 738 9760 Office: +1 (949) 393 3522 Ext: 11756805

From: Klaus Nicolaedis <Klaus.Nicolaedis@unirac.com> Sent: Monday, July 26, 2021 7:08 AM To: Deep Vora Intertek <deep.vora@intertek.com> Cc: Robert Danastasio <robert.danastasio@unirac.com> Subject: [External] Unirac SFM module listing

Hi Deep,

We have an AHJ questioning if the REC Alpha 72 is approved because of how we list the REC modules in the IM.

	Alpha (72) (Black)			
	N-Peak (Black)			
	PEAK Energy Series			
	PEAK Energy BLK2 Series			
956	PEAK Energy 72 Series			
REC	TwinPeak Series			
	TwinPeak 2 Series			
	TwinPeak 2 BLK2 Series			
	TwinPeak 2S(M)72(XV)			
	TwinPeak 3 Series (38mm)			

Can you send us an email with your signature block stating that the following modules are approved with SFM?

Alpha Alpha 72 Alpha Black

Kind regards,



1411 Broadway Blvd. NE, Albuquerque NM - 87102

Klaus Nicolaedis CERTIFICATION ENGINEER Unirac, Inc. klaus.nicolaedis@unirac.com direct 505.462.2190

## CONFIDENTIALITY NOTICE

This email may contain confidential or privileged information, if you are not the intended recipient, or the person responsible for delivering the message to the intended recipient then please notify us by return email immediately. Should you have received this email in error then you should not copy this for any purpose nor disclose its contents to any other person.

This message is from an EXTERNAL SENDER - please be CAUTIOUS, particularly with links and attachments.

# S

# **SYSTEM COMPONENTS** INSTALLATION GUIDE PAGE



## Trimrail<sup>™</sup> and Module Clips

## Sub-Components:

- 1. Trim Rail
- 2. Module Clip
- 3. T-Bolt
- Tri-Drive Nut 4.

## Trimrail™

## Functions:

- Required front row structural support (with module clips)
- Module mounting ٠
- Installation aid ٠
- . Aesthetic trim

## Features:

- Mounts directly to L-feet ٠
- Aligns and captures module leading edge .
  - Supports discrete module thicknesses from 32, 33, 35, 38, and 40mm

## **Module Clips**

## Functions:

- Required front row structural support (with trimrail)
- Module mounting •

## Features:

- Mounts to Trimrail<sup>™</sup> with T-bolt and tri-drive nut
- Manually adjustable to fit module thicknesses 32, 33, 35, ٠ 38, and 40mm.



## Trimrail<sup>™</sup> Flashkit

## Sub-Components:

L-Foot Hex bolt Tri-drive nut Channel Nut Scocket Head Cap Screw 3"Channel/Slider w/grommet 3" Wide Flashing Structural Screw & SS EPDM Washer

## Functions:

- Attach Trimrail<sup>™</sup> to roof attachment / flashing
- Patented roof sealing technology at roof attachment point •

## Features:

- Slot provides vertical adjustments to level array
- Slider provides north/south adjustment along the slope of the roof
- Shed and Seal Technology

## Sub-Components:

- 1. Structural Splice Extrusion
- 2. Bonding Clip

## **Functions:**

- Front row structural support
- Installation aid

- Features:
- Tool-less installation

**Trimrail<sup>™</sup> Splice** 





1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.

Structurally connects 2 pieces of Trimrail<sup>™</sup> Electrically bonds 2 pieces of Trimrail<sup>™</sup>

Aligns and connects Trimrail<sup>™</sup> pieces

NABCEP CERTIFIED PV INSTALLATION PROFESSIONAL Scott Gurney # PV-011719-015866			
CONTR BRS FIE 385.49	ACTOR: ELD OPS 8.6700		
SPEC S	HEET		
PAGE NUMBER	REVISION 0		

# **SYSTEM COMPONENTS** INSTALLATION GUIDE PAGE



## SFM Slider Flashkit

S

## Sub-Components:

- 1. Slider w/grommet
- 2. Structural Screw & SS EPDM washer
- 3. 3" Wide Flashing

## Functions:

- Patented Shed & Seal roof sealing technology at roof attach-. ment point
- For use with compatible 2" Microrail or 8" Attached Splices ٠

## Features:

- . Slider provides north/south adjustment along the slope of the roof
- Shed and Seal Technology ٠



## Module-to-Module N-S Bonding

## Sub-Components:

- 1. Clamp
- Bonding Pins (2) 2.
- 3. 5/16" Socket Head Cap Screw
- 4. Clamp Base

## **Functions/** Features:

- Row to row bonding
- Single Use Only
- Fits module sizes 32-40mm



## Trim -to- Module Bonding Clamp and Floating Trim Clamp

## Sub-Components:

- 1. Wedge
- Bonding Pin 2.
- 3. T-Bolt
- Nut 4.
- Cast Base 5.

## **Functions/Features:**

- Module to Trimrail<sup>™</sup> bonding single use only •
- Attaches Trimrail<sup>™</sup> to module when fewer than 2 rafter attachment points are available
- Fits module sizes 32-40mm
- Fits module sizes 32-40mm



## Wire Bonding Clip w/ 8AWG

## Functions:

- Row to row bonding
- Module to Trimrail<sup>™</sup> bonding
- Single Use Only

## Features:

Tool-less installation



## **MLPE Mounting Assembly**

## Sub-Components:

- 1. MLPE Mount Base
- 2. 5/16 Socket Head Cap Screw
- 3. Bonding Pin

## Functions:

- MLPE to module bonding

## Features:

UL2703 Recognized

MLPE = Module Level Power Electronics, e.g. microinverter or power optimizer



Securely mounts MLPE to module frames

Mounts easily to typical module flange



1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



CONTRACTOR: **BRS FIELD OPS** 385.498.6700

HEET NAME SPEC SHEET

AGE NUMBER SS

REVISION 0







Place flashings

**PILOT HOLES:** marked attachement points

Drill pilot holes for lag screws or structural screws (as necessary) at





## INSTALL SLIDERS AND TRIMRAIL ROOF ATTACHMENTS:

• Insert flashings per manufacturer instructions

NOTE: Use Lag screw or structural fastener with a maximum diameter of 5/16"

- Attach sliders to rafters •
- Verify proper row to row spacing for module size (Mod NS + 1") ٠
- Ensure that TrimrailTM roof attachments in each row have sufficient • engagement with slider dovetails for proper attachment.

