



## Historic Preservation Services

Community Development & Neighborhood Services

281 North College Avenue

P.O. Box 580

Fort Collins, CO 80522.0580

970.416.4250

[preservation@fcgov.com](mailto:preservation@fcgov.com)

[fcgov.com/historicpreservation](http://fcgov.com/historicpreservation)

### **CERTIFICATE OF APPROPRIATENESS – Minor Alteration**

**ISSUED: August 31, 2022**

**EXPIRATION: August 31, 2023**

Livingston Holdings, LLC  
c/o Greg Farris, Front Range Roofing Systems  
736 Whalers Way, Bldg G, Ste 201  
Fort Collins, CO 80525

Dear Greg Farris:

This letter provides you with certification that proposed work to your designated Fort Collins landmark property, the Philippi Harness Shop at 218 Linden St. has been approved by the City's Historic Preservation Division (HPD) because the proposed work appears to be routine in nature with minimal effects to the historic resource, and meets the requirements of Chapter 14, [Article IV](#) of the Fort Collins Municipal Code.

The alterations reviewed include:

- Roofing - Install 11 squares of Carlisle shingles. No materials/layers being removed. Not removing materials to the decking. Provide required attic ventilation. Install required ice and water shield. Install per manufacturers high wind specifications. R30 minimum insulation, maintain positive drainage. One story, flat roof. License/Certificate holder to do the work.

Notice of the approved application has been provided to building and zoning staff to facilitate the processing of any permits that are needed for the work. Please note that work beyond that indicated in your permit application/correspondence requires additional approval. Items requiring further approval include, but are not limited to, the following activities:

- Work affecting, or repair of, a chimney;
- Repair or replacement of historic decorative or functional features on or near the roof, such as fascia, purlins, brackets, eaves, gutters, and dormers;
- Installation of roof insulation above the sheathing that will result in more than a 4-inch increase in the roof height; (note: uncovered portions at the eave should be covered with plain fascia or drip edge);
- Addition of new rooftop features including skylights, dormers, and large new vents (note: no further review is needed to install standard edge, ridge, or "turtle" vents required for meeting ventilation standards on new roofs).

If the approved work is not completed prior to the expiration date noted above, you may apply for an extension by contacting staff at least 30 days prior to expiration. Extensions may be granted for up to 12 additional months, based on a satisfactory staff review of the extension request.

If you have any questions regarding this approval, or if I may be of any assistance, please do not hesitate to contact me. I can be reached at [yjones@fcgov.com](mailto:yjones@fcgov.com) or at (970) 224-6045.

Sincerely,

Yani Jones  
Historic Preservation Planner