



GENERAL NOTES

1. Use direct tap (as shown) for 3/4 inch and 1 inch services unless water main is PVC, in which case, use a tapping saddle.
2. Install 1 1/2 inch and 2 inch services with tapped tee and corporation stop at time of construction or use a tapping saddle.
3. Locate curb box and meter pit according to the approved utility drawings.
4. The City is responsible for maintaining the water main, corporation stop, and service piping up to and including the curb stop. The owner is responsible for service from the curb stop, including the outlet coupling to the building.
5. No couplings allowed between curb stop and meter setting.
6. Use type K copper for the service from the corporation stop to a minimum of 5 feet past the meter pit.
7. No landscaping (shrubs, boulders, etc.), retaining walls or fences allowed within 4 feet of the curb stop and meter pit, and no trees within 10 feet of curb and meter pit.
8. All residential water service shall be installed in the center of the lot unless otherwise approved by the Utility.
9. All water and sanitary sewer service shall have a minimum horizontal separation of ten feet.



CITY OF FORT COLLINS
 UTILITIES - WATER
 FIELD OPERATIONS
 P.O. BOX 580
 FORT COLLINS, CO. 80550
 (970) 221-6700

TITLE OF DRAWING

TYPICAL WATER SERVICE

REVISED DATE:
 4/12/11
 DETAIL
 11