



GENERAL NOTES:

1. PROVIDE CLEAR AND UNOBSTRUCTED 2 FT. BY 2 FT. MINIMUM ACCESS TO THE COPPERHORN AND SHUTOFF VALVES.
2. ELECTRICAL CONDUIT WILL BE 1/2 INCH OR LARGER ELECTRICAL METALLIC TUBING ONLY, INSTALLED IN CONFORMANCE WITH ARTICLES 347 AND 348 OF THE CURRENT NATIONAL ELECTRIC CODE. CONDUIT MAY NOT EXTEND MORE THAN 75 FEET BETWEEN JUNCTION BOXES. CONDUIT WILL BE CONNECTED TO A RECESSED EXTERIOR ELECTRICAL BOX MOUNTED WITHIN 1 FOOT OF THE FRONT CORNER OF THE STRUCTURE ON THE SAME SIDE AS THE ELECTRIC METER AND TERMINATED WITHIN 6 INCHES OF THE COPPERHORN. NO FLEXIBLE PVC CONDUIT ALLOWED.
3. ALL JUNCTION BOXES MUST BE INSTALLED NO MORE THAN 96 INCHES ABOVE THE FLOOR AND HAVE OPEN ACCESS.
4. COPPERHORNS WILL BE INSTALLED SO THAT METERS ARE IN A HORIZONTAL POSITION.
5. A SECURE SUPPORT IS REQUIRED FOR COPPERHORNS.
6. JUNCTION BOXES SHALL NOT BE INSTALLED IN ATTICS OR CRAWL SPACES.
7. METERS SHALL NOT BE INSTALLED IN CRAWL SPACES.