

GENERAL NOTES:

1. DO NOT INSTALL IN ANY STREET, ALLEY, PARKING AREA, DRIVEWAY, DRAINAGE DITCH OR DETENTION BASIN.
2. NO LANDSCAPING (SHRUBS, BOULDERS, ETC.) OR STRUCTURES TO BE WITHIN 4 FEET OF METER BOX, OR NO TREES WITHIN 6 FEET OF METER BOX.
3. SLOPE GROUND SURROUNDING METER BOX AWAY FROM LID AT 2% GRADE FOR A MIN DISTANCE OF 4 FEET.
4. MAKE NO PLUMBING CONNECTIONS (TEES, COUPLINGS, ETC.) IN METER BOX.
5. ALL TEES AND CONNECTION FITTINGS TO BE A MINIMUM OF 2 FEET FROM METER BOX WALL ON OUTLET SIDE.
6. GRADE ACCEPTANCE AFTER METER BOX INSTALLATION REQUIRES THAT THE OWNER ADJUST METER BOX COVER TO 1/2 INCH ABOVE FINAL GRADE.
7. IF A PRESSURE REDUCING VALVE IS REQUIRED BY PLUMBING CODE, INSTALL VALVE INSIDE THE BUILDING, IMMEDIATELY FOLLOWING THE MAIN SHUT-OFF VALVE.
8. REFER TO QUICK REFERENCE FOR INSTALLATION OF EXTERIOR SETTING FOR 3/4 " AND 1" WATER METERS (QUICK REFERENCE 15)

STANDARD EXTERIOR SETTING FOR 3/4" AND 1" WATER METERS

City of Fort Collins	CITY OF FORT COLLINS UTILITIES P.O. BOX 580 FORT COLLINS, CO. 80522 (970) 221-6759	WATER CONSTRUCTION DETAILS	APPROVED: DATE REVISED: 4/20/2022 DRAWN BY: SAA	DETAIL W-15