



GENERAL NOTES

1. Do not install in any street, alley, parking area, driveway, sidewalk, drainage ditch or detention basin.
2. No landscaping (shrubs, boulders, etc.) or structures to be within 4 feet of meter box, or No trees within 10 feet of meter box.
3. Slope ground surrounding meter box away from lid at 2% minimum grade.
4. Make no plumbing connections (tees, couplings, etc.) in meter box.
5. All tees and connection fittings to be a minimum of 5 feet from meter box wall on outlet side.
6. Grade acceptance after meter box installation requires that the owner adjust meter box cover to 1/2 inch above final grade.
7. If a pressure reducing valve is required by Plumbing Code, install valve inside the building, immediately following the main shut-off valve.