



GENERAL NOTES:

1. SUPPORT METER SETTERS BY (2) 18 INCH LENGTHS OF 1 INCH IRON PIPE INSERTED THROUGH BRACE PIPE EYELETS AND SET ATOP (4) 8 INCH SQUARE CONCRETE BLOCKS.
2. DO NOT INSTALL IN ANY STREET, ALLEY, PARKING AREA, DRIVEWAY, SIDEWALK, DRAINAGE DITCH OR DETENTION BASIN.
3. NO LANDSCAPING (TREES, SHRUBS, BOULDERS, ETC.) OR RETAINING WALLS TO BE WITHIN 4 FEET OF METER PIT AND NO TREES WITHIN 10 FEET.
4. THE METER PIT AND AMR POD(S) MUST REMAIN OPEN AND ACCESSIBLE FOR METER READING AND MAINTENANCE.
5. SLOPE GROUND SURROUNDING METER PIT AWAY FROM LID AT 2% GRADE OR GREATER.
6. MAKE NO PLUMBING CONNECTIONS (TEES, COUPLINGS, ETC.) IN METER PIT.
7. ALL TEES, COUPLINGS AND CONNECTION FITTINGS TO BE A MINIMUM OF 5 FEET FROM METER PIT WALL (MIN. OUTLET SIDE).
8. GRADE ACCEPTANCE AFTER METER PIT INSTALLATION REQUIRES THAT THE OWNER ADJUST METER PIT COVER TO 1/2 INCH ABOVE LANDSCAPED FINAL GRADE.
9. IF A PRESSURE REDUCING VALVE IS REQUIRED BY PLUMBING CODE, IT SHALL BE INSTALLED INSIDE THE BUILDING, IMMEDIATELY FOLLOWING THE MAIN SHUT-OFF VALVE.
10. A SEPERATE AMR POD MUST BE INSTALLED FOR EACH METER REGISTER.



CITY OF FORT COLLINS
 UTILITIES - WATER
 FIELD OPERATIONS
 P.O. BOX 580, FORT COLLINS,
 CO. 80522 (970) 221-6700

TITLE OF DRAWING
**STANDARD SETTING FOR 1-1/2 IN. AND 2 IN.
 WATER METERS**

REVISED DATE:
 6/23/10
**DETAIL
 16-A**