



GENERAL NOTES:

1. IF A PRESSURE REDUCING VALVE IS REQUIRED BY PLUMBING CODE, INSTALL VALVE INSIDE THE BUILDING IMMEDIATELY FOLLOWING THE MAIN SHUT OFF VALVE.
2. ALL JOINTS OUTSIDE OF VAULT SHALL BE RESTRAINED MECHANICAL JOINTS. (REFERENCE SECTION 02615)
3. ALL PIPING WITHIN VAULT SHALL BE D.I.P. WITH FLANGED FITTINGS, EXCEPT FOR THE SOLID SLEEVES.
4. GATE VALVES MUST OPEN RIGHT AND BE EPOXY COATED, RESILIENT SEAT WITH A HAND WHEEL ASSIST.
5. FOR IRRIGATION ONLY SERVICES, NO BYPASS ALLOWED.
6. METER INSTALLATION DESIGN FOR 6 IN. AND LARGER METERS SHALL BE DETERMINED BY THE UTILITY.
7. LOCATION AND ALIGNMENT OF AMR POD(S) ON VAULT TOP CAN VARY.
8. A SEPERATE AMR POD MUST BE INSTALLED FOR EACH METER REGISTER.