



GENERAL NOTES:

1. DO NOT INSTALL IN ANY STREET, ALLEY, PARKING AREA, DRIVEWAY, SIDEWALK DRAINAGE DITCH OR DETENTION BASIN.
2. NO LANDSCAPING (SHRUBS, BOULDERS, ECT.) OR STRUCTURES TO BE WITHIN 4 FT. OR TREES WITHIN 10 FT. OF METER VAULT.
3. SLOPE GROUND SURROUNDING METER VAULT AWAY FROM LID AT 2% GRADE OR GREATER.
4. MAKE NO PLUMBING CONNECTIONS (TEES, COUPLINGS, ECT.) IN METER VAULT.
5. GRADE ACCEPTANCE AFTER METER PIT INSTALLATION REQUIRES THAT THE OWNER ADJUST METER VAULT COVER TO 1/2 IN. ABOVE FINAL GRADE.
6. IF A PRESSURE REDUCING VALVE IS REQUIRED BY PLUMBING CODE, IT SHALL BE INSTALLED INSIDE THE BUILDING, IMMEDIATELY FOLLOWING THE MAIN SHUT-OFF VALVE.