

PART I - DISCHARGE LIMITATIONS and REQUIREMENTS

A. **Permitted Wastes:** Only those wastes described below may be discharged to the Sanitary Waste Transfer Station.

1. Septage waste. Septage waste shall be defined as liquid or solid material removed from a septic tank, cesspool, pit toilet, portable toilet, type III marine sanitation device or similar treatment works that receives only domestic sewage.
2. The pH of all discharges must be equal to or greater than 5.0 and less than or equal to 11.0.
3. Other wastewaters may be discharged with prior written approval from the City of Fort Collins Utilities. Approval may be granted by the following individuals or other individuals as designated by the Utilities.

<u>Title</u>	<u>Name</u>	<u>Phone</u>	<u>Cell</u>
Technical Services Supervisor	Allison Becker	970-221-6927	970-412-5368
Process Control Supervisor	Ramon Arguello	970-221-6925	970-980-4595
Water Reclamation & Biosolids Manager	Jason Graham	970-221-6921	970-231-9729

B. **Prohibited Wastes:**

1. Grease trap wastes.
2. Car wash or other automotive sand trap wastes.
3. Wastes defined as hazardous waste by 40 CFR Part 261.
4. Process and domestic wastewater from oil or gas well sites.
5. Industrial wastes regulated by categorical standards in 40 CFR Parts 405-471.
6. Prohibited wastes included in Sec. 26-337 of the City Code.
7. All wastes other than septage wastes, unless prior written approval for the discharge has been obtained from the City of Fort Collins Utilities.

C. **Refusal to Allow Discharge:** The Fort Collins Utilities reserves the right to refuse acceptance of any hauled waste load from the permittee. This refusal may be based on sampling and analysis results, review of the hauled waste manifest, visible characteristics of the waste, any criteria in Part I, Section A or B of this permit, or for any other reason as determined by the Utilities.

D. **Removal of Waste from Holding Tank:** The Fort Collins Utilities reserves the right to refuse a load of hauled waste held in the Utilities holding tank for any reason as specified in Part I, Section A, B, or C of this permit. If a load held in the Utilities holding tank is later refused, the permittee shall remove the waste from the holding tank within 24 hours of notification and shall pay all costs of such removal and for any sampling and analysis costs incurred by the Utilities.