



ALTERNATE BASE

MINIMUM INSIDE DIAMETER OF MANHOLE SHALL BE AS FOLLOWS:

PIPE SIZE	MIN. MANHOLE DIAMETER
15 IN. OR LESS	48 IN.
18 IN. TO 30 IN.	60 IN.
OVER 30 INCHES	72 IN.

STANDARD MANHOLE



SEWER CONSTRUCTION
DETAILS

APPROVED:

DATE: 08/19/02

DRAWN BY: NBJ

DETAIL
WW-3